

1

# **GE Energy**

James C. Kinsey Project Manager, ESBWR Licensing

PÕ Box 780 M/C J-70 Wilmington, NC 28402-0780 USA

T 910 675 5057 F 910 362 5057 jim.kinsey@ge.com

MFN 07-240

Docket No. 52-010

May 2, 2007

U.S. Nuclear Regulatory Commission Document Control Desk Washington, D.C. 20555-0001

# Subject: Response to Portion of NRC Request for Additional Information Letter No. 70 Related to ESBWR Design Certification Application – Standby Liquid Control – RAI Number 14.3-84

Enclosure 1 contains GE's response to the subject NRC RAI transmitted via the Reference 1 letter.

If you have any questions or require additional information regarding the information provided here, please contact me.

Sincerely,

Bathy Sedney for

James C. Kinsey Project Manager, ESBWR Licensing



MFN 07-240 Page 2 of 2

j

### Reference:

1. MFN 06-382, Letter from U.S. Nuclear Regulatory Commission to David Hinds, *Request for Additional Information Letter No. 70 Related to ESBWR* Design Certification Application, October 10, 2006

### Enclosure:

- MFN 07-240 Response to Portion of NRC Request for Additional Information Letter No. 70 Related to ESBWR Design Certification Application – Standby Liquid Control – RAI Number 14.3-84
- cc:AE CubbageUSNRC (with enclosures)DH HindsGE (with enclosures)RE BrownGE (w/o enclosures)eDRF0000-0067-3673

**Enclosure 1** 

1

MFN 07-240

# Response to Portion of NRC Request for Additional Information Letter No. 70 Related to ESBWR Design Certification Application Standby Liquid Control – RAI Number 14.3-84

# MFN 07-240 Enclosure 1

Page 1 of 1

# NRC RAI 14.3-84

The following ITAAC should be added to Table 2.2.4-2, ITAAC For The Standby Liquid Control System:

- 13. Existing ITAAC in the SLC does not check for the flow rate of the as built SLC system into the RPV. This design commitment should also identify the reactor pressure at which the flow rate is delivered.
- 14. Manual initiation of the SLC from the main control room.
- 15. Both divisions of the SLC system are automatically initiated during an ATWS event.

### **GE** Response

Tier 1, Rev. 3 addresses the concerns in RAI 14.3-84. The Item 13 concerns are addressed in ITAAC 3 and 4. The Item 14 concern is addressed in DD Instrumentation Bullet 4 in conjunction with ITAAC 8. The Item 15 concern is addressed in ITAAC 2.f.

### **DCD** Impact

No additional DCD change will be made in response to this RAI.