

May 23, 2007

Mr. Michael R. Kansler
President
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

SUBJECT: JAMES A. FITZPATRICK NUCLEAR POWER PLANT - RESPONSE TO
GENERIC LETTER 2006-02 "GRID RELIABILITY AND THE IMPACT ON
PLANT RISK AND THE OPERABILITY OF OFFSITE POWER" (TAC NO.
MD0982)

Dear Mr. Kansler:

On February 1, 2006, the U.S. Nuclear Regulatory Commission (NRC) issued Generic Letter (GL) 2006-02, "Grid Reliability and the Impact on Plant Risk and the Operability of Offsite Power" (Agencywide Document Access and Management System (ADAMS) Accession No. ML060180352) to all holders of operating licenses for nuclear power reactors except those who have permanently ceased operation and have certified that fuel has been removed from the reactor vessel.

GL 2006-02 notified licensees of the NRC staff's need for information in four areas as follows:

(1) use of protocols between the nuclear power plant (NPP) and the transmission system operator (TSO), independent system operator (ISO), or reliability coordinator/authority (RC/RA) and the use of transmission load flow analysis tools (analysis tools) by TSOs to assist NPPs in monitoring grid conditions to determine the operability of offsite power systems under plant technical specifications (TSs). (The TSO, ISO, or RA/RC is responsible for preserving the reliability of the local transmission system. In this GL, the term TSO is used to denote these entities);

(2) use of NPP/TSO protocols and analysis tools by TSOs to assist NPPs in monitoring grid conditions for consideration in maintenance risk assessments;

(3) offsite power restoration procedures in accordance with Section 2 of NRC Regulatory Guide (RG) 1.155, "Station Blackout;" and

(4) losses of offsite power caused by grid failures at a frequency equal to or greater than once in 20 site-years in accordance with RG 1.155.

Subsequent to the GL, the NRC issued a Request for Additional Information (RAI), (ADAMS Accession No. ML063380308) regarding the resolution of GL 2006-02 to 63 of 65 holders of operating licenses for nuclear power reactors. The RAI requested licensees respond to questions in the following areas:

M. Kansler

- 2 -

- (1) Switchyard Minimum Voltage;
- (2) Loss of Real-Time Contingency Analysis (RTCA) Capability;
- (3) Verification of RTCA Predicted Post-Trip Voltage;
- (4) Identification of Applicable Single Contingencies;
- (5) Seasonal Variation in Grid Stress (reliability and Loss-of-offsite power (LOOP) Probability);
- (6) Interface With Transmission System Operator During Extended Plant Maintenance.

By letters dated March 30, 2006, and January 29, 2007, (ADAMS Accession Nos. ML060940178 and ML070380311) you responded to the information request of GL 2006-02 and the subsequent RAI. Based on the information you provided, the NRC staff has concluded that compliance is being maintained with NRC regulatory requirements governing electric power sources and associated personnel training and considers your response to GL 2006-02 complete.

Please contact me at (301) 415-2901 if you have any questions on this issue.

Sincerely,

/RA/

John P. Boska, Senior Project Manager
Plant Licensing Branch I-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-333

cc: See next page

M. Kansler

- 2 -

- (1) Switchyard Minimum Voltage;
- (2) Loss of Real-Time Contingency Analysis (RTCA) Capability;
- (3) Verification of RTCA Predicted Post-Trip Voltage;
- (4) Identification of Applicable Single Contingencies;
- (5) Seasonal Variation in Grid Stress (reliability and Loss-of-offsite power (LOOP) Probability);
- (6) Interface With Transmission System Operator During Extended Plant Maintenance.

By letters dated March 30, 2006, and January 29, 2007, (ADAMS Accession Nos. ML060940178 and ML070380311) you responded to the information request of GL 2006-02 and the subsequent RAI. Based on the information you provided, the NRC staff has concluded that compliance is being maintained with NRC regulatory requirements governing electric power sources and associated personnel training and considers your response to GL 2006-02 complete.

Please contact me at (301) 415-2901 if you have any questions on this issue.

Sincerely,

/RA/

John P. Boska, Senior Project Manager
 Plant Licensing Branch I-1
 Division of Operating Reactor Licensing
 Office of Nuclear Reactor Regulation

Docket No. 50-333

cc: See next page

DISTRIBUTION:

PUBLIC RidsNrrDorLp1-1 RidsNrrPMJBoska RidsOGCMailCenter
 LPL1-1 Reading File RidsNrrLASLittle RidsAcrsAcnwMailCenter
 ECobey, RI RidsNrrDeEeeb

ADAMS ACCESSION NUMBER: ML071410284

OFFICE	LPL1-1/PM	LPL1-1/LA	EEEB/BC	LPL1-1/BC
NAME	JBoska	SLittle	GWilson	MKowal
DATE	5/21/07	5/22/07	5/22/07	5/23/07

OFFICIAL RECORD COPY

FitzPatrick Nuclear Power Plant

cc:

Mr. Gary J. Taylor
Chief Executive Officer
Entergy Operations, Inc.
1340 Echelon Parkway
Jackson, MS 39213

Mr. John T. Herron
Sr. VP and Chief Operating Officer
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. Peter T. Dietrich
Site Vice President
Entergy Nuclear Operations, Inc.
James A. FitzPatrick Nuclear Power Plant
P.O. Box 110
Lycoming, NY 13093

Mr. Kevin J. Mulligan
General Manager, Plant Operations
Entergy Nuclear Operations, Inc.
James A. FitzPatrick Nuclear Power Plant
P.O. Box 110
Lycoming, NY 13093

Mr. Oscar Limpias
Vice President Engineering
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. Christopher Schwarz
Vice President, Operations Support
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. John F. McCann
Director, Licensing
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Ms. Charlene D. Faison
Manager, Licensing
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. Michael J. Colomb
Director of Oversight
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. David Wallace
Director, Nuclear Safety Assurance
Entergy Nuclear Operations, Inc.
James A. FitzPatrick Nuclear Power Plant
P.O. Box 110
Lycoming, NY 13093

Mr. James Costedio
Manager, Regulatory Compliance
Entergy Nuclear Operations, Inc.
James A. FitzPatrick Nuclear Power Plant
P.O. Box 110
Lycoming, NY 13093

Assistant General Counsel
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Resident Inspector's Office
James A. FitzPatrick Nuclear Power Plant
U. S. Nuclear Regulatory Commission
P.O. Box 136
Lycoming, NY 13093

FitzPatrick Nuclear Power Plant

cc:

Mr. Charles Donaldson, Esquire
Assistant Attorney General
New York Department of Law
120 Broadway
New York, NY 10271

Mr. Garrett D. Edwards
814 Waverly Road
Kennett Square, PA 19348

Mr. Peter R. Smith, President
New York State Energy, Research,
and Development Authority
17 Columbia Circle
Albany, NY 12203-6399

Mr. Paul Eddy
New York State Dept. of Public Service
3 Empire State Plaza
Albany, NY 12223-1350

Oswego County Administrator
Mr. Steven Lyman
46 East Bridge Street
Oswego, NY 13126

Supervisor
Town of Scriba
Route 8, Box 382
Oswego, NY 13126

Mr. James H. Sniezek
BWR SRC Consultant
5486 Nithsdale Drive
Salisbury, MD 21801-2490

Mr. Michael D. Lyster
BWR SRC Consultant
5931 Barclay Lane
Naples, FL 34110-7306