



CALCULATION SUMMARY SHEET (CSS)

Document Identifier 32 - 9049429 - 000

Title North Anna Units 1 & 2 PZR Safety/Relief Nozzle Weld Overlay Crack Growth Evaluation

PREPARED BY:

REVIEWED BY:

METHOD: DETAILED CHECK INDEPENDENT CALCULATION

NAME H. P. Gunawardane

NAME D. E. Killian

SIGNATURE

SIGNATURE

TITLE ENGINEER IV

DATE 4/27/07

TITLE ADVISORY ENGINEER

DATE 4/27/07

COST CENTER 41304

REF. PAGE(S) 36

TM STATEMENT: REVIEWER INDEPENDENCE BD

NAME B. DJAZMATI

PURPOSE AND SUMMARY OF RESULTS:

Purpose: This document is a non-proprietary version of AREVA NP Document Number 32-9043013-000. The proprietary information removed from 32-9043013-000 is indicated by a pair of square brackets "[]". The geometry and operating conditions are Dominion Power proprietary. The purpose of the present analysis is to evaluate the fatigue crack growth of a partial through-wall 360° circumferential flaw into the Alloy 52M weld overlays at the North Anna Units 1 & 2 Pressurizer Safety and Relief Nozzles. This evaluation is performed at both the Alloy 82/182 butt weld joining the nozzle to safe end and the stainless steel weld joining the safe end to piping.

Results/Conclusion: After 33 years of operation, fatigue crack growth into the overlay material at both materials (Alloy 82/182 and stainless steel) is minimal and is summarized in the table below:

		DM WELD OVERLAY	SS WELD OVERLAY
Min WOL thickness,	$t_{wol} =$	[]	
Additional WOL thickness required,	$\Delta t_{wol} =$		
Initial flaw size,	$a_i =$	1.1500 in.	0.6500 in.
Final flaw size after 33 years,	$a_f =$	1.1506 in.	0.6502 in.
Flaw growth,	$\Delta a =$	0.0006 in.	0.0002 in.
Allowable crack depth to thickness ratio,	$(a/t)_{all} =$	0.7500	0.7500
Final crack depth to thickness ratio,	$(a/t)_{final} =$	0.7457	0.4648

The final configuration at the overlaid locations meets the Section XI, Appendix C acceptance criteria and the remaining ligament also satisfies basic applied membrane stress considerations.

THE FOLLOWING COMPUTER CODES HAVE BEEN USED IN THIS DOCUMENT:

CODE/VERSION/REV

CODE/VERSION/REV

THE DOCUMENT CONTAINS ASSUMPTIONS THAT MUST BE VERIFIED PRIOR TO USE ON SAFETY-RELATED WORK

YES

NO

RECORD OF REVISIONS

<u>Revision</u>	<u>Affected Pages</u>	<u>Description of Revision</u>	<u>Date</u>
000	All	Original release	04/07

TABLE OF CONTENTS

1.0 Purpose..... 6

2.0 Analytical Methodology 8

3.0 Key Assumptions 9

4.0 Calculations 10

 4.1 Postulated Flaw Shape 10

 4.2 Geometry..... 10

 4.3 Mechanical Properties 11

 4.4 Fatigue Crack Growth..... 11

 4.5 Stress Intensity Factor Solution 12

 4.6 Applied Stresses..... 12

 4.6.1 Transient Stresses 12

 4.6.2 Sustained Stresses 13

 4.6.3 Residual Stress in Welds 14

 4.7 Flaw Growth Analysis 15

 4.8 Limit Load Check..... 15

 4.9 Applied Membrane Stress Check..... 17

5.0 Results and Conclusion..... 18

 5.1 DM Weld Overlay..... 18

 5.2 SS Weld Overlay 29

 5.3 Conclusion..... 35

6.0 References..... 36

7.0 Computer Output..... 37

LIST OF TABLES

Table 1. Mechanical Properties of Alloy 52M	11
Table 2. Sustained Loads at the Safe End	13
Table 3. Sustained Loads at the Nozzle	14
Table 4. Loading Conditions for Limit Load Check at Safe End	16
Table 5. Loading Conditions for Limit Load Check at Nozzle	16
Table 6. Evaluation of Partial Through-Wall Circumferential Flaw in DM Weld Overlay	19
Table 7. Limit Load Results at DM Weld Overlay	28
Table 8. Applied Membrane Stress Check at DM Weld Overlay	28
Table 9. Evaluation of Partial Through-Wall Circumferential Flaw in SS Weld Overlay	30
Table 10. Limit Load Results at SS Weld Overlay	34
Table 11. Applied Membrane Stress Check at SS Weld Overlay	34

LIST OF FIGURES

Figure 1. Weld Overlay Configuration7

Figure 2. Internal Full Circumferential Part Through-Wall Flaw 10

Figure 3. Finite Element Model Section with Stress Pathlines Superposed..... 15

1.0 Purpose

Due to the susceptibility of Alloy 600 and its associated weldments Alloy 82/182 to primary water stress corrosion cracking (PWSCC), Dominion plans to install full structural weld overlays at the safety and relief nozzles of the pressurizer at North Anna Units 1 and 2 (NA-1&2). A repair procedure has been developed where the dissimilar metal (DM) Alloy 82/182 weld and stainless steel (SS) safe end and weld, and a portion of both the nozzle and attached pipe are overlaid with PWSCC resistant Alloy 52M material, as shown in Figure 1. This repair design is more fully described by the overlay design drawings (References 1, 2) and the technical requirements document (Reference 3). It is postulated that a 360° circumferential flaw would propagate by PWSCC through the thickness of the Alloy 82/182 weld to the interface with the Alloy 52M overlay material. Qualification of the welding process (Reference 4) has demonstrated as-deposited weld metal chemistry sufficient to prevent PWSCC growth into the applied weld overlay and as such, no dilution layer is considered in this analysis. Although PWSCC would not continue to occur in the Alloy 52M overlay, it is further conservatively postulated that a small fatigue initiated flaw forms in the Alloy 52M overlay and combines with the PWSCC crack in the Alloy 82/182 weld to form a large partial through-wall full circumferential flaw that would propagate into the Alloy 52M overlay by fatigue crack growth under cyclic loading conditions.

A fracture mechanics analysis is performed to evaluate this worst case flaw in the repair configuration. This evaluation will consider sustained and normal/upset condition transient stresses (Reference 5) with the associated number of transient cycles to predict the final flaw size at the end of license extension at NA-1&2, which equates to a 33 year service life. This evaluation will demonstrate that the postulated circumferential flaw meets the ASME Code Section XI, Appendix C acceptance criteria (References 6, 16). An additional check will be made on the applied membrane stresses in the remaining ligament under normal operating conditions to make sure that they do not exceed the material yield strength. This analysis is performed for both the Alloy 82/182 weld as well as the stainless steel weld joining the safe end to the piping.




Figure 1. Weld Overlay Configuration

2.0 Analytical Methodology

This analysis postulates a 360° circumferential flaw, which propagates by fatigue crack growth into the weld overlay, governed by a crack growth rate and stress intensity factor solution as detailed in Section 4.0. Applied stresses include both transient and sustained normal operating loads. The crack is grown on a yearly basis for 33 years.

As part of the overall effort in designing the weld overlay, a sizing calculation was prepared that determined the minimum thickness required to prevent net section collapse of the overlaid pipe (Reference 7). The sizing calculation design basis is a full circumferential through-wall flaw in the Alloy 82/182 butt weld or the stainless steel weld. The calculated minimum thickness does not take into account fatigue crack growth in the Alloy 52M weld overlay. This fracture mechanics calculation establishes the additional overlay thickness beyond the sizing calculation minimum requirement including the effect of a large initial flaw size and fatigue crack growth beyond this point while ensuring that the failure criteria detailed below are satisfied.

For highly ductile materials such as Alloy 52M, the acceptance criterion on flaw size is a 75% through-wall limit on depth (References 6, 16):

$$\frac{a}{t} \leq 0.75$$

Another acceptance criterion for ductile materials is demonstration of sufficient limit load margin. A limit load check is performed to ensure that net section collapse does not occur following crack growth as required by ASME B&PV Code, Section XI, Appendix C (References 6, 16).

Additionally, applied membrane stresses in the remaining ligament will be compared to the yield strength to ensure that failure will not occur due to axial pressure and piping loads under normal operating conditions.

Details of the methodology presented here are provided in Section 4.0 of this document.

3.0 Key Assumptions

There are no major assumptions for this calculation. Minor assumptions are noted where applicable.

The following engineering judgments are used in this analysis:

1. The fatigue crack growth rate for Alloy 600 material in a PWR environment (References 8, 9) modified by a multiplier of 2 based on Reference 10, can be used for Alloy 52M weld material in this analysis. Further discussion of this crack growth rate can be found in Section 4.4.
2. The stress analysis (Reference 5) used nozzle geometric configuration data (References 12, 13) available at the time. Although updated configuration data is now available, a sensitivity analysis has demonstrated that the original geometry produces conservative results. Additionally, the configuration data from References 12 and 13 results in a weld overlay design thickness greater than that which would be required for the latest geometric data. Thus, the original analysis and nozzle configurations are used in this evaluation. Furthermore, this evaluation uses the weld overlay sizing calculation (Reference 7) revision that was based on the geometric configuration (References 12, 13) used in the stress analysis (Reference 5).

4.0 Calculations

4.1 Postulated Flaw Shape

A full circumferential partial through-wall internal flaw in a cylinder as shown in Figure 2 is postulated to exist at the time the overlay is applied. The flaw growth analysis contained within addresses the growth of the postulated flaw into the overlay material by cyclic loading.




Figure 2. Internal Full Circumferential Part Through-Wall Flaw

An axial flaw is considered to be bounded by the full circumferential partial through-wall internal flaw as shown in Figure 2 for several reasons. These include:

- Net section collapse of the axial flaw is not possible as the critical flaw size is very large.
- The axial flaw postulated is of 2:1 aspect ratio (length to depth) which generally results in a reduced stress intensity factor compared to a 360° circumferential flaw.
- The maximum length of an axial flaw is constrained by PWSCC resistant materials (the low alloy steel nozzle and stainless steel safe end).
- No external loads such as deadweight, thermal expansion or (tensile) shrinkage stresses are present in the hoop direction. Pressure stresses are accounted for in the transient stress results.
- Hoop residual stresses are less significant than axial residual stresses for crack growth.

4.2 Geometry

Basic dimensions at the safe end to nozzle DM weld are

Outside diameter prior to overlay, [] in. (References 12, 13)
 Inside diameter, [] in. (References 12, 13)

Basic dimensions at the safe end to piping SS weld are

Outside diameter prior to overlay, [] in. (References 12, 13)
 Inside diameter, [] in. (References 12, 13)

4.3 Mechanical Properties

The yield strength for the Alloy 52M overlay material is tabulated below.

Table 1. Mechanical Properties of Alloy 52M

Condition	Temperature (°F)	Yield Strength, σ_y (ksi)
		ASME Code (Reference 14)
Room Temperature	70	35.0
Normal Operating	[]	[]

The Design Stress Intensity (S_m) of the weld overlay material is 23.3 ksi at temperatures ranging from 100°F to 800°F.

4.4 Fatigue Crack Growth

Flaw growth due to cyclic loading is calculated using the fatigue crack growth model in the NRC flaw evaluation guidelines for Alloy 600 in a PWR environment (References 8, 9) which is based on work that was presented in NUREG/CR-6721 (Reference 10). Reference 10 shows that Alloy 52M materials do not exhibit the enhanced corrosion fatigue crack growth behavior of Alloy 82/182 materials in simulated 320°C PWR water. Instead, Alloy 52M behaves quite similarly to Alloy 600 in PWR water. However, to be conservative, a multiplier of 2 is applied to the Alloy 600 crack growth rate. Crack growth analysis is then conducted on a cycle-by-cycle basis or to end of life.

$$\frac{da}{dN} = 2 * CS_R S_{ENV} (\Delta K)^n \tag{1}$$

where ΔK is the stress intensity factor range in terms of MPa√m and da/dN is the crack growth rate in terms of m/cycle

$$C = 4.835 \times 10^{-14} + 1.622 \times 10^{-16} T - 1.490 \times 10^{-18} T^2 + 4.355 \times 10^{-21} T^3 \tag{2}$$

$$S_R = [1 - 0.82R]^{-2.2}$$

$$S_{ENV} = 1 + A [CS_R \Delta K^n]^{m-1} T_R^{1-m}$$

$$A = 4.4 \times 10^{-7}$$

$$m = 0.33$$

$$n = 4.1$$

$$T = \text{degrees C}$$

$$R = K_{min} / K_{max}$$

$$T_R = \text{rise time, set at 30 sec.}$$

4.5 Stress Intensity Factor Solution

The stress intensity factor used for an internal full circumferential partial through-wall flaw in a cylinder is the Buchalet and Bamford solution (Reference 15). This solution is based on an inside radius to thickness ratio of 10, which is conservative for the present configuration.

The stress intensity factor is:

$$K_I = \sqrt{\pi a} \left[A_0 F_1 + \frac{2a}{\pi} A_1 F_2 + \frac{a^2}{2} A_2 F_3 + \frac{4a^3}{3\pi} A_3 F_4 \right], \quad (3)$$

A_0 , A_1 , A_2 and A_3 are coefficients of the third order polynomial stress distribution describing the axial stress ($S(x)$) variation through the cylinder wall given below:

$$S(x) = A_0 + A_1 x + A_2 x^2 + A_3 x^3 \quad (4)$$

where x is the distance measured from the inner surface of the cylinder wall.

F_1 , F_2 , F_3 and F_4 are geometry dependent magnification factors given by:

$$\begin{aligned} F_1 &= 1.1259 + 0.2344(a/t) + 2.2018(a/t)^2 - 0.2083(a/t)^3 \\ F_2 &= 1.0732 + 0.2677(a/t) + 0.6661(a/t)^2 + 0.6354(a/t)^3 \\ F_3 &= 1.0528 + 0.1065(a/t) + 0.4429(a/t)^2 + 0.6042(a/t)^3 \\ F_4 &= 1.0387 - 0.0939(a/t) + 0.6018(a/t)^2 + 0.3750(a/t)^3 \end{aligned}$$

4.6 Applied Stresses

There are three categories of stress that need to be considered in this evaluation. Through-wall applied stresses in the axial direction are quantified. These stresses include:

- Transient through-wall stresses due to fluctuations in pressure and temperature
- Sustained stresses due to dead weight, piping thermal expansion, and axial shrinkage
- Welding residual stresses

The steady state stresses (i.e. sustained and residual) were combined with the stresses at each transient time point to develop the extreme (high and low) stress states for each transient. The combined through-wall stresses are fit to the third order polynomial described in the previous section.

4.6.1 Transient Stresses

The cyclic operating stresses that are needed to calculate fatigue crack growth were obtained from a linear-elastic three-dimensional finite element analysis (Reference 5). These fatigue stresses were developed for each of ten transients at a number of time points to capture the maximum and minimum stresses due to fluctuations in pressure and temperature. Per the technical requirements document (Reference 3), the number of RCS design transients established for the initial 40 year life is applicable to the 60 year licensed life of the plant (40 year design life plus 20 year life extension). Using the design transient cycle counts results in a conservative number of remaining plant cycles relative to the actual cycles of each transient that

the plant has experienced during the period of operation up to the installation of the weld overlays.

Cyclic operating stresses were generated in Reference 5 for the ten transients listed below. The transient descriptions and cycle counts are given in Reference 5.

<u>No.</u>	<u>Transient</u>	<u>Cycles over 60 years</u>
1	()
2		
3		
4		
5		
6		
7		
8		
9		
10		

The above transients are grouped into six sets, as listed below. The bounding stresses from each set will be used to conservatively bound each group of cyclic loadings. An additional transient event due to seismic (OBE) loads is also included as a seventh transient. The high stress condition is taken to be the stresses due to each of these events applied at the steady state condition, such that the stresses are cycling between the maximum stresses and steady state are additional transients.

<u>Group</u>	<u>Transient</u>	<u>Cycles over 60 years</u>
1	()
2		
3		
4		
5		
6		
7		

4.6.2 Sustained Stresses

The loads applied at the safe end (References 7, 17) are given below:

Table 2. Sustained Loads at the Safe End

Load Case	Forces (lbf)			Moments (in-lbf)			
	Axial	F _y	F _z	Torsion	M _y	M _z	SRSS
DW	()
TH							
Total							

Note: The axial forces are aligned with the nozzle center line.

The loads applied at the safe end can be transferred to the nozzle by the moment arm of [] (Reference 7) and the results are listed in Table 3.

Table 3. Sustained Loads at the Nozzle

Load Case	Forces (lbf)			Moments (in-lbf)			
	Axial	F _y	F _z	Torsion	M _y	M _z	SRSS
DW							
TH							
Total							

Note: The axial forces are aligned with the nozzle end center line.

4.6.3 Residual Stress in Welds

The residual stress profile through the thickness of the DM and SS welds and overlay is obtained from an analysis performed for the NA-1&2 safety and relief nozzles (Reference 11). The two nozzle designs differ in the piping downstream of the stainless steel weld, where for the safety piping, a 45° elbow comes off the weld, whereas the relief nozzle safe end is attached to a reducer. This design difference does not influence the residual stresses in both the Alloy 82/182 dissimilar metal weld and associated overlay at this location. Possible differences in residual stresses would be seen at the stainless steel weld. Additionally, for the safety nozzle, the elbow results in a larger deposit of overlay on the intrados side of the nozzle than on the extrados side. From a crack growth and weld overlay residual stress standpoint, this results in the extrados side being more conservative because the postulated circumferential crack depth is relatively larger at this location, and also because the relatively thinner overlay will induce less compressive stresses at the inside surface of the extrados stainless steel weld. Two dimensional residual stress analyses were performed for the relief nozzle and the extrados side of the safety nozzle. The results of these analyses show that the differences in residual stresses in both analyses are insignificant. The results from the relief nozzle analysis are used in this crack growth evaluation. Stresses were obtained over multiple paths through the thickness of the DM and SS welds and overlay. The paths over which these stresses are obtained are shown in Figure 3, and axial residual stresses are obtained over these paths. These stresses are combined with the transient stress results to obtain the combined stresses over the pathline. From this process, it was determined that the stresses at Path 3 were controlling for the DM weld. These results are used to perform the fatigue crack growth calculation.



Figure 3. Finite Element Model Section with Stress Pathlines Superposed

4.7 Flaw Growth Analysis

Flaw growth is calculated in one-year increments for each of the transient groups. The actual flaw growth analysis is presented in Table 6 for the DM weld and in Table 9 for the SS weld. For each table, the applied cycles are distributed uniformly over the service life by linking the incremental crack growth for each transient.

4.8 Limit Load Check

At the end of the flaw growth analysis, a limit load check is performed to ensure that net section collapse will not occur.

Per the ASME B&PV Code, Section XI, Appendix C (References 6, 16), only primary stresses (P_m and P_b) are considered. The primary stresses considered in this application result from internal pressure, dead weight and seismic loads (OBE or DBE). C-3320 of the same reference also specifies two sets of loading cases with different safety factors (SF) to be used: Normal/Upset (N/U) operating conditions ($SF = 2.77$), and Emergency/Faulted (E/F) conditions ($SF = 1.39$). The limiting load combinations for the N/U conditions are: internal pressure + DW + OBE + Open Valve. The limiting load combinations for the E/F conditions are: internal pressure + DW + DBE + Open Valve. Table 4 lists the maximum loads at the safe end (Reference 7). The loads applied at the safe end can be transferred to the nozzle by the moment arm of [] (Reference 7) and the results are listed in Table 5.

Table 4. Loading Conditions for Limit Load Check at Safe End

Load Case	Forces (lbf) ⁽¹⁾			Moments (in-lbf)			SRSS
	Axial	F _y	F _z	Torsion	M _y	M _z	
Internal Pressure ⁽²⁾							
DW							
OBE + Open Valve (±)							
DBE + Open Valve (±)							
Total for N/U							
Total for E/F							

Note: (1) The axial forces are aligned with the nozzle center line
(2) Based on 2500 psia – conservative for all transients

Table 5. Loading Conditions for Limit Load Check at Nozzle

Load Case	Forces (lbf) ⁽¹⁾			Moments (in-lbf)			SRSS
	Axial	F _y	F _z	Torsion	M _y	M _z	
Internal Pressure ⁽²⁾							
DW							
OBE + Open Valve (±)							
DBE + Open Valve (±)							
Total for N/U							
Total for E/F							

Note: (1) The axial forces are aligned with the nozzle center line
(2) Based on 2500 psia – conservative for all transients

For a circumferentially cracked pipe, the relation between the applied loads and the crack depth at incipient plastic collapse per References 6 and 16 is given by

$$P'_b = \frac{6S_m}{\pi} \left(2 - \frac{a}{t} \right) \sin \beta \tag{7}$$

where t is the pipe thickness, β is the angle that defines the location of neutral axis (see Figure C-3320-1 of Appendix C, (References 6, 16) for details), and a is the crack depth. The assumed circumferential through-wall crack penetrates the compressive bending region such that $(\theta + \beta) > \pi$, where θ is the half crack angle. Therefore the angle β per References 6 and 16 is given by

$$\beta = \frac{\pi}{2 - \frac{a}{t}} \left(1 - \frac{a}{t} - \frac{P_m}{3S_m} \right) \tag{8}$$

where P_m is the piping membrane stress in the axial direction in the uncracked section of the pipe. Per Reference 3 for a weld overlay using Alloy 52M, filler material shall be deposited using the ambient temperature temper bead machine GTAW process. The failure bending stress P'_b is therefore given by

$$P'_b = SF(P_m + P_b) - P_m \quad (9)$$

with $SF = 2.77$ for Normal/Upset conditions and $SF = 1.39$ for Emergency/Faulted conditions. P_b is the piping bending stress in the intact section of the pipe. If the bending stress calculated using eqn. (7) exceeds that using eqn. (9) at the final crack depth, the component meets limit load requirements.

Results of the limit load check are shown in Table 7 and Table 10.

4.9 Applied Membrane Stress Check

This calculation verifies that the applied axial loads carried by the remaining ligament do not exceed yield stress at the final flaw size. Results are shown in Table 8 and Table 11.

5.0 Results and Conclusion

5.1 DM Weld Overlay

The stress intensity factors at the crack tip in the DM weld at the Alloy 52M weld overlay interface are calculated for each transient. Crack growth into the overlay is shown in Table 6 on the next page.

Table 6. Evaluation of Partial Through-Wall Circumferential Flaw in DM Weld Overlay

A large, empty rounded rectangular frame that serves as a placeholder for the content of Table 6. The frame is defined by a solid black line and has rounded corners at the top and bottom. It occupies most of the page area below the caption.

Table 6. Evaluation of Partial Through-Wall Circumferential Flaw in DM Weld Overlay (cont'd)

A large, empty rounded rectangular frame that serves as a placeholder for a table. The frame is defined by a thin black line and has rounded corners. It occupies most of the page area below the caption.

Table 6. Evaluation of Partial Through-Wall Circumferential Flaw in DM Weld Overlay (cont'd)



Table 6. Evaluation of Partial Through-Wall Circumferential Flaw in DM Weld Overlay (cont'd)



Table 6. Evaluation of Partial Through-Wall Circumferential Flaw in DM Weld Overlay (cont'd)

A large, empty rounded rectangular frame that occupies most of the page below the caption. It is defined by a thin black line and has rounded corners at the top and bottom. The interior of the frame is completely blank, suggesting that the table content was not rendered or is otherwise missing.

Table 6. Evaluation of Partial Through-Wall Circumferential Flaw in DM Weld Overlay (cont'd)

A large, empty rounded rectangular frame with a thin black border, occupying most of the page below the caption. It appears to be a placeholder for a table or diagram.

Table 6. Evaluation of Partial Through-Wall Circumferential Flaw in DM Weld Overlay (cont'd)




Table 6. Evaluation of Partial Through-Wall Circumferential Flaw in DM Weld Overlay (cont'd)

A large, empty rounded rectangular frame that occupies most of the page below the caption. It is defined by a thin black line and has rounded corners at the top and bottom. The interior of the frame is completely blank, suggesting that the table content was not rendered or is otherwise missing.

Table 6. Evaluation of Partial Through-Wall Circumferential Flaw in DM Weld Overlay (cont'd)




Flaw Sizes

Initial flaw size,	$a_i = 1.1500$ in.
Final flaw size after 33 years,	$a_f = 1.1506$ in.
Flaw growth,	$\Delta a = 0.0006$ in.
Final crack depth to thickness ratio,	$a/t = 0.7457$


Results of Limit Load Check

Table 7. Limit Load Results at DM Weld Overlay

Parameters	Description	N/U	E/F	
d_o , inch	WOL outside diameter			
d_i , inch	Inside diameter			
a_f , inch	Final crack depth			
F , lbf	Axial force			
M , in-lbf	SRSS moment			
t_{wol} , inch	Weld overlay thickness			
t , inch	Overall thickness including weld overlay			
A , inch ²	Sectional area			
Z , inch ³	Section modulus			
P_m , psi	Membrane stress			
P_b , psi	Bending stress			
SF	Safety factor, Reference 4		2.77	1.39
P'_b , psi	Fallure bending stress by eqn. (7)			
P'_b , psi	Fallure bending stress by eqn. (9)			
a/t	Final crack depth to thickness ratio	0.7457	0.7457	

Results of Applied Membrane Stress Check

Table 8. Applied Membrane Stress Check at DM Weld Overlay

Parameters	Description	Value
d_o , inch	WOL outside diameter	
t_{rem} , inch	Remaining ligament thickness	
F , lbf	Axial force (DW + TH + Shrink + Press)	
A_{rem} , inch ²	Sectional area of ligament	
P_{ml} , psi	Membrane stress in ligament	
σ_y , psi	650°F yield stress in ligament	
	Margin	2.02

5.2 SS Weld Overlay

The stress intensity factors at the crack tip in the stainless steel weld to Alloy 52M weld overlay interface were calculated for each transient. For all transients, other than the [] transients, the highest and lowest stress intensity factors were negative, which indicates that no fatigue crack growth is possible. For the remaining transients [], crack growth into the overlay is shown in Table 9 on the next page.

Table 9. Evaluation of Partial Through-Wall Circumferential Flaw in SS Weld Overlay




Table 9. Evaluation of Partial Through-Wall Circumferential Flaw in SS Weld Overlay (cont'd)


A large, empty rounded rectangular frame that serves as a placeholder for a table. The frame is defined by a thin black line and has rounded corners at the top and bottom. It occupies most of the page area below the caption.

Table 9. Evaluation of Partial Through-Wall Circumferential Flaw in SS Weld Overlay (cont'd)





Table 9. Evaluation of Partial Through-Wall Circumferential Flaw in SS Weld Overlay (cont'd)

A large, empty rounded rectangular frame that occupies most of the page. It is defined by a single black line forming a vertical rectangle with rounded top and bottom corners. The interior of the frame is completely blank, suggesting that the table content has been redacted or is otherwise missing from this page.

Flaw Sizes

Initial flaw size,	$a_i = 0.6500$ in.
Final flaw size after 33 years,	$a_f = 0.6502$ in.
Flaw growth,	$\Delta a = 0.0002$ in.
Final crack depth to thickness ratio,	$a/t = 0.4648$

Results of Limit Load Check

Table 10. Limit Load Results at SS Weld Overlay

Parameters	Description	N/U	E/F		
d_o , inch	WOL outside diameter	()	()		
d_i , inch	Inside diameter				
a_f , inch	Final crack depth				
F , lbf	Axial force				
M , in-lbf	SRSS moment				
t_{wol} , inch	Weld overlay thickness				
t , inch	Overall thickness including weld overlay				
A , inch ²	Sectional area				
Z , inch ³	Section modulus				
P_m , psi	Membrane stress				
P_b , psi	Bending stress				
SF	Safety factor, Reference 4			2.77	1.39
P'_b , psi	Fallure bending stress by eqn. (7)			()	()
P'_b , psi	Fallure bending stress by eqn. (9)				
a/t	Final crack depth to thickness ratio	0.4648	0.4648		

Results of Applied Membrane Stress Check

Table 11. Applied Membrane Stress Check at SS Weld Overlay

Parameters	Description	Value
d_o , inch	WOL outside diameter	()
t_{rem} , inch	Remaining ligament thickness	
F , lbf	Axial force (DW + TH + Shrink + Press)	
A_{rem} , inch ²	Sectional area of ligament	
P_{mi} , psi	Membrane stress in ligament	
σ_y , psi	650°F yield stress in ligament	
	Margin	4.71

5.3 Conclusion

After 33 years of operation, fatigue crack growth into the overlay material at both locations is minimal and is summarized in the table below:

		DM WELD OVERLAY	SS WELD OVERLAY
Min WOL thickness,	$t_{wol} =$	[
Additional WOL thickness required,	$\Delta t_{wol} =$		
Initial flaw size,	$a_i =$	1.1500 in.	0.6500 in.
Final flaw size after 33 years,	$a_f =$	1.1506 in.	0.6502 in.
Flaw growth,	$\Delta a =$	0.0006 in.	0.0002 in.
Allowable crack depth to thickness ratio,	$(a/t)_{all} =$	0.7500	0.7500
Final crack depth to thickness ratio,	$(a/t)_{final} =$	0.7457	0.4648

The final configuration at the overlaid locations meets the Section XI, Appendix C acceptance criteria and the remaining ligament also satisfies basic applied membrane stress considerations.

6.0 References

1. AREVA Drawing 02-8017177D-001, "North Anna Pressurizer Safety Nozzle Overlay Design."
2. AREVA Drawing 02-8017182D-001, "North Anna Pressurizer Relief Nozzle Overlay Design."
3. AREVA Document 51-9031151-002, "North Anna Units 1 and 2 Pressurizer Nozzle Weld Overlays – Technical Requirements."
4. AREVA Document 51-9009149-004, "Alloy 52 Overlay Chemistry Results."
5. AREVA Document 32-9038441-001, "North Anna Units 1 & 2 Pressurizer Safety/Relief Nozzle Weld Overlay Analysis."
6. ASME Boiler and Pressure Vessel Code, 1989 Edition, Section XI, Division 1.
7. AREVA Document 32-9034340-001, "North Anna Units 1 and 2 Pressurizer Weld Overlay Sizing Calculation - Safety/Relief Nozzles."
8. NRC Letter from Richard Barrett, Director Division of Engineering, Office of NRR to Alex Marion of Nuclear Energy Institute, "Flaw Evaluation Guidelines," April 11, 2003, Accession Number ML030980322.
9. Enclosure 2 to Reference 8, "Appendix A: Evaluation of Flaws in PWR Reactor Vessel Upper Head Penetration Nozzles," Accession Number ML030980333.
10. NUREG/CR-6721, "Effects of Alloy Chemistry, Cold Work, and Water Chemistry on Corrosion Fatigue and Stress Corrosion Cracking of Nickel Alloys and Welds," U.S. Nuclear Regulatory Commission (Argonne National Laboratory), April 2001.
11. AREVA Document 32-9043050-000, "North Anna Units 1 and 2, Pressurizer Safety Relief Nozzle Weld Residual Stress Analysis."
12. AREVA Drawing 02-8016863C-002, "North Anna Pressurizer Safety Nozzle Design."
13. AREVA Drawing 02-8016749C-002, "North Anna Pressurizer Relief Nozzle Design."
14. ASME Boiler and Pressure Vessel Code, 2001 Edition including Addenda through 2003, Section II, Part D.
15. C.B. Buchalet and W.H. Bamford, "Stress Intensity Factor Solutions for Continuous Surface Flaws in Reactor Pressure Vessels," Mechanics of Crack Growth, ASTM STP 590, American Society for Testing and Materials, 1976, pp. 385-402.
16. ASME Boiler and Pressure Vessel Code, 1995 Edition including Addenda through 1996, Section XI, Division 1.
17. AREVA Document 51-9036969-004, "Pressurizer Bounding Transients for North Anna Units 1 & 2."

7.0 Computer Output

Not Applicable.