

TABLE 3.3-10

ACCIDENT MONITORING INSTRUMENTATION

<u>INSTRUMENT</u>	<u>TOTAL NO. OF CHANNELS</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>ACTION</u>
1. Containment Pressure	4	1	43
2. Reactor Coolant Outlet Temperature- T _{HOT} (Wide Range)	4 (1/loop)	4	35
3. Reactor Coolant Inlet Temperature- T _{COLD} (Wide Range)	4 (1/loop)	4	35
4. Reactor Coolant Pressure - Wide Range and Extended Range	3	1	37
5. Pressurizer Water Level	4	1	43
6. Steam Line Pressure	4/steam generator	1/steam generator	43
7. Steam Generator Water Level - Narrow Range	4/steam generator	1/steam generator	43
8. Steam Generator Water Level - Wide Range	4 (1/steam generator)	4	35
9. Refueling Water Storage Tank Water Level	3	1	37
10. Auxiliary Feedwater Storage Tank Water Level	3	1	37
11. Auxiliary Feedwater Flow	4 (1/steam generator)	4	35
12. Reactor Coolant System Subcooling Margin Monitoring	2	1	36

SOUTH TEXAS - UNITS 1 & 2

3/4 3-68

Unit 1 - Amendment No. 177
Unit 2 - Amendment No. 164

TABLE 3.3-10 (Continued)

ACTION STATEMENTS

- ACTION 35 - a. With the number of OPERABLE channels one less than the Minimum Channels Operable requirement, restore the inoperable channel to OPERABLE status within 30 days or submit a Special Report within the next 14 days describing the preplanned alternate method of monitoring, the cause of the inoperability, and the plans and schedule for restoring the instrumentation channels of the Function to OPERABLE status.
- b. With the number of OPERABLE channels two or more less than the Minimum Channels Operable requirement, restore one or more of the inoperable channels such that at least three channels are in OPERABLE status within 7 days, or be in at least HOT SHUTDOWN within the next 12 hours.
- ACTION 36 - a. With the number of OPERABLE channels one less than the Total Number of Channels requirements, restore one inoperable channel to OPERABLE status within 7 days, or be in at least HOT SHUTDOWN within the next 12 hours.
- b. With the number of OPERABLE channels less than the Minimum Channels Operable requirements, restore at least one inoperable channel to OPERABLE status within 48 hours, or be in at least HOT SHUTDOWN within the next 12 hours.
- ACTION 37 - a. With the number of OPERABLE channels one less than the Total Number of Channels requirements, restore the inoperable channel to OPERABLE status within 31 days, or be in at least HOT SHUTDOWN within the next 12 hours.
- b. With the number of OPERABLE channels two less than the Total Number of Channels requirement, restore at least one inoperable channel to OPERABLE status within 7 days, or be in at least HOT SHUTDOWN within the next 12 hours.
- c. With the number of OPERABLE channels less than the Minimum Channels Operable requirement, restore at least one inoperable channel to OPERABLE status within 48 hours or be in at least HOT SHUTDOWN within the next 12 hours.