

REQUESTS FOR ADDITIONAL INFORMATION (RAIs)
ESBWR DESIGN CONTROL DOCUMENT (DCD) TIER 2, Revision 3, Chapter 6

RAI Number	Reviewer	Question Summary	Full Text
6.2-52 Suppl. 1	Wagage H	Update response as a result of modeling changes	<p>In response to RAI 6.2-52, MFN 06-348, GE provided changes made to the NRC approved TRACG code. This response included a justification for the changes and the results of tie-back calculations. Regarding GE response to parts B and C of the request, GE stated that “[t]hese discussions will be included in the Supplement in DCD Section 6.2.” Staff believes that the information quoted was incorporated into the DCD, Tier 2, Revision 3, Chapter 6, Appendix 6A, Table 6A-1, “Evaluation of TRACG Application Procedure.” However, GE did not include a discussion of the justification including the results of the tie-back calculation for the changes to the approved TRACG code in the DCD. The justification for a change to the previously approved TRACG code is necessary to be incorporated into a licensing document either the DCD or as a supplement to the Topical Report.</p> <p>Please provide the justification including the results of the tie-back calculations in the DCD or in a supplement to NEDC-33083P-A, "TRACG Application for ESBWR." If NEDC-33083P-A is supplemented, ensure that the supplement is referenced in the DCD.</p>