

Westinghouse Electric Company Nuclear Power Plants P.O. Box 355 Pittsburgh, Pennsylvania 15230-0355 USA

U.S. Nuclear Regulatory Commission ATTENTION: Document Control Desk Washington, D.C. 20555 Direct tel: 412-374-6306 Direct fax: 412-374-5005 e-mail: sterdia@westinghouse.com

Your ref: Project Number 740 Our ref: DCP/NRC1900

May 24, 2007

Subject: AP1000 COL Standard Technical Report Submittal of APP-GW-GLR-119, Revision 0

In support of Combined License application pre-application activities, Westinghouse is submitting Revision 0 of AP1000 Standard Combined License Technical Report Number 119. The purpose of Technical Report 119 is to provide a justification for the removal of Tier 2* information from Chapter 4 of the Design Control Document in Revision 16 for the initial core for the AP1000 Combined License. Changes to the Design Control Document identified in Technical Report Number 119 are intended to be incorporated into FSARs referencing the AP1000 design certification or incorporated into an amended design certification. This report is submitted as part of the NuStart Bellefonte COL Project (NRC Project Number 740). The information included in this report is generic and is expected to apply to all COL applications referencing the AP1000 Design Certification.

The purpose for submittal of this report was explained in a March 8, 2006 letter from NuStart to the U.S. Nuclear Regulatory Commission. This revision includes markups to DCD Appendix 3C.

Pursuant to 10 CFR 50.30(b), APP-GW-GLR-119, Revision 0, "AP1000 Design Control Document Chapter 4 Tier 2* Information," Technical Report Number 119, is submitted as Enclosure 1 under the attached Oath of Affirmation.

It is expected that when the NRC review of Technical Report Number 119 is complete, Tier 2* information will be removed from Chapter 4 of the DCD in Revision 16.

Questions or requests for additional information related to the content and preparation of this report should be directed to Westinghouse. Please send copies of such questions or requests to the prospective applicants for combined licenses referencing the AP1000 Design Certification. A representative for each applicant is included on the cc: list of this letter.

Westinghouse requests the NRC to provide a schedule for review of this Technical Report within two weeks of its submittal.



00143psa.doc

DCP/NRC1900 May 24, 2007 Page 2 of 2

Very truly yours,

_Ste

A. Sterdis, Manager Licensing and Customer Interface Regulatory Affairs and Standardization

/Attachment

1. "Oath of Affirmation," dated May 24, 2007

/Enclosure

1. APP-GW-GLR-0119, Revision 0, "AP1000 Design Control Document Chapter 4 Tier 2* Information," Technical Report Number 119, dated May 2007.

cc:	D. Jaffe	-	U.S. NRC	1E	1A
	E. McKenna	-	U.S. NRC	1E	1A
	G. Curtis	-	TVA	1E	1A
	P. Grendys	-	Westinghouse	1E	1A
	P. Hastings	-	Duke Power	1E	1A
	C. Ionescu	-	Progress Energy	1E	1A
	D. Lindgren	-	Westinghouse	1 E	1 A
	A. Monroe	-	SCANA	1E	1A
	M. Moran	-	Florida Power & Light	1E	1A
	C. Pierce	-	Southern Company	1E	1A
	E. Schmiech	-	Westinghouse	1E	1A
	G. Zinke	-	NuStart/Entergy	1E	1A
	M. Asztalos		Westinghouse	1 E	1 A

ATTACHMENT 1

"Oath of Affirmation"

•

ATTACHMENT 1

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

In the Matter of:)
NuStart Bellefonte COL Project)
NRC Project Number 740)

APPLICATION FOR REVIEW OF "AP1000 GENERAL COMBINED LICENSE INFORMATION" FOR COL APPLICATION PRE-APPLICATION REVIEW

W. E. Cummins, being duly sworn, states that he is Vice President, Regulatory Affairs & Standardization, for Westinghouse Electric Company; that he is authorized on the part of said company to sign and file with the Nuclear Regulatory Commission this document; that all statements made and matters set forth therein are true and correct to the best of his knowledge, information and belief.

W. E. Cummins Vice President Regulatory Affairs & Standardization

Subscribed and sworn to before me this dy day of May 2007.

COMMONWEALTH OF PENNSYLVANIA
Notarial Seal Debra McCarthy, Notary Public
My Commission Expires Aug. 31, 2009
Member, Pennsylvania Association of Notaries
Debra m Carthy
Notary Public

ENCLOSURE 1

APP-GW-GLR-119, Revision 0

AP1000 Design Control Document Chapter 4 Tier 2* Information

Technical Report Number 119

AP1000 DOCUMENT COVER SHEET

		TDC:		Permanent F	ile:	APY:
			RFS	S#:	RFS ITEM #	t:
AP1000 DOCUMENT NO.	REVISION NO.	29	AS	SIGNED TO		
APP-GW-GLR-119	0	Page 1 of 30	r w	-McGinnis		
ALTERNATE DOCUMENT N	IUMBER: TR-119	PA	W JolWC	RK BREAKDOW	'N #:	
ORIGINATING ORGANIZAT	ION: NPP	5	,70			
TITLE: AP1000 Design Cor	ntrol Document Chap	ter 4 Tier 2* Inf	formation	1		
ATTACHMENTS:		,		DCP #/REV. INC	ORPORATED) IN THIS
None				DOCUMENT RE N/A	VISION:	
CALCULATION/ANALYSIS F N/A	REFERENCE:					
ELECTRONIC FILENAME APP-GW-GLR-119-RA	ELECTRONIC FILE I	FORMAT E	ELECTRO	NIC FILE DESCI	RIPTION	
LEGAL REVIEW	ери С. Ярадасы	ME SIG	GNATURE	/DATE	h Son 1	Acu 5/23/
PATENT REVIEW M. M. Corletti		SIC	GNATURE		Indat	\$ 5/27/07
WESTINGHOUSE F This document is the prop subcontractors and suppl accordance with the term	PROPRIETARY CLA perty of and contains Prop iers. It is transmitted to y s and conditions of the ag	SS 2 prietary Informatio rou in confidence a greement under w	on owned b and trust, a hich it was	y Westinghouse El and you agree to tre provided to you.	ectric Company eat this docume	LLC and/or its nt in strict
	SIGNATUR	E/DATE	4-1	(- 2)-67		
REVIEWERS	SIGNATUR	E/DATE	<u>~</u>			
D.F. Hutchings	D.7	. Hutch	: P	3-23-0	7	
ERIFIER D.A. LINDBREN	SIGNATUR	EDACE	5/24	VERIFICATION	N METHOD	NE REVIEW
P1000 RESPONSIBLE MANAG	ER SIGNATURI	Et A	T I.	APPROVAL I		
		mentio complete			VIY UI	file is other t

* Approval of the responsible manager signifies that document is complete, all required reviews are complete, electronic file is attached and document is released for use.

APP-GW-GLR-119 Revision 0 May 2007

AP1000 Standard Combined License Technical Report

AP1000 Design Control Document Chapter 4 Tier 2* Information

Westinghouse Electric Company LLC Nuclear Power Plants Post Office Box 355 Pittsburgh, PA 15230-0355

©2007 Westinghouse Electric Company LLC All Rights Reserved

TABLE OF CONTENTS

INTRODUCTION	.4
REFERENCES	4
APPENDIX 1	5

Ŀ

INTRODUCTION

The purpose of Technical Report 119 is to provide a justification for the removal of Tier 2* information from Chapter 4 of the Design Control Document in Revision 16 for the initial core for the AP1000 Combined License. This information was asterisked because changes to the Tier 2* information must be reviewed by the NRC for the first reactor core. In WCAP-16652-NP (Technical Report 18), Westinghouse committed to provide a generic Core Reference Report to address final core and fuel design changes prior to initial core load. The Core Reference Report will provide a standard reference to be used by COL license holders in the submittal of License Amendment Requests. The core reference report will contain the supplemental technical information required for closure of the Combined License Information Items contained in Chapter 4 of the AP1000 Design Control Document (DCD). Chapter 4, "Reactor," describes the mechanical components of the reactor and reactor core, including the fuel rods and fuel assemblies, the nuclear design, and the thermal-hydraulic design. Technical Report 119 requests permission to change DCD Chapter 4 Tier 2* information to Tier 2 based on the commitment to submit a generic Core Reference Report for the initial core.

Westinghouse proposes to change Chapter 4 Tier 2* information in Revision 16 of the DCD. The original Tier 2* information will be revised to normal text with no brackets, italics, or asterisks. Table 1 of Technical Report 119 commits that changes to the DCD Chapter 4 previous Tier 2* information in this table for the first core will be submitted as a part of a Core Reference Report to the NRC and submittal of a License Amendment Request (LAR) as described in 10 CFR 50.92 before initial startup. Changes to fuel and core parameters made in subsequent cycles will be made consistent with Westinghouse's NRC approved reload methodology.

The remaining portions of Technical Report 119 contain full subsections from Revision 15 of Chapter 4 of the AP1000 Design Control Document that contained the Tier 2* information and the proposed changes.

CONCLUSION

Tier 2* information in Revision 15 of the Design Control Document and in Technical Report 18 (WCAP-16652-NP) is marked up in Appendix 1 to reflect removal of italics and bracketed, asterisked, information based on a commitment to submit changes to previous Tier 2* information for the initial core in a Core Reference Report.

REFERENCES

- APP-GW-GLR-059, "AP1000 Core & Fuel Design Technical Report (18)" (WCAP-16652-NP, Revision 0)
- 2. APP-GW-GL-700, "AP1000 Design Control Document", Revision 15

APPENDIX 1

TABLE 1REQUESTED CHANGE SUMMARY

DCD (Rev. 15) Change Summary for Chapter 4 – Sections 4.1, 4.2, 4.3 and 4.4							
ID	Sec	Page	Update	Rationale for DCD Update			
4.1 [1]	4.1.1 4.1.3	4.1.4 - 4.1.6	Remove Tier 2* information (remove italics, brackets, and asterisk) from the specific principle design requirements in Section 4.1.1. Remove Tier 2* from Reference 9 in Section 4.1.1. The change for the average first cycle linear power from 5.71 to 5.718 was previously made in APP-GW-GLR-059.	Changes to the principle design requirements and for the applicability of Reference 9 for the first core will be submitted as a part of a Core Reference Report to the NRC and submittal of a License Amendment Request (LAR) as described in 10 CFR 50.92 before initial startup. Changes to the principle design requirements and for the applicability of Reference 9 made in subsequent cycles will be made consistent with Westinghouse's NRC approved reload methodology.			
4.2 [1]	4.2	4.2-2	Remove Tier 2* information for the use of WCAP-12488 as a basis for a set a fuel design criteria.	Changes to the applicability of WCAP- 12488 as a basis for a set a fuel design criteria for the first core will be submitted as a part of a Core Reference Report to the NRC and submittal of a License Amendment Request (LAR) as described in 10 CFR 50.92 before initial startup. Changes to the applicability of WCAP-12488 as a basis for a set a fuel design criteria made in subsequent cycles will be made consistent with Westinghouse's NRC approved reload methodology.			
4.2 [2]	4.2.1	4.2-2	Remove Tier 2* information for fuel design bases and acceptance limits	Changes to the fuel design bases and acceptance limits for the first core will be submitted as a part of a Core Reference Report to the NRC and submittal of a License Amendment Request (LAR) as described in 10 CFR 50.92 before initial startup. Changes to fuel design bases and acceptance limits made in subsequent cycles will be made consistent with Westinghouse's NRC approved reload methodology.			

DCD (Rev. 15) Change Summary for Chapter 4 – Sections 4.1, 4.2, 4.3 and 4.4					
ID	Sec	Page	Update	Rationale for DCD Update	
4.2 [3]	4.2.1.1.2	4.2-3	Remove Tier 2* information for clad stress and strain results	Changes to the clad stress and strain results for the first core will be submitted as a part of a Core Reference Report to the NRC and submittal of a License Amendment Request (LAR) as described in 10 CFR 50.92 before initial startup. Changes to the clad stress and strain results made in subsequent cycles will be made consistent with Westinghouse's NRC approved reload methodology.	
4.2 [4]	4.2.1.1.3	4.2-3	Remove Tier 2* information for the usage factor due to cyclic fatigue	Changes to the results of the determination of the usage factor due to cyclic fatigue for the first core will be submitted as a part of a Core Reference Report to the NRC and submittal of a License Amendment Request (LAR) as described in 10 CFR 50.92 before initial startup. Changes to the results of the determination of the usage factor due to cyclic fatigue made in subsequent cycles will be made consistent with Westinghouse's NRC approved reload methodology.	
4.2 [5]	4.2.1.5	4.2-5	Remove Tier 2* information for the use of WCAP-12488 methodology to evaluate fuel assembly design changes.	Changes to the applicability of WCAP- 12488 as a valid methodology to evaluate fuel assembly design changes for the first core will be submitted as a part of a Core Reference Report to the NRC and submittal of a License Amendment Request (LAR) as described in 10 CFR 50.92 before initial startup. Changes to the applicability of WCAP-12488 as a valid methodology to evaluate fuel assembly design changes made in subsequent cycles will be made consistent with Westinghouse's NRC approved reload methodology.	

DCD (Rev. 15) Change Summary for Chapter 4 – Sections 4.1, 4.2, 4.3 and 4.4							
ID	Sec	Page	Update	Rationale for DCD Update			
4.2 [6]	4.2.1.6	4.2-7	Remove Tier 2* information for the use of WCAP-12488 methodology to evaluate in-core control components.	Changes to the applicability of WCAP- 12488 as a valid methodology to evaluate in-core control components for the first core will be submitted as a part of a Core Reference Report to the NRC and submittal of a License Amendment Request (LAR) as described in 10 CFR 50.92 before initial startup. Changes to the applicability of WCAP-12488 as a valid methodology to evaluate in-core control components made in subsequent cycles will be made consistent with Westinghouse's NRC approved reload methodology.			
4.2 [7]	4.2.3	4.2-19	Remove Tier 2* information for the confirmation that fuel assemblies, fuel rods, and in-core components satisfy SRP Section 4.2 performance and safety criteria.	Changes to the confirmation that fuel assemblies, fuel rods, and in-core components satisfy SRP Section 4.2 performance and safety criteria for the first core will be submitted as a part of a Core Reference Report to the NRC and submittal of a License Amendment Request (LAR) as described in 10 CFR 50.92 before initial startup. Changes to the extent that SRP Section 4.2 performance and safety criteria are met in subsequent cycles will be made consistent with Westinghouse's NRC approved reload methodology.			
4.2 [8]	4.2.3, 4.2.6	4.2-19, 4.2.35	Remove Tier 2* information for the use of WCAP-12488 methodology for the fuel criteria evaluation process. Note, References 23 and 24 were previously added to Section 4.2 by APP-GW-GLR-059.	Changes to the methodology for the fuel criteria evaluation process for the first core will be submitted as a part of a Core Reference Report to the NRC and submittal of a License Amendment Request (LAR) as described in 10 CFR 50.92 before initial startup. Changes to the methodology for the fuel criteria evaluation process in subsequent cycles will be made consistent with Westinghouse's NRC approved reload methodology.			

DCD (Rev. 15) Change Summary for Chapter 4 – Sections 4.1, 4.2, 4.3 and 4.4						
ID	Sec	Page	Update	Rationale for DCD Update		
4.3 [1]	4.3.1, 4.3.5	4.3-1, 4.3-39	Remove Tier 2* information for the use of enhanced analytical techniques outside of those approved by NRC in WCAP- 12488-P-A.	Changes to the use of enhanced analytical techniques outside of those approved by NRC in WCAP-12488-P- A for the first core will be submitted as a part of a Core Reference Report to the NRC and submittal of a License Amendment Request (LAR) as described in 10 CFR 50.92 before initial startup. Changes to the use of enhanced analytical techniques outside of those approved by NRC in WCAP- 12488-P-A in subsequent cycles will be made consistent with Westinghouse's NRC approved reload methodology.		
4.3 [2]	4.3.1.1.1	4.3-2	Remove Tier 2* information for maximum average burnup and maximum extended burnup.	Changes to the maximum average burnup and maximum extended burnup for the first core will be submitted as a part of a Core Reference Report to the NRC and submittal of a License Amendment Request (LAR) as described in 10 CFR 50.92 before initial startup. Changes to the maximum average burnup and maximum extended burnup in subsequent cycles will be made consistent with Westinghouse's NRC approved reload methodology.		
4.3 [3]	Table 4.3-1		Remove Tier 2* status for the description of the first reactor core. Note that other changes to Table 4.3-1 are described in APP-GW- GLR-059.	Changes to the description of the first reactor core will be submitted as a part of a Core Reference Report to the NRC and submittal of a License Amendment Request (LAR) as described in 10 CFR 50.92 before initial startup. Changes to the description of the core in subsequent cycles will be made consistent with Westinghouse's NRC approved reload methodology.		
4.3 [4]	Table 4.3-2		Remove Tier 2* status for the nuclear design parameters for the first reactor core. Note that other changes to Table 4.3-2 are described in APP-GW- GLR-059.	Changes to the nuclear design parameters for the first reactor core will be submitted as a part of a Core Reference Report to the NRC and submittal of a License Amendment Request (LAR) as described in 10 CFR 50.92 before initial startup. Changes to the nuclear design parameters for the first reactor core in subsequent cycles will be made consistent with Westinghouse's NRC approved reload methodology.		

DCD (R	DCD (Rev. 15) Change Summary for Chapter 4 – Sections 4.1, 4.2, 4.3 and 4.4					
ID	Sec	Page	Update	Rationale for DCD Update		
4.3 [5]	Table 4.3-3		Remove Tier 2* status for the reactivity requirements for rod cluster control assembly for the first reactor core.	Changes to the reactivity requirements for the rod cluster control assemblies for the first reactor core will be submitted as a part of a Core Reference Report to the NRC and submittal of a License Amendment Request (LAR) as described in 10 CFR 50.92 before initial startup. Changes to the reactivity requirements for the rod cluster control assemblies for the first reactor core in subsequent cycles will be made consistent with Westinghouse's NRC approved reload methodology.		
4.4[1]	4.4.8	4.4-32	Remove Tier 2* status the use of WCAP-12488 methodology as the basis for maximum average burnup and maximum extended burnup.	Changes to the use of WCAP-12488 methodology for maximum average burnup and maximum extended burnup for the first core will be submitted as a part of a Core Reference Report to the NRC and submittal of a License Amendment Request (LAR) as described in 10 CFR 50.92 before initial startup. Changes to the use of WCAP-12488 methodology for maximum average burnup and maximum extended burnup in subsequent cycles will be made consistent with Westinghouse's NRC approved reload methodology.		

APPENDIX 1 DCD TIER 2* Mark-ups for Chapter 4 – Section 4.1

(remove brackets, italics, asterisks)

4.1.1 Principal Design Requirements

The fuel and rod control rod mechanism are designed so the performance and safety criteria described in Chapter 4 and Chapter 15 are met. [The mechanical design and physical arrangement of the reactor components, together with the corrective actions of the reactor control, protection, and emergency cooling systems (when applicable) are designed to achieve these criteria, referred to as Principal Design Requirements:

[The mechanical design and physical arrangement of the reactor components, together with the corrective actions of the reactor control, protection, and emergency cooling systems (when applicable) are designed to achieve these criteria, referred to as Principal Design Requirements:

- Fuel damage, defined as penetration of the fuel clad, is predicted not to occur during normal operation and anticipated operational transients.

- Materials used in the fuel assembly and in core control components are selected to be compatible in a pressurized water reactor environment.
- •For normal operation and anticipated transient conditions, the minimum DNBR calculated using the WRB-2M correlation is greater than or equal to 1.14.
- •Fuel-melting will not occur at the overpower-limit for Condition I or-II events.
- •The maximum fuel rod-cladding temperature following a loss of coolant-accident is calculated to be less than 2200°F.
- •For-normal operation and anticipated transient conditions, the calculated core average linear power, including densification effects, is less than or equal to 5.718 kw/ft for the initial fuel cycle.
- •For normal operation and anticipated transient conditions, the calculated total heat flux hot channel factor, F₀, is less than or equal to 2.60 for the initial fuel cycle.
- •Calculated rod worths provide sufficient reactivity to account for the power defect from full power to zero power and provide the required shutdown margin, with allowance for the worst stuck rod.
- •Calculations of the accidental withdrawal of two control banks using the maximum reactivity change rate predict that the peak linear heat rate and DNBR limits are met.

Fuel damage, defined as penetration of the fuel clad, is predicted not to occur during normal operation and anticipated operational transients.

- Materials used in the fuel assembly and in-core control components are selected to be compatible in a pressurized water reactor environment.
- For normal operation and anticipated transient conditions, the minimum DNBR calculated using the WRB-2M correlation is greater than or equal to 1.14.
- Fuel melting will not occur at the overpower limit for Condition I or II events.
- The maximum fuel rod cladding temperature following a loss-of-coolant accident is calculated to be less than 2200°F.
- For normal operation and anticipated transient conditions, the calculated core average linear power, including densification effects, is less than or equal to 5.718 kw/ft for the initial fuel cycle.
- For normal operation and anticipated transient conditions, the calculated total heat flux hot channel factor, F_Q, is less than or equal to 2.60 for the initial fuel cycle.
- Calculated rod worths provide sufficient reactivity to account for the power defect from full power to zero power and provide the required shutdown margin, with allowance for the worst stuck rod.
- Calculations of the accidental withdrawal of two control banks using the maximum reactivity change rate predict that the peak linear heat rate and DNBR limits are met.

- The maximum rod control cluster-assembly and gray rod speed (or travel rate) is 45 inches per minute.
- The control rod drive mechanisms are hydrotested after-manufacture at a minimum of 150 percent of system design pressure.
- For the initial fuel cycle, the fuel rod temperature coefficient is calculated to be negative for power operating conditions.
- For the initial fuel cycle, the moderator temperature coefficient is calculated to be negative for power operating conditions.]* The maximum rod control cluster assembly and gray rod speed (or travel rate) is 45 inches per minute.
- The control rod drive mechanisms are hydrotested after manufacture at a minimum of 150 percent of system design pressure.
- For the initial fuel cycle, the fuel rod temperature coefficient is calculated to be negative for power operating conditions.
- For the initial fuel cycle, the moderator temperature coefficient is calculated to be negative for power operating conditions.^{1*}

4.1.3 References

- Letter from N. J. Liparulo (Westinghouse) to J. E. Lyons (NRC), "Transmittal of Response to NRC Request for Information on Wolf Creek Fuel Design Modifications," NSD-NRC-97-5189, June 30, 1997.
- Letter from N. J. Liparulo (Westinghouse) to R. C. Jones (NRC), "Transmittal of Presentation Material for NRC/Westinghouse Fuel Design Change Meeting on April 15, 1996," NSD-NRC-96-4964, April 22, 1996.
- 3. Letter from Westinghouse to NRC, "Fuel Criteria Evaluation Process Notification for the 17x17 Robust Fuel Assembly with IFM Grid Design," NSD-NRC-98-5796, October 13, 1998.
- 4. Letter from H. A. Sepp (Westinghouse) to T. E. Collins (NRC), "Notification of FCEP Application for WRB-1 and WRB-2 Applicability to the 17x17 Modified LPD Grid Design for Robust Fuel Assembly Application," NSD-NRC-98-5618, March 25, 1998.
- Letter from H. A. Sepp (Westinghouse) to T. E. Collins (NRC), "Fuel Criteria Evaluation Process Notification for the Revised Guide Thimble Dashpot Design for the 17x17 XL Robust Fuel Assembly Design," NSD-NRC-98-5722, June 23, 1998.
- 6. Davidson, S. L., and Kramer, W. R., (Ed.), "Reference Core Report Vantage 5 Fuel Assembly," WCAP-10444-P-A (Proprietary), September 1985 and WCAP-10445-A (Non-Proprietary), December 1983.
- 7. Davidson, S. L., (Ed.), "VANTAGE 5H Fuel Assembly," Addendum 2-A, WCAP-10444-P-A (Proprietary) and WCAP-10445-NP-A (Non-Proprietary), February 1989.

 Davidson, S. L., and Nuhfer, D. L., (Ed.), "VANTAGE+ Fuel Assembly Reference Core Report," WCAP-12610-P-A (Proprietary) and WCAP-14342-A (Non-Proprietary), April 1995.

[9. Davidson, S. L. (Ed.), "Fuel Criteria Evaluation Process," WCAP-12488-A (Proprietary) and WCAP-14204-A (Non-Proprietary), October 1994.]*

19. Davidson, S. L. (Ed.), "Fuel Criteria Evaluation Process," WCAP-12488-A (Proprietary) and WCAP-14204-A (Non-Proprietary), October 1994.]*

10. NTD-NRC-94-4275 Westinghouse's Interpretation of Staff's Position on Extended Burnup, August 29, 1994.

APPENDIX 1 DCD TIER 2* MARK-UPS FOR CHAPTER 4 – SECTION 4.2

(remove brackets, italics, asterisks)

4.2 FUEL SYSTEM DESIGN

The plant conditions for design are divided into four categories.

- Condition I normal operation and operational transients
- Condition II events of moderate frequency
- Condition III infrequent incidents
- Condition IV limiting faults

Chapter 15 describes bases and plant operation and events involving each condition.

The reactor is designed so that its components meet the following performance and safety criteria:

- The mechanical design and physical arrangement of the reactor core components, together with corrective actions of the reactor control, protection, and emergency cooling systems (when applicable) provide that:
 - Fuel damage, that is, breach of fuel rod clad pressure boundary, is not expected during Condition I and Condition II events. A very small amount of fuel damage may occur. This is within the capability of the plant cleanup system and is consistent with the plant design bases.
 - The reactor can be brought to a safe state following a Condition III event with only a small fraction of fuel rods damaged. The fraction of fuel rods damaged must be limited to meet the dose guidelines of 10 CFR 100 although sufficient fuel damage might occur to preclude immediate resumption of operation.
 - The reactor can be brought to a safe state and the core kept subcritical with acceptable heat transfer geometry following transients arising from Condition IV events.
- The fuel assemblies are designed to withstand non-operational loads induced during shipping, handling, and core loading without exceeding the criteria of subsection 4.2.1.5.1.
- The fuel assemblies are designed to accept control rod insertions to provide the required reactivity control for power operations and reactivity shutdown conditions.
- The fuel assemblies have provisions for the insertion of in-core instrumentation.

• The reactor vessel and internals, in conjunction with the fuel assembly structure, directs reactor coolant through the core. Because of the resulting flow distribution and bypass flow, the heat transfer performance requirements are met for the modes of operation.

The following subsection provides the fuel system design bases and design limits. It is consistent with the criteria of the Standard Review Plan, Section 4.2.

Consistent with the growth in technology, Westinghouse modifies fuel system designs. These modifications utilize NRC approved methods. [A set of design fuel criteria to be satisfied by new fuel designs was issued to the NRC in WCAP 12488 A (Reference 1)]* and also presented below in subsection 4.2.1.. [A set of design fuel criteria to be satisfied by new fuel designs was issued to the NRC in WCAP-12488-A (Reference 1)]* and also presented below in subsection 4.2.1.

4.2.1 Design Basis

The fuel rod and fuel assembly design bases are established to satisfy the general performance and safety criteria presented in Section 4.2 of the Standard Review Plan. [The design bases and acceptance limits used by Westinghouse are also described in the Westinghouse Fuel Criteria Evaluation Process, WCAP-12488 A (Reference 1).]*

[The design bases and acceptance limits used by Westinghouse are also described in the Westinghouse Fuel Criteria Evaluation Process, WCAP-12488-A (Reference 1).]*

The fuel rods are designed to satisfy the fuel rod design criteria for rod burnup levels up to the design discharge burnup using the extended burnup design methods described in the Extended Burnup Evaluation report, WCAP-10125-P-A (Reference 2).

The AP1000 fuel rod design considers effects such as fuel density changes, fission gas release, clad creep, and other physical properties which vary with burnup. The integrity of the fuel rods is provided by designing to prevent excessive fuel temperatures as discussed in subsection 4.2.1.2.1; excessive internal rod gas pressures due to fission gas releases as discussed in subsections 4.2.1.3.1 and 4.2.1.3.2; and excessive cladding stresses, strains, and strain fatigue, as discussed in subsections 4.2.1.1.2 and 4.2.1.1.3. The fuel rods are designed so that the conservative design bases of the following events envelope the lifetime operating conditions of the fuel. For each design basis, the performance of the limiting fuel rod, with appropriate consideration for uncertainties, does not exceed the limits specified by the design basis. The detailed fuel rod design also establishes such parameters as pellet size and density, clad/pellet diametral gap, gas plenum size, and helium pre-pressurization level.

Integrity of the fuel assembly structure is provided by setting limits on stresses and deformations due to various loads and by preventing the assembly structure from interfering with the functioning of other components. Three types of loads are considered:

- Non-operational loads, such as those due to shipping and handling
- Normal and abnormal loads, which are defined for Conditions I and II
- Abnormal loads, which are defined for Conditions III and IV

The design bases for the in-core control components are described in subsection 4.2.1.6.

4.2.1.1 Cladding

4.2.1.1.1 Mechanical Properties

The ZIRLO[™] cladding material combines neutron economy (low absorption cross-section); high corrosion resistance to coolant, fuel, and fission products; and high strength and ductility at operating temperatures. ZIRLO[™] is an advanced zirconium based alloy that has the same or similar properties and advantages as Zircaloy-4 and was developed to support extended fuel burnup. WCAP-12610-P-A (Reference 5) provides a discussion of chemical and mechanical properties of the ZIRLO[™] cladding material and a comparison to Zircaloy-4.

4.2.1.1.2 Stress-Strain Limits

Clad Stress

[The volume average effective stress calculated with the Von Mises equation (considering interference due to uniform cylindrical pellet clad contact, caused by pellet thermal expansion, pellet swelling and uniform clad creep, and pressure differences) is less than the 0.2 percent offset yield stress with due consideration to temperature and irradiation effects for Condition I and II events, WCAP 12488 A (Reference 1).]*[The volume average effective stress calculated with the Von Mises equation (considering interference due to uniform cylindrical pellet-clad contact, caused by pellet thermal expansion, pellet swelling and uniform clad creep, and pressure differences) is less than the 0.2 percent offset yield stress with due consideration to temperature and irradiation effects for Condition I and II events, WCAP-12488-A (Reference 1).]* -While the clad has some capability for accommodating plastic strain, the yield stress has been accepted as a conservative design limit. The allowable stress limits due to Condition III and IV loadings, described in subsection 4.2.1.5.3, are also applied to the fuel rod.

Clad Strain

[The total plastic tensile creep strain due to uniform clad creep, and uniform cylindrical fuel pellet expansion associated with fuel swelling and thermal expansion is less than one percent from the unirradiated condition, WCAP-12488-A (Reference 1).]*[The total plastic tensile creep strain due to uniform clad creep, and uniform cylindrical fuel pellet expansion associated with fuel swelling and thermal expansion is less than one percent from the unirradiated condition, WCAP-12488-A (Reference 1).]* -The acceptance limit for fuel rod clad strain during Condition II events is that the total tensile strain due to uniform cylindrical pellet thermal expansion is less than one percent from the pretransient value. These limits are consistent with proven practice.

4.2.1.1.3 Fatigue and Vibration

Fatigue

[The usage factor due to cycle fatigue is less than 1.0, WCAP-12488 A (Reference 1).]*[The usage factor due to cycle fatigue is less than 1.0, WCAP-12488-A (Reference 1).]* That is, for a given strain range, the number of strain fatigue cycles are less than those required for failure. The fatigue curve is based on a safety factor of two on the stress amplitude or a safety factor of 20 on the number of cycles, whichever is more conservative.

4.2.1.5 Fuel Assembly Structural Design

As discussed in subsection 4.2.1, the structural integrity of the fuel assemblies is provided by setting design limits on stresses and deformations due to various non-operational, operational, and accident loads. These limits are applied to the design and evaluation of the top and bottom nozzles, guide thimbles, grids, and thimble joints. [Design changes to the fuel assembly structure qualify for evaluation in WCAP-12488-A (Reference 1).]^{*}

.-{Design changes to the fuel assembly structure qualify for evaluation in WCAP-12488-A (Reference 1).- J^{*}

The design bases for evaluating the structural integrity of the fuel assemblies are discussed in subsections 4.2.1.5.1 through 4.2.1.5.3.

4.2.1.6 In-core Control Components

The in-core control components are subdivided into permanent and temporary devices. The permanent components are the rod cluster control assemblies, gray rod control assemblies, and secondary neutron source assemblies. The temporary components are the primary neutron source assemblies (which are normally used only in the initial core), the burnable absorber assemblies, and the thimble plugs. For some reloads, the use of burnable absorbers may be necessary for power distribution control and/or to achieve an acceptable moderator temperature coefficient throughout core life (See Subsection 4.3.1.2.2). [Design changes to the in-core control components qualify for evaluation using the criteria defined in WCAP-12488-A (Reference 1).]*

{Design changes to the in-core control components qualify for evaluation using the criteria defined in WCAP-12488-A (Reference 1).]*

Materials are selected for:

- Compatibility in a pressurized water reactor environment
- Adequate mechanical properties at room and operating temperatures
- Resistance to adverse property changes in a radioactive environment
- Compatibility with interfacing components

Material properties are given in WCAP-9179 (Reference 4).

^{*} NRC Staff approval is required prior to implementing a change in this information; see DCD Introduction Section 3.5.

^{*} NRC Staff approval is required prior to implementing a change in this information; see DCD Introduction Section 3.5.

The design bases for the in-core control components are given in subsections 4.2.1.6.1 through 4.2.1.6.3.

4.2.3 Design Evaluation

[The fuel assemblies, fuel rods, and in-core control components are designed to satisfy the performance and safety criteria of]*[The fuel assemblies, fuel rods, and in-core control components are designed to satisfy the performance and safety criteria of]* -Section 4.2 of the Standard Review Plan, the mechanical design bases of subsection 4.2.1 and [the Fuel Criteria Evaluation Process per WCAP-12488 A (Reference 1)]*,[the Fuel Criteria Evaluation Process per WCAP-12488 A (Reference 1)]*,[the Fuel Criteria and hydraulic design bases specified in Sections 4.3 and 4.4.

Effects of Conditions II, III, IV or anticipated transients without trip on fuel integrity are presented in Chapter 15.

The initial step in fuel rod design evaluation for a region of fuel is to determine the limiting rod(s). Limiting rods are defined as those rods whose predicted performance provides the minimum margin to each of the design criteria. For a number of design criteria, the limiting rod is the lead burnup rod of a fuel region. In other instances, it may be the maximum power or the minimum burnup rod. For the most part, no single rod is limiting with respect to all the design criteria.

After identifying the limiting rod(s), an analysis is performed to consider the effects of rod operating history, model uncertainties, and dimensional variations. To verify adherence to the design criteria, the evaluation considers the effects of postulated transient power changes during operation consistent with Conditions I and II. These transient power increases can affect both rod average and local power levels. Parameters considered include rod internal pressure, fuel temperature, clad stress, and clad strain. In fuel rod design analyses, these performance parameters provide the basis for comparison between expected fuel rod behavior and the corresponding design criteria limits.

Fuel rod and assembly models used for the performance evaluations are documented and maintained under an appropriate control system. Material properties used in the design evaluations are given in WCAP-12610 (Reference 5).

4.2.6 References

- [1. Davidson, S. L. (Ed.), "Fuel Criteria Evaluation Process," WCAP-12488-A (Proprietary) and WCAP-14204-A (Non-Proprietary), October 1994.]*
- **[1.** Davidson, S. L. (Ed.), "Fuel Criteria Evaluation Process," WCAP-12488-A (Proprietary) and WCAP-14204-A (Non-Proprietary), October 1994.]*
- 2. Davidson, S. L. (Ed.) et al., "Extended Burnup Evaluation of Westinghouse Fuel," WCAP-10125-P-A (Proprietary) and WCAP-10126-NP-A (Non-Proprietary), December 1985.
- 3. "Operational Experience with Westinghouse Cores," WCAP-8183, Revision 23, January 1996.

- 4. Beaumont, M. D., et al., "Properties of Fuel and Core Component Materials," WCAP-9179, Revision 1 (Proprietary) and WCAP-9224 (Non-Proprietary), July 1978.
- 5. Davidson, S. L., and Nuhfer, D. L. (Ed.), "VANTAGE+ Fuel Assembly Reference Core Report," WCAP-12610-P-A (Proprietary), June 1990 and WCAP-14342-A (Non-Proprietary), April 1995.
- 6. Hellman, J. M., Ed, "Fuel Densification Experimental Results and Model for Reactor Application," WCAP-8218-P-A (Proprietary) and WCAP-8219-A (Nonproprietary), March 1975.
- Weiner, R. A., et al., "Improved Fuel Performance Models for Westinghouse Fuel Rod Design and Safety Evaluations," WCAP-10851-P-A (Proprietary) and WCAP-11873-A (Nonproprietary), August, 1988.
- Davidson, S. L. (Ed) et al., "Assessment of Clad Flattening and Densification Power Spike Factor Elimination in Westinghouse Nuclear Fuel," WCAP-13589-A (Proprietary) and WCAP-14297-A (Non-Proprietary), March 1995.
- Risher, D., et al., "Safety Analysis for the Revised Fuel Rod Internal Pressure Design Basis," WCAP-8963-P-A (Proprietary), November 1976 and WCAP-8964-A (Non-Proprietary), August 1977.
- Skarita, J., et al., "Westinghouse Wet Annular Burnable Absorber Evaluation Report," WCAP-10021-P-A, Revision 1 (Proprietary) and WCAP-10377-NP-A, Revision 2 (Non-Proprietary), October 1983.
- Davidson, S. L. (Ed.) et al., "Reference Core Report VANTAGE 5 Fuel Assembly," WCAP-10444-P-A (Proprietary) and WCAP-10445-NP-A (Nonproprietary), September 1985.
- 12. ASTM-A-580-90, Specification for Stainless and Heat-resisting Steel Wire.
- 13. Demario, E. E., "Hydraulic Flow Test of the 17x17 Fuel Assembly," WCAP-8278 (Proprietary) and WCAP-8279 (Non-Proprietary), February 1974.
- 14. Skaritka, J. (Ed.), "Fuel Rod Bow Evaluation," WCAP-8691, Revision 1 (Proprietary) and WCAP-8692, Revision 1 (Non-Proprietary), July 1979.
- 15. Davidson, S. L. and Iorii, J. A., "Reference Core Report 17x17 Optimized Fuel Assembly," WCAP-9500-P-A (Proprietary) and WCAP-9500-A (Nonproprietary), May 1982.
- 16. O'Donnell, W. J., and Langer, B. F., "Fatigue Design Basis for Zircaloy Components," Nuclear Science and Engineering 20, pp 1-12, 1964.
- Gesinski, L., and Chiang, D., "Safety Analysis of the 17x17 Fuel Assembly for Combined Seismic and Loss-of-Coolant Accident," WCAP-8236 (Proprietary) and WCAP-8288 (Nonproprietary), December 1973.

- 18. Davidson, S. L., et al., "Verification, Testing, and Analysis of the 17x17 Optimized Fuel Assembly," WCAP-9401-P-A (Proprietary) and WCAP-9402-A (Nonproprietary), August 1981.
- Witt, F. J., Bamford, W. H., and Esselman, T. C., "Integrity of the Primary Piping Systems of Westinghouse Nuclear Power Plants During Postulated Seismic Events," WCAP-9283 (Nonproprietary), March 1978.
- 20. ASTM-E-142-86, Methods for Controlling Quality of Radiographic Testing.
- Foster, J. P., et al., "Westinghouse Improved Performance Analysis and Design Model (PAD 4.0)," WCAP-15063-P-A, Revision 1 (Proprietary) and WCAP-15064-NP-A, Revision 1 (Non-Proprietary), July 2000.
- 22. George, R. A., et al., "Revised Clad Flattening Model," WCAP-8377 (Proprietary), July 1974.
- 23. WCAP-7113, "Use of Burnable Poison Rods in Westinghouse Pressurized Water Reactors," October 1967.
- 24. WCAP-16652-P, "AP1000 Core & Fuel Design Techncial Report"

APPENDIX 1 DCD TIER 2* MARK-UPS FOR CHAPTER 4 – SECTION 4.3

(REMOVE BRACKETS, ITALICS, ASTERISKS)

4.3 NUCLEAR DESIGN

4.3.1 Design Basis

This section describes the design bases and functional requirements used in the nuclear design of the fuel and reactivity control system and relates these design bases to the General Design Criteria (GDC). The design bases are the fundamental criteria that must be met using approved analytical techniques. [Enhancements to these techniques may be made provided that the changes are founded by NRC approved methodologies as discussed in]*[Enhancements to these techniques may be made provided that the changes are founded by NRC approved methodologies as discussed in]* -WCAP-9272-P-A (Reference 1) and [WCAP-12488-P-A (Reference 2).]*

and {WCAP-12488-P-A (Reference 2).]*

The plant conditions for design are divided into four categories:

- Condition I Normal operation and operational transients
- Condition II Events of moderate frequency
- Condition III Infrequent incidents
- Condition IV Limiting faults

The reactor is designed so that its components meet the following performance and safety criteria:

- In general, Condition I occurrences are accommodated with margin between any plant parameter and the value of that parameter which would require either automatic or manual protective action.
- Condition II occurrences are accommodated with, at most, a shutdown of the reactor with the plant capable of returning to operation after corrective action.
- Fuel damage, that is, breach of fuel rod clad pressure boundary, is not expected during Condition I and Condition II occurrences. A very small amount of fuel damage may occur. This is within the capability of the chemical and volume control system (CVS) and is consistent with the plant design basis.
- Condition III occurrences do not cause more than a small fraction of the fuel elements in the reactor to be damaged, although sufficient fuel element damage might occur to preclude immediate resumption of operation.

- The release of radioactive material due to Condition III occurrences is not sufficient to interrupt or restrict public use of those areas beyond the exclusion area boundary.
- A Condition III occurrence does not by itself generate a Condition IV occurrence or result in a consequential loss of function of the reactor coolant or reactor containment barriers.
- Condition IV faults do not cause a release of radioactive material that results in exceeding the limits of 10 CFR 100. Condition IV occurrences are faults that are not expected to occur but are defined as limiting faults which are included in the design.

The core design power distribution limits related to fuel integrity are met for Condition I occurrences through conservative design and are maintained by the action of the control system.

The requirements for Condition II occurrences are met by providing an adequate protection system which monitors reactor parameters.

The control and protection systems are described in Chapter 7.

The consequences of Condition II, III, and IV occurrences are described in Chapter 15.

4.3.1.1 Fuel Burnup

4.3.1.1.1 Basis

A limitation on initial installed excess reactivity or average discharge burnup is not required other than as is quantified in terms of other design bases, such as overall negative power reactivity feedback discussed below. [The NRC has approved, in WCAP 12488 P-A (Reference 2), maximum fuel rod average burnup of 60,000 MWD/MTU. Extended burnup to 62,000 MWD/MTU has been established in Reference 61.]*. [The NRC has approved, in WCAP-12488-P-A (Reference 2), maximum fuel rod average burnup of 60,000 MWD/MTU. Extended burnup to 62,000 MWD/MTU has been established in Reference 61.]*. [The NRC has approved, in WCAP-12488-P-A (Reference 2), maximum fuel rod average burnup of 60,000 MWD/MTU. Extended burnup to 62,000 MWD/MTU has been established in Reference 61.]*.

4.3.5 References

- 1. Bordelon, F. M, et al., "Westinghouse Reload Safety Evaluation Methodology," WCAP-9272-P-A (Proprietary) and WCAP-9273-NP-A (Nonproprietary), July 1985.
- -{2. Davidson, S. L. (Ed.), "Fuel Criteria Evaluation Process," WCAP-12488-P-A (Proprietary) and WCAP-14204-A (Nonproprietary), October 1994.]^{*}
- [2. Davidson, S. L. (Ed.), "Fuel Criteria Evaluation Process," WCAP 12488 P A (Proprietary) and WCAP 14204 A (Nonproprietary), October 1994.]^{*}

^{*} NRC Staff approval is required prior to implementing a change in this information; see DCD Introduction Section 3.5.

APP-GW-GLR-119, Revision 0

(other section 4.3 references are not Tier 2*)

* NRC Staff approval is required prior to implementing a change in this information; see DCD Introduction Section 3.5.

Table 4.3-1 (Sheet 1 of 3)

<u>|REACTOR CORE DESCRIPTION</u> (FIRST CYCLE)|±

Active core
Equivalent diameter (in.)
Active fuel height first core (in.), cold
Height-to-diameter ratio
Total cross section area (ft ²)
H ₂ O/U molecular ratio, cell, cold
Reflector thickness and composition
Top - water plus steel (in.)~10
Bottom - water plus steel (in.)~10
Side - water plus steel (in.)
Fuel assemblies
Number
<u>Rod array</u>
Rods per assembly
Rod pitch (in.)
Overall transverse dimensions (in.)
Fuel weight, as UO ₂ (lb)
Zircaloy clad weight (lb)
Number of grids per assembly
Top and bottom - (Ni-Cr-Fe Alloy 718)
Intermediate
Intermediate flow mixing (IFM)
Number of guide thimbles per assembly
Composition of guide thimblesZIRLO™
Diameter of guide thimbles, upper part (in.)
Diameter of guide thimbles, lower part (in.)
Diameter of instrument guide thimbles (in.)
lote.

(a) <u>The top grid will be fabricated of nickel-chromium-iron Alloy 718</u>

Table 4.3-1 (Sheet 2 of 3) **FREACTOR CORE DESCRIPTION** (FIRST CYCLE)^{‡*} Fuel rods Diameter gap (in.) .0.0065 <u>Clad material</u>.....ZIRLO Fuel pellets Fuel enrichments (weight %) Mass of UO₂ per ft of fuel rod (lb/ft)0.366 Rod Cluster Control Assemblies Density $(lb/in.^3)$ Gray Rod Cluster Assemblies

<u>Table 4.3-2 (Sheet 1 of 2)</u>						
<u>{NUCLEAR DESIGN PARAMETERS</u> (FIRST CYCLE)}≛						
Core average linear power, including densification effects (kW/ft)						
Total heat flux hot channel factor, F _Q		2.60				
<u>Nuclear enthalpy rise hot channel factor, $F_{\Delta H}^{N}$</u>		<u>1.65</u>				
Reactivity coefficients (a)	Design Limits	Best Estimate				
Doppler-only power coefficients (see Figure 15.0.4-1) (pcm/% pow	ver) ^(b)					
Upper curve	19.4 to -12.6	13.3 to - <u>8.7</u>				
Lower curve	<u>-10.2 to -6.7</u>	11.3 to - <u>8.4</u>				
Doppler temperature coefficient (pcm/°F) ^(b)	3.5 to -1.0	2.1 to -1.3				
Moderator temperature coefficient (pcm/°F) ^(b)	0 to -40	0 to -35				
Boron coefficient (pcm/ppm) ^(b)	13.5 to -5.0	10.5 to - <u>6.9</u>				
Rodded moderator density (pcm/g/cm ³) ^(b)	$ \le 0.47 \times 10^5$	$\dots \leq 0.45 \times 10^5$				
Delayed neutron fraction and lifetime, β_{eff}		0.0075(0.0044) ^(c)				
<u>Prompt Neutron Lifetime</u> , ℓ^* , μ s						
Control rods						
Rod requirements		See Table 4.3-3				
Maximum ejected rod worth		See Chapter 15				
Bank worth HZP no overlap (pcm) ^(b)	BOL, Xe Free	EOL, Eq. Xe				
<u>MA Bank</u>						
<u>MB</u> Bank	131	<u>198</u>				
MC Bank						
MD Bank						
<u>M1 Bank</u>						
M2 Bank						
AO Bank						

<u>Table 4.3-2 (Sheet 2 of 2)</u>						
<u>{NUCLEAR DESIGN PARAMETERS</u> <u>(FIRST CYCLE)}≭</u>						
Typical Hot Channel Factors $F^N_{\Delta H}$						
Unrodded	<u>1.40</u> <u>1.33</u>					
MA bank	1.461.38					
<u>MA + MB banks</u>	<u></u> 1.491.42					
<u>MA + MB + MC banks</u>	<u>1.501.31</u>					
<u>MA + MB + MC + MD banks</u>	<u></u>					
MA + MB + MC + MD + M1 banks	<u>1.45</u>					
AO bank	<u>1.601.52</u>					
Boron concentrations (ppm)						
Zero power, k _{eff} = 0.99, cold ^(d) RCCAs out						
Zero power, $k_{eff} = 0.99$, hot ^(e) RCCAs out	1502					
Design basis refueling boron concentration						
Zero power, $k_{eff} \leq 0.95$, cold ^(d) RCCAs in	<u>1179</u>					
Zero power, $k_{eff} = 1.00$, $hot^{(e)}$ RCCAs out						
Full power, no xenon, k _{eff} = 1.0, hot RCCAs out						
Full power, equilibrium xenon, k = 1.0, hot RCCAs out						
Reduction with fuel burnup						
First cycle (ppm/(GWD/MTU)) ^(f)	See Figure 4.3-3					
Reload cycle (ppm/(GWD/MTU))	<u>~40</u>					
otes:						

(a) Uncertainties are given in subsection 4.3.3.3.

(b) 1 pcm = $10^{-5} \Delta \rho$ where $\Delta \rho$ is calculated form two statepoint values of k_{eff} by ln (k_1/k_2).

(c) Bounding lower value used for safety analysis.

(d) Cold means 68°F, 1 atm.

(e) Hot means 557°F, 2250 psia.

(f) 1 GWD = 1000 MWD. During the first cycle, a large complement of burnable absorbers is present which significantly reduce the boron depletion rate compared to reload cycles.

APPENDIX 1

	Table 4.3-3				
[REACTIVITY REQUIREMENTS FOR ROD CLUSTER CONTROL ASSEMBLIES]*					
	Reactivity Effects (Percent)	BOL (First Cycle)	EOL (First Cycle)	EOL Representative (Equilibrium Cycle)	
1.	Control requirements				
	Total power defect $(\%\Delta\rho)(a)$	1.89	2.54	3.02	
	Redistribution (adverse xenon only) (% $\Delta \rho$)	0.27	0.40	0.32	
	Rod insertion allowance $(\%\Delta\rho)$	2.00	2.00	2.00	
2.	Total control (%Δρ)	4.16	4.94	5.34	
3.	Estimated RCCA worth (69 rods)			<u></u>	
	a. All full-length assemblies inserted ($\%\Delta\rho$)	12.69	10.89	10.64	
	b. All assemblies but one (highest worth) inserted $(\%\Delta\rho)$	10.49	9.27	9.35	
4.	Estimated RCCA credit with 7 percent adjustment to accommodate uncertainties, item 3b minus 7 percent ($\%\Delta\rho$)	9.76	8.62	8.70	
5.	Shutdown margin available, item 4 minus item 2 ($\%\Delta\rho$)(b)	5.60	3.68	3.36	

Notes:

(a) Includes void effects

(b) The design basis minimum shutdown is 1.60 percent

,

APPENDIX 1 DCD TIER 2* MARK-UPS FOR CHAPTER 4 – SECTION 4.4

(remove brackets, italics, asterisks)

4.4.8 References

- 1. ANSI N18.2a-75, "Nuclear Safety Criteria for the Design of Stationary Pressurized Water Reactor Plants."
- 2. Friedland, A. J. and Ray, S., "Revised Thermal Design Procedure," WCAP-11397-P-A (Proprietary) and WCAP-11397-A (Non-Proprietary), April 1989.
- 3. 3.Christensen, J. A., Allio, R. J., and Biancheria, A., "Melting Point of Irradiated UO₂," WCAP-6065, February 1965.
- 4. Davidson, S. L. and Kramer, W. R. (Ed.), "Reference Core Report VANTAGE 5 Fuel Assembly," WCAP-10444-P-A (Proprietary) and WCAP-10445-NP-A (Non-Proprietary), September 1985.
- 5. Tong, L. S., "Boiling Crisis and Critical Heat Flux," AEC Critical Review Series, TID-25887, 1972.
- 6. Tong, L. S., "Critical Heat Fluxes in Rod Bundles, Two Phase Flow and Heat Transfer in Rod Bundles," Annual Winter Meeting ASME, November 1968, p. 3146.
- Letter from A. C. Thadani (NRC) to W. J. Johnson (Westinghouse), January 31, 1989, Subject: Acceptance for Referencing of Licensing Topical Report, WCAP-9226-P/9227-NP, "Reactor Core Response to Excessive Secondary Steam Releases."
- Motley, F. E., Cadek, F. F., "DNB Test Results for R-Grid Thimble Cold Wall Cells," WCAP-7695-L Addendum 1, October 1972.
- [------Davidson, S. L. (Ed.), "Westinghouse Fuel Criteria Evaluation Process," WCAP 12488 A, October 1994.]*
- ------Davidson, S. L. (Ed.), "Westinghouse Fuel Criteria Evaluation Process," WCAP-12488-A, October 1994.]*