

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.4.6.1 -----NOTE-----                      Not required to be performed in MODE 3.                      -----</p> <p>Verify equivalent leakage of each RCS PIV is <math>\leq 0.5</math> gpm per nominal inch of valve size up to a maximum of 5 gpm, at an RCS pressure <math>\geq 1000</math> psig and <math>\leq 1025</math> psig.</p>	<p>In accordance with Inservice Testing Program</p>