

## CONTAINMENT SYSTEMS

### SURVEILLANCE REQUIREMENTS (Continued)

---

- c. At least once per 18 months, during shutdown, by:
  - 1. Verifying that each automatic valve in the flow path actuates to its correct position on CSAS and RAS test signals.
  - 2. Verifying that upon a RAS test signal, the containment sump isolation valves open and that a recirculation mode flow path via an OPERABLE shutdown cooling heat exchanger is established.
  - 3. Verifying that each spray pump starts automatically on a CSAS test signal.
- d. Verify each spray nozzle is unobstructed following maintenance which could result in nozzle blockage.