

FAQ Number 06-0028 FAQ Revision 2

FAQ Title Training Definition and Content

Plant: Harris Nuclear Plant (HNP) Date: 05-21-07

Contact: Alan Holder Phone: 919-546-3372

Email: alan.holder@pgnmail.com

Distribution: *(NEI Internal Use)*

805 TF FPWG FPRATF

Purpose of FAQ:

Clarify expected content “familiarization with plant fire prevention procedures, fire reporting, and plant emergency alarms” regarding scope of or depth of the training.

Is this Interpretation of guidance? Yes / No

Proposed new guidance not in NEI 04-02? Yes / No

Details:

NEI 04-02 guidance needing interpretation (include section, paragraph, and line numbers as applicable):

NEI 04-02, Section 4.3.1, Fundamental Fire Protection Program and Design Elements Transition Review, appendices to list acceptable interpretations to the NFPA 805 standard (future).

Circumstances requiring guidance interpretation or new guidance:

Clarification of NFPA-805, Standard for Fire Protection for Light Water Reactor Electric Generating Plants (2001 Edition), Chapter 3, Section 3.3.1.1 General Fire Prevention Activities, “(1) Training on fire safety information for all employees and contractors including, as a minimum, familiarization with plant fire prevention procedures, fire reporting, and plant emergency alarms.”

Specifically, clarify what is “familiarization with plant fire prevention procedures, fire reporting, and plant emergency alarms” regarding scope of or depth of the training.

Detail contentious points if licensee and NRC have not reached consensus on the facts and circumstances:

NA

Potentially relevant existing FAQ numbers:FAQ 06-0007

Response Section:**Proposed resolution of FAQ and the basis for the proposal:**

Clarify expected content “familiarization with plant fire prevention procedures, fire reporting, and plant emergency alarms” regarding scope and content the training. This FAQ asks for clarification of what is “familiarization with plant fire prevention procedures, fire reporting, and plant emergency alarms” regarding scope of or depth of the training.” Because existing employee general access and indoctrination training is a mature program, and based on NEI 03-04, Guide for Plant Access Training, section 7.5 Fire Protection, consistent information of sufficient detail, is provided at all sites by their General Employee Training (GET) Program. The proposed interpretation contains those key elements listed in the NEI guidance.

If appropriate, provide proposed rewording of guidance for inclusion in the next Revision:

As follows;

Clarification NFPA 805 specific sections as may be applied under NEI 04-02, to be included in (New) Appendix K, to NEI 04-02 upon approval of specific clarification (final formatting to be provided by NEI contract writers).

Specific clarification for NFPA 805 section 3.3.1.1, from FAQ 06-0028;

Where used in section 3.3.1.1, the term, “familiarization with plant fire prevention procedures, fire reporting, and plant emergency alarms”, should be considered to be acceptable when it includes the minimum following training objectives;

- Location and use of plant fire prevention procedures.
- Individual responsibilities regarding fire barriers such as fire dampers, doors, and seals.
- Actions an individual is required to take upon discovery of a fire.
- Individual responsibilities regarding the control of transient combustibles (wood, solvents, oil) and the disposal of flammable and combustible materials.
- Examples of the types of hot work requiring a permit.
- Recognition of, and response to a station fire alarm.
- Other plant specific fire prevention activities.

This familiarization may be included as part of the plant’s General Employee Training (GET) program.