



State of New Jersey

DEPARTMENT OF ENVIRONMENTAL PROTECTION
 Division of Environmental Safety and Health
 Radiation Protection and Release Prevention Element
 Bureau of Nuclear Engineering
 PO Box 415
 Trenton, New Jersey 08625-0415
 Phone: (609) 984-7700
 Fax: (609) 984-7513

JON S. CORZINE
 Governor

LISA P. JACKSON
 Commissioner

May 30, 2007

United States Nuclear Regulatory Commission
 Document Control Desk
 Washington, DC 20555-0001

Dear Gentlemen:


Subject: Hope Creek Generating Station (HCGS)
 Docket No. 50-354
 License Change Request (LCR) H06-02

PSEG Nuclear LLC (PSEG) submitted the subject change request to the Nuclear Regulatory Commission (NRC) on November 15, 2006. The proposed change would remove Primary Containment Isolation Valve lists and references to these lists from the Technical Specifications (TS). The information contained in the deleted tables would be relocated to the HCGS Technical Requirements Manual (TRM).

The New Jersey Department of Environmental Protection's (DEP) Bureau of Nuclear Engineering (BNE) reviewed the request in accordance with the requirements of 10 CFR 50.91(b). Our review determined that the proposed TS changes are consistent with NRC Generic Letter 91-08, "Removal of Component Lists from Technical Specifications"; the proposed changes are consistent with the Improved Standard Technical Specifications (STS) described in NUREG-1433, "Standard Technical Specifications, General Electric Plants (BWR/4)"; and changes to the TRM are required to be reviewed pursuant to 10 CFR 50.59. Therefore, we have no comments.

If you have any questions, please contact Jerry Humphreys at (609) 984-7469.

Sincerely yours,


 Kent Tosch
 Manager IV, BNE

4001

c: R. Pinney, New Jersey DEP

N. McNamara , NRC Region I State Liaison Officer

R. Ennis, NRC Project Manager

M. Gaffney, PSEG Hope Creek Regulatory Assurance