



State of New Jersey

DEPARTMENT OF ENVIRONMENTAL PROTECTION
Division of Environmental Safety and Health
Radiation Protection and Release Prevention Element
Bureau of Nuclear Engineering
P. O. Box 415
Trenton, New Jersey 08625-0415
Tel (609) 984-7700
Fax (609) 984-7513

JON S. CORZINE
Governor

LISA P. JACKSON
Commissioner

May 30, 2007

United States Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Dear Sir:

Subject: Salem Generating Station Units 1 and 2
Docket Nos. 50-272 and 50-311
License Change Request S06-10
Request for Change to Technical Specifications
Steam Generator Feedwater Pump Trip, Feedwater Isolation Valve
Response Time Testing and Containment Cooling System

PSEG Nuclear LLC submitted the proposed change to the Salem Technical Specifications by letter to the NRC dated March 16, 2007. The proposed amendment involves (1) new technical specification (TS) surveillance requirements for Steam Generator Feedwater Pump trip and Feedwater Isolation Valve closure, and (2) revised TS surveillance requirements for Containment Fan Cooler Unit flow.

The BNE has no comments on the proposed change. If you need to discuss this subject further, please contact Elliot Rosenfeld at (609) 984-7548.

Sincerely,

Kent W. Tosch, Manager
Bureau of Nuclear Engineering

ACC1
NRC/NRR

Ditribution

Dr. Jill Lipoti, DEP

Paul Baldauf, DEP

Richard Pinney, DEP

Elliot Rosenfeld, DEP

Nancy McNamara, NRC Region 1

Rick Ennis, NRC Licensing Project Manager

Daniel Schroeder, Sr Resident Inspector

Steven Mannon, Regulatory Assurance Manager, Salem Generating Station