



Tennessee Valley Authority, Post Office Box 2000, Soddy-Daisy, Tennessee 37379-2000

June 12, 2007

State of Tennessee  
Department of Environment and Conservation  
Division of Water Pollution Control  
Enforcement & Compliance Section  
6<sup>th</sup> Floor, L & C Annex  
401 Church Street  
Nashville, Tennessee 37243-1534

Dear Mr. Hannah:

SEQUOYAH NUCLEAR PLANT - DISCHARGE MONITORING REPORT FOR MAY 2007

Enclosed is the May 2007 Discharge Monitoring Report for Sequoyah Nuclear Plant. Also enclosed is a correction to the April DMR for Outfall 103 Flow. Please contact me at (423) 843-6700 if you have any questions or comments.

Sincerely,

Stephanie A. Howard  
Principal Environmental Engineer  
Signatory Authority for  
J. Randy Douet  
Site Vice President  
Sequoyah Nuclear Plant

Enclosure

cc (Enclosure):

Chattanooga Environmental Assistance Center  
Division of Water Pollution Control  
State Office Building, Suite 550  
540 McCallie Avenue  
Chattanooga, Tennessee 37402-2013

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555

Name **TVA - SEQUOYAH NUCLEAR PLANT**  
 Address **P.O. BOX 2000**  
 (INTEROFFICE SB-2A)  
**SODDY - DAISY TN 37384**  
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**  
 Location **HAMILTON COUNTY**

**TN0026450** **101 G**  
 PERMIT NUMBER DISCHARGE NUMBER

MONITORING PERIOD  
 From **07 05 01** To **07 05 31**

F - FINAL  
 DIFFUSER DISCHARGE  
 EFFLUENT

\*\*\* NO DISCHARGE  \*\*\*

ATTN: Stephanie A. Howard

NOTE: Read instructions before completing this form.

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
TEMPERATURE, WATER DEG. CENTIGRADE 00010 Z 0 0 INSTREAM MONITORING	SAMPLE MEASUREMENT	*****	*****	**	*****	*****	25.3	04	0	31 / 31	MODEL
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	30.5 DAILY MX	DEG. C.		SEE PERMIT	CK REQ.
TEMPERATURE, WATER DEG. CENTIGRADE 00010 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****	35.3	04	0	31 / 31	RCORDR
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	REPORT DAILY MX	DEG. C.		SEE PERMIT	CK REQ.
TEMP. DIFF. BETWEEN SAMP. & UPSTRM DEG.C 00016 1 S 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****	2.3	04	0	31 / 31	CALCTD
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	3.0 DAILY MX	DEG. C.		CONTINUOUS	CALCTD
PH 00400 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	**	7.2	*****	7.9	12	0	6 / 31	GRAB
	PERMIT REQUIREMENT	*****	*****	****	6.0 MINIMUM	*****	9.0 MAXIMUM	SU		WEEKLY	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	**	*****	6	6	19	0	1 / 31	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	30 MO AVG	100 DAILY MX	MG/L		MONTHLY	GRAB
OIL AND GREASE 00556 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	**	*****	<6	<6	19	0	1 / 31	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	15 MO AVG	20 DAILY MX	MG/L		MONTHLY	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	1584	03	*****	*****	*****	**	0	31 / 31	RCORDR
	PERMIT REQUIREMENT	*****	REPORT DAILY MX	MGD	*****	*****	*****	****		CONTINUOUS	RCORDR

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  
 J. Randy Douet  
 Site Vice President  
 TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

*Stephanie A. Howard*  
 Principal Environmental Engineer  
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE  
 423 843-6700  
 AREA CODE NUMBER  
 DATE  
 07 06 12  
 YEAR MO DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)  
 No closed mode operation. The following information is included in an attachment: 1. thermal compliance information 2. CCW data 3. veliger monitoring data

May 2007 DMR Attachment

**May 2007 Thermal Compliance Information**

May 1-31: The downstream temperature and temperature rate-of-change are based on measurements from Station 8, the "backup temperature monitor" located at the end of the mixing zone (TRM 483.4). The temperature rise is based on the increase in temperature from measurements at Station 14, located upstream of the plant (TRM 490.5), and measurements at Station 8 (TRM 483.4). Consistent with the permit, measurements reported for the downstream temperature and the temperature rise represent daily maximum 24-hour rolling averages; and, measurements reported of the temperature rate-of-change represent 1-hour averages. Measurements were used rather than the numerical modeling system because of relatively low river flows. TVA has learned as a result of the continuing studies performed under Part III.G. of the permit that under low flow conditions, adjustments may be needed in the formulation of numerical model to improve its accuracy. Until river flows increase or appropriate model adjustments can be made, the modeling system is considered "out of service".

**May 2007 CCW Data**

<b>CCW TRENCH</b>				
<b>Date/Time Collected</b>	<b>Extractable Petroleum Hydrocarbons</b>	<b>Analysis Date/Time</b>	<b>Analyst</b>	<b>Method</b>
05/02/2007 @ 1155	0.25 mg/L	05/05/2007 @ 1833	TSF	EPA 8015
<b>CCW CHANNEL</b>				
<b>Date/Time Collected</b>	<b>Extractable Petroleum Hydrocarbons</b>	<b>Analysis Date/Time</b>	<b>Analyst</b>	<b>Method</b>
05/02/2007 @ 1150	<0.10 mg/L	05/05/2007 @ 1823	TSF	EPA 8015

**May 2007 Veliger Monitoring Information**

Samples were collected on 5/2/07, 5/11/07, and 5/17/07, but have not been analyzed due to equipment issues. Veliger monitoring information will be submitted with the June DMR.

Name **TVA - SEQUOYAH NUCLEAR PLANT**  
 Address **P.O. BOX 2000**  
 (INTEROFFICE SB-2A)  
**SODDY - DAISY TN 37384**  
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**  
 Location **HAMILTON COUNTY**

MAJOR  
 (SUBR 01)

**TN0026450** **101 G**  
 PERMIT NUMBER DISCHARGE NUMBER

F - FINAL  
 DIFFUSER DISCHARGE  
 EFFLUENT

MONITORING PERIOD  
 From **07 05 01** To **07 05 31**

\*\*\* NO DISCHARGE  \*\*\*

ATTN: Stephanie A. Howard

NOTE: Read instructions before completing this form.

PARAMETER	SAMPLE MEASUREMENT / PERMIT REQUIREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
<b>CHLORINE, TOTAL RESIDUAL</b> 50060 1 0 0	SAMPLE MEASUREMENT	*****	*****	**	*****	0.018	0.034	19	0	25 / 31	GRAB
<b>EFFLUENT GROSS VALUE</b>	PERMIT REQUIREMENT	*****	*****	***	*****	<b>0.10 MO AVG</b>	<b>0.10 INST MAX</b>	MG/L		WEEK-DAYS	CALCTD
<b>TEMPERATURE - C, RATE OF CHANGE</b> 82234 1 0 0	SAMPLE MEASUREMENT	*****	1	62	*****	*****	*****	**	0	31 / 31	CALCTD
<b>EFFLUENT GROSS VALUE</b>	PERMIT REQUIREMENT	*****	<b>2 DAILY MX</b>	DEG C/HR	*****	*****	*****	***		CONTINUOUS	CALCTD
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  
**J. Randy Douet**  
 Site Vice President  
 TYPED OR PRINTED

I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

*Stephanie A. Howard*  
 Principal Environmental Engineer  
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE		DATE		
423	843-6700	07	06	12
AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)  
 The following injections occurred: 1. Biodetergent 73551 (max. calc. conc. was 0.017mg/L--limit 2.0mg/L) 2. MSW 101 (max. calc. conc. was 0.015mg/L--limit 0.2mg/L) 3. H-150M (max. calc. conc. was 0.038mg/L--limit 0.050mg/L) 4. H-150M (low detection level analytical method was <0.020mg/L--limit 0.050mg/L)

Name **TVA - SEQUOYAH NUCLEAR PLANT**  
 Address **P.O. BOX 2000**  
 (INTEROFFICE SB-2A)  
**SODDY - DAISY TN 37384**  
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**  
 Location **HAMILTON COUNTY**

MAJOR  
 (SUBR 01)  
 F - FINAL

**TN0026450** **101 T**  
 PERMIT NUMBER DISCHARGE NUMBER

BIOMONITORING FOR OUTFALL 101  
 EFFLUENT

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
07	05	01	07	05	31

From


To

\*\*\* NO DISCHARGE  \*\*\*

NOTE: Read instructions before completing this form.

ATTN: Stephanie A. Howard

PARAMETER	SAMPLE MEASUREMENT / PERMIT REQUIREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
IC25 STATRE 7DAY CHR CERIODAPHNIA	SAMPLE MEASUREMENT	*****	*****	**	Other	*****	*****	23			
TRP3B 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	45.2 MINIMUM	*****	*****	PERCENT		SEE PERMIT	COMPOS
IC25 STATRE 7DAY CHR PIMEPHALES	SAMPLE MEASUREMENT	*****	*****	**	Other	*****	*****	23			
TRP6C 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	45.2 MINIMUM	*****	*****	PERCENT		SEE PERMIT	COMPOS
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  J. Randy Douet Site Vice President  TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 Stephanie A. Howard Principal Environmental Engineer	TELEPHONE		DATE		
			423	843-6700	07	06	12
		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)  
 Toxicity was sampled 5/28/07 - 6/2/07. Final results from fathead minnows and daphnids that were exposed to SQN Outfall 101 samples have not been received from Environmental Testing Solutions, TVA's toxicity testing contract lab. The results and report will be submitted with the June DMR.

Name **TVA - SEQUOYAH NUCLEAR PLANT**  
 Address **P.O. BOX 2000**  
 (INTEROFFICE SB-2A)  
**SODDY - DAISY TN 37384**  
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**  
 Location **HAMILTON COUNTY**

**TN0026450**      **103 G**  
 PERMIT NUMBER      DISCHARGE NUMBER

F - FINAL  
 LOW VOL. WASTE TREATMENT POND  
 EFFLUENT

MONITORING PERIOD  
 YEAR MO DAY      YEAR MO DAY  
 From **07 05 01** To **07 05 31**

\*\*\* NO DISCHARGE  \*\*\*

ATTN: Stephanie A. Howard

NOTE: Read instructions before completing this form.

PARAMETER	SAMPLE MEASUREMENT / PERMIT REQUIREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
PH	SAMPLE MEASUREMENT	*****	*****	**	7.4	*****	8.9	12	0	13 / 31	GRAB
00400 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	**	6.0 MINIMUM	*****	9.0 MAXIMUM	SU		THREE/ WEEK	GRAB
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	45	82	26	*****	7	11	19	0	5 / 31	GRAB
00530 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	380 MO AVG	1250 DAILY MX	LBS/DY	*****	30 MO AVG	100 DAILY MX	MG/L		WEEKLY	GRAB
OIL AND GREASE	SAMPLE MEASUREMENT	<34	<42	26	*****	<6	<6	19	0	5 / 31	GRAB
00556 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	190 MO AVG	250 DAILY MX	LBS/DY	*****	15 MO AVG	20 DAILY MX	MG/L		WEEKLY	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	0.684	0.942	03	*****	*****	*****	**	0	31 / 31	TOTALZ
50050 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT MO AVG	REPORT DAILY MX	MGD	*****	*****	*****	**		SEE PERMIT	TOTALZ
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  J. Randy Douet Site Vice President  TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	<i>Stephanie A. Howard</i> Principal Environmental Engineer SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
			423	843-6700	07	06	12
			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

Name TVA - SEQUOYAH NUCLEAR PLANT  
Address P. O. BOX 2000  
(INTEROFFICE SB-2A)  
SODDY - DAISY TN 37384  
Facility TVA - SEQUOYAH NUCLEAR PLANT  
Location HAMILTON COUNTY

TN0026450 107 G  
PERMIT NUMBER DISCHARGE NUMBER

MONITORING PERIOD  
From 

YEAR	MO	DAY
07	05	01

 To 

YEAR	MO	DAY
07	05	31


F - FINAL  
METAL CLEANING WASTE POND  
EFFLUENT

\*\*\* NO DISCHARGE  \*\*\*

NOTE: Read instructions before completing this form.

ATTN: Stephanie A. Howard

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
PH	SAMPLE MEASUREMENT	*****	*****	**		*****		12			
00400 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	6.0 MINIMUM	*****	9.0 MAXIMUM	SU		DAILY	GRAB
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		19			
00530 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	30 DAILY MX	MG/L		DAILY	COMPOS
OIL AND GREASE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		19			
00556 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	15 DAILY MX	MG/L		DAILY	GRAB
PHOSPHORUS, TOTAL (AS P)	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		19			
00665 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	1.0 DAILY MX	MG/L		DAILY	COMPOS
COPPER, TOTAL (AS CU)	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		19			
01042 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	1.0 DAILY MX	MG/L		DAILY	COMPOS
IRON, TOTAL (AS FE)	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		19			
01045 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	1.0 DAILY MX	MG/L		DAILY	COMPOS
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT			03	*****	*****	*****	**			
50050 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT MO AVG	REPORT DAILY MX	MGD	*****	*****	*****	****		DAILY	CALCTD

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  J. Randy Douet Site Vice President  TYPED OR PRINTED	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 Stephanie A. Howard Principal Environmental Engineer SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

No Discharge this Period

Name **TVA - SEQUOYAH NUCLEAR PLANT**  
 Address **P. O. BOX 2000**  
 (INTEROFFICE SB-2A)  
**SODDY - DAISY TN 37384**  
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**  
 Location **HAMILTON COUNTY**

MAJOR (SUBR 01)  
 F - FINAL  
 RECYCLED COOLING WATER  
 EFFLUENT

**TN0026450** **110 G**  
 PERMIT NUMBER DISCHARGE NUMBER

MONITORING PERIOD						
YEAR	MO	DAY	YEAR	MO	DAY	
07	05	01	To	07	05	31

ATTN: Stephanie A. Howard

\*\*\* NO DISCHARGE  \*\*\*

NOTE: Read instructions before completing this form.

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION			NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
TEMPERATURE, WATER DEG. CENTIGRADE	SAMPLE MEASUREMENT	*****	*****	04	*****	*****				
00010 Z 0 0 INSTREAM MONITORING	PERMIT REQUIREMENT	*****	*****	DEG C	*****	*****	38.3 DAILY MX		DAILY	GRAB-4
PH	SAMPLE MEASUREMENT	*****	*****	**		*****				
00400 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	***	6.0 MINIMUM	*****	9.0 MAXIMUM		WEEKLY	GRAB
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	*****	*****	**	*****	*****				
00530 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	***	*****	*****	30 DAILY MX		DAILY	COMPOS
OIL AND GREASE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****				
00556 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	***	*****	*****	15 DAILY MX		DAILY	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT			03	*****	*****	*****			
50050 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT MO AVG	REPORT DAILY MX	MGD	*****	*****	*****		DAILY	CALCTD
CHLORINE, TOTAL RESIDUAL	SAMPLE MEASUREMENT	*****	*****	**	*****	*****				
50060 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	***	*****	*****	0.10 DAILY MX		WEEKLY	GRAB-4
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  
**J. Randy Douet**  
 Site Vice President  
 TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

*Stephanie A. Howard*  
 Principal Environmental Engineer  
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE		DATE		
423	843-6700	07	06	12
AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

No Discharge this Period



PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**  
 Address **P.O. BOX 2000**  
 (INTEROFFICE SB-2A)  
**SODDY - DAISY TN 37384**  
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**  
 Location **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
 DISCHARGE MONITORING REPORT (DMR)

MAJOR  
 (SUBR 01)  
 F - FINAL

Form Approved.  
 OMB No. 2040-0004

**TN0026450** **110 T**  
 PERMIT NUMBER DISCHARGE NUMBER

MONITORING PERIOD						
YEAR	MO	DAY	YEAR	MO	DAY	
07	05	01	To	07	05	31

RECYCLED COOLING WATER  
 EFFLUENT

\*\*\* NO DISCHARGE  \*\*\*

NOTE: Read instructions before completing this form.

ATTN: Stephanie A. Howard

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
IC25 STATRE 7DAY CHR CERIODAPHNIA	SAMPLE MEASUREMENT	*****	*****	**		*****	*****	23			
TRP3B 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	45.2 MINIMUM	*****	*****	PERCENT		SEMI ANNUAL	COMPOS
IC25 STATRE 7DAY CHR PIMEPHALES	SAMPLE MEASUREMENT	*****	*****	**		*****	*****	23			
TRP6C 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	45.2 MINIMUM	*****	*****	PERCENT		SEMI ANNUAL	COMPOS
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
J. Randy Douet Site Vice President		423	843-6700	07	06	12
TYPED OR PRINTED		AREA CODE	NUMBER	YEAR	MO	DAY

*Stephanie A. Howard*  
 Principal Environmental Engineer  
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

No Discharge this Period

Name **TVA - SEQUOYAH NUCLEAR PLANT**  
 Address **P. O. BOX 2000**  
 (INTEROFFICE SB-2A)  
**SODDY - DAISY TN 37384**  
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**  
 Location **HAMILTON COUNTY**

**TN0026450** **116 G**  
 PERMIT NUMBER DISCHARGE NUMBER

MONITORING PERIOD  
 From **07 05 01** To **07 05 31**

F - FINAL  
 BACKWASH  
 EFFLUENT

\*\*\* NO DISCHARGE  \*\*\*

ATTN: Stephanie A. Howard

NOTE: Read instructions before completing this form.

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
<b>DEBRIS, FLOATING (SEVERITY)</b>		*****	*****	**	*****	*****	0	9A	0	1 / 31	VISUAL
01345 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	<b>REPORT MO TOTAL</b>	PASS=0 FAIL=1		SEE PERMIT	VISUAL
<b>OIL AND GREASE VISUAL</b>		*****	0	94	*****	*****	*****	**	0	1 / 31	VISUAL
84066 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	<b>REPORT MO TOTAL</b>	YES=1 NO=0	*****	*****	*****	***		SEE PERMIT	VISUAL
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  
**J. Randy Douet**  
 Site Vice President  
 TYPED OR PRINTED

I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

*Stephanie A. Howard*  
 Principal Environmental Engineer  
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE: 423 843-6700  
 DATE: 07 06 12  
 AREA CODE NUMBER YEAR MO DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)  
 Operations performs visual inspections for floating debris and oil and grease during all backwashes.

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name TVA - SEQUOYAH NUCLEAR PLANT  
 Address P.O. BOX 2000  
(INTEROFFICE SB-2A)  
SODDY - DAISY TN 37384  
 Facility TVA - SEQUOYAH NUCLEAR PLANT  
 Location HAMILTON COUNTY

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
 DISCHARGE MONITORING REPORT (DMR)

MAJOR  
 (SUBR 01)  
 F - FINAL  
 BACKWASH  
 EFFLUENT

Form Approved.  
 OMB No. 2040-0004

TN0026450 117 G  
 PERMIT NUMBER DISCHARGE NUMBER

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
07	05	01	07	05	31

From

To

\*\*\* NO DISCHARGE  \*\*\*

NOTE: Read instructions before completing this form.

ATTN: Stephanie A. Howard

PARAMETER	X	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
DEBRIS, FLOATING (SEVERITY)	SAMPLE MEASUREMENT	*****	*****	**	*****	*****	0	9A	0	1 / 31	VISUAL
01345 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	***	*****	*****	REPORT MO TOTAL	PASS=0 FAIL=1		SEE PERMIT	VISUAL
OIL AND GREASE VISUAL	SAMPLE MEASUREMENT	*****	0	94	*****	*****	*****	**	0	1 / 31	VISUAL
84066 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	REPORT MO TOTAL	YES=1 NO=0	*****	*****	*****	***		SEE PERMIT	VISUAL
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  J. Randy Douet  Site Vice President  TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
		423	843-6700	07	06	12
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE	NUMBER	YEAR	MO	DAY

*Stephanie A. Howard*  
 Principal Environmental Engineer

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)  
 Operations performs visual inspections for floating debris and oil and grease during all backwashes.

Name TVA - SEQUOYAH NUCLEAR PLANT  
Address P.O. BOX 2000  
(INTEROFFICE SB-2A)  
SODDY - DAISY TN 37384  
Facility TVA - SEQUOYAH NUCLEAR PLANT  
Location HAMILTON COUNTY

**TN0026450**  
PERMIT NUMBER

**118 G**  
DISCHARGE NUMBER

F - FINAL  
WASTEWATER & STORM WATER  
EFFLUENT

MONITORING PERIOD

YEAR	MO	DAY	YEAR	MO	DAY
07	05	01	07	05	31

From To

\*\*\* NO DISCHARGE  \*\*\*

NOTE: Read instructions before completing this form.

ATTN: Stephanie A. Howard

PARAMETER	SAMPLE MEASUREMENT / PERMIT REQUIREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
OXYGEN, DISSOLVED (DO)	SAMPLE MEASUREMENT	*****	*****	**		*****	*****	19			
00300 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	***	2.0 DAILY MN	*****	*****	MG/L		TWICE/ WEEK	GRAB
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		19			
00530 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	***	*****	*****	100 DAILY MX	MG/L		TWICE/ WEEK	GRAB
SOLIDS, SETTLEABLE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		25			
00545 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	***	*****	*****	1.0 DAILY MX	ML/L		ONCE/ MONTH	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT			03	*****	*****	*****	**			
50050 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT MO AVG	REPORT DAILY MX	MGD	*****	*****	*****	*		ONCE/ BATCH	ESTIMA
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
J. Randy Douet Site Vice President		423	843-6700	07	06	12
TYPED OR PRINTED		AREA CODE	NUMBER	YEAR	MO	DAY

*Stephanie A. Howard*  
Principal Environmental Engineer  
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)  
During this reporting period, there has been no flow from the Dredge Pond other than that resulting from rainfall.

Name **TVA - SEQUOYAH NUCLEAR PLANT**  
 Address **P.O. BOX 2000**  
 (INTEROFFICE SB-2A)  
**SODDY - DAISY TN 37384**  
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**  
 Location **HAMILTON COUNTY**

**TN0026450** **103 G**  
 PERMIT NUMBER DISCHARGE NUMBER

F - FINAL  
 LOW VOL. WASTE TREATMENT POND  
 EFFLUENT


MONITORING PERIOD  
 From **07 04 01** To **07 04 30**

\*\*\* NO DISCHARGE  \*\*\*

ATTN: Stephanie A. Howard

NOTE: Read instructions before completing this form.

PARAMETER	SAMPLE MEASUREMENT / PERMIT REQUIREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
PH	SAMPLE MEASUREMENT	*****	*****	**	7.2	*****	8.6	12	0	13 / 30	GRAB
00400 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	**	6.0 MINIMUM	*****	9.0 MAXIMUM	SU		THREE/ WEEK	GRAB
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	77	89	26	*****	9	10	19	0	4 / 30	GRAB
00530 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	380 MO AVG	1250 DAILY MX	LBS/DY	*****	30 MO AVG	100 DAILY MX	MG/L		WEEKLY	GRAB
OIL AND GREASE	SAMPLE MEASUREMENT	<47	<58	26	*****	<6	<6	19	0	4 / 30	GRAB
00556 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	190 MO AVG	250 DAILY MX	LBS/DY	*****	15 MO AVG	20 DAILY MX	MG/L		WEEKLY	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	1.073	1.627	03	*****	*****	*****	**	0	30 / 30	TOTALZ
50050 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT MO AVG	REPORT DAILY MX	MGD	*****	*****	*****	**		SEE PERMIT	TOTALZ
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  J. Randy Douet Site Vice President  TYPED OR PRINTED	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 Stephanie A. Howard Principal Environmental Engineer	TELEPHONE		DATE		
			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)