

of the Act and to the rules, regulations, and orders of the Commission now or hereafter in effect; and is subject to the additional conditions specified or incorporated below:

2.C.(1) Maximum Power Level

Florida Power Corporation is authorized to operate the facility at a steady state reactor core power level not in excess of 2568 Megawatts (100 percent of rated core power level).

2.C.(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. **224**, are hereby incorporated in the license. Florida Power Corporation shall operate the facility in accordance with the Technical Specifications.

The Surveillance Requirements contained in the Appendix A Technical Specifications and listed below are not required to be performed immediately upon implementation of Amendment 149. The Surveillance Requirements shall be successfully demonstrated prior to the time and condition specified below for each.

- a) SR 3.3.8.2.b shall be successfully demonstrated prior to entering MODE 4 on the first plant start-up following Refuel Outage 9.
- b) SR 3.3.11.2, Function 2, shall be successfully demonstrated no later than 31 days following the implementation date of the ITS.
- c) SR3.3.17.1, Functions 1, 2, 6, 10, 14, & 17 shall be successfully demonstrated no later than 31 days following the implementation date of the ITS.
- d) SR3.3.17.2, Function 10 shall be successfully demonstrated prior to entering MODE 3 on the first plant start-up following Refuel Outage 9.
- e) SR 3.6.1.2 shall be successfully demonstrated prior to entering MODE 2 on the first plant start-up following Refuel Outage 9.
- f) SR 3.7.12.2 shall be successfully demonstrated prior to entering MODE 2 on the first plant start-up following Refuel Outage 9.
- g) SR 3.8.1.10 shall be successfully demonstrated prior to entering MODE 2 on the first plant start-up following Refuel Outage 9.
- h) SR 3.8.3.3 shall be successfully demonstrated prior to entering MODE 4 on the first plant start-up following Refuel Outage 9.

### 3.0 LIMITING CONDITION FOR OPERATION (LCO) APPLICABILITY

---

LCO 3.0.1 LCOs shall be met during the MODES or other specified conditions in the Applicability, except as provided in LCO 3.0.2, LCO 3.0.7 and LCO 3.0.8.

---

LCO 3.0.2 Upon discovery of a failure to meet an LCO, the Required Actions of the associated Conditions shall be met, except as provided in LCO 3.0.5 and 3.0.6.

If the LCO is met or is no longer applicable prior to expiration of the specified Completion Time(s), completion of the Required Action(s) is not required, unless otherwise stated.

---

LCO 3.0.3 When an LCO is not met, except as provided in the associated ACTIONS, and an associated ACTION is not met or provided, the unit shall be placed in a MODE or other specified condition in which the Specification is not applicable. Action shall be initiated within 1 hour to place the unit, as applicable, in:

- a. MODE 3 within 7 hours;
- b. MODE 4 within 13 hours; and
- c. MODE 5 within 37 hours.

Exceptions to this Specification are stated in the individual Specifications.

Where corrective measures are completed that permit operation in accordance with the LCO or ACTIONS, completion of the actions required by LCO 3.0.3 is not required.

LCO 3.0.3 is only applicable in MODES 1, 2, 3, and 4.

---

LCO 3.0.4 When an LCO is not met, entry into a MODE or other specified condition in the Applicability shall only be made:

- a. When the associated ACTIONS to be entered permit continued operation in the MODE or other specified condition in the Applicability for an unlimited period of time; or

(continued)

### 3.0 LCO APPLICABILITY

---

LCO 3.0.6  
(continued)                      When a support system's Required Action directs a supported system to be declared inoperable or directs entry into Conditions and Required Actions for a supported system, the applicable Conditions and Required Actions shall be entered in accordance with LCO 3.0.2.

---

LCO 3.0.7                              PHYSICS TESTS Exception LCOs (Specification 3.1.8 and 3.1.9) allow specified Technical Specifications (TS) requirements to be suspended to permit performance of special tests and operations. Unless otherwise specified, all other TS requirements remain unchanged. Compliance with PHYSICS TESTS Exception LCOs is optional. When a PHYSICS TEST Exception LCO is desired to be met but is not met, the ACTIONS of the PHYSICS TESTS Exception LCO shall be met. When a PHYSICS TEST Exception LCO is not desired to be met, entry into a MODE or other specified condition in the Applicability shall only be made in accordance with other applicable Specifications.

---

LCO 3.0.8                              When one or more required snubbers are unable to perform their associated support function(s), any affected supported LCO(s) are not required to be declared not met solely for this reason if risk is assessed and managed, and:

- a.     the snubbers not able to perform their associated support function(s) are associated with only one train or subsystem of a multiple train or subsystem supported system or are associated with a single train or subsystem supported system and are able to perform their associated support function within 72 hours; or
- b.     the snubbers not able to perform their associated support function(s) are associated with more than one train or subsystem of a multiple train or subsystem supported system and are able to perform their associated support function within 12 hours.

At the end of the specified period the required snubbers must be able to perform their associated support function(s), or the affected supported system LCO(s) shall be declared not met.

---