

**NRC Staff Supplemental Request for Information on GE's Partial Response to
ESBWR RAI 15.0-12 (MFN 06-173)**

In the Rev.3 of DCD 15.0-3 it is stated " Where an acceptance criterion is not specified in regulations and the SRP, then the criterion in the reference 1 LTR shall be used." The LTR NEDO-33175, Rev.1 has not been approved by the staff. Revise the DCD to reference only the regulations and the SRP. Any departures from the SRP should be justified in the DCD rather than referring to NEDO-33175.