

PRELIMINARY NOTIFICATION- REGION III

June 26, 2007

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE - PNO-III-07-008A

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region III staff on this date.

Facility

Point Beach Unit 1
Nuclear Management Company, LLC
Two Rivers, WI
Docket: 50-266
License: DPR-24

Licensee Emergency Classification

Notification of Unusual Event
 Alert
 Site Area Emergency
 General Emergency
 Not Applicable

SUBJECT: UPDATE TO UNIT 1 REACTOR SHUTDOWN

DESCRIPTION:

This preliminary notification supplements information in PNO-III-07-008, which documented the shutdown of the Point Beach Unit 1 reactor on June 15, 2007. At that time, the licensee was unable to resolve the issues associated with the turbine-driven auxiliary feedwater pump within the Technical Specification allowed outage time.

During the shutdown, the licensee repaired the turbine-driven auxiliary feedwater pump and restarted the reactor on June 23, 2007. Full power was achieved on June 24, 2007.

The NRC continues a Special Inspection of the issues associated with the turbine-driven auxiliary feedwater pump. Prior to the reactor restart, the team verified the adequacy of the licensee's corrective actions and the thoroughness of the extent of condition.

This information is current as of 7:30 a.m. on June 26, 2007.

The information in this preliminary notification has been reviewed with licensee management.

CONTACTS:

Jamnes Cameron Raymond Ng
630/829-9833 630/829-9618