

July 12, 2007

LICENSEE: Entergy Nuclear Operations, Inc.,

FACILITY: James A. FitzPatrick Nuclear Power Plant

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON JUNE 7, 2007, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND ENTERGY NUCLEAR OPERATIONS, INC., CONCERNING REQUESTS FOR ADDITIONAL INFORMATION PERTAINING TO THE JAMES A. FITZPATRICK NUCLEAR POWER PLANT, LICENSE RENEWAL APPLICATION

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of Entergy Nuclear Operations, Inc., held a telephone conference call on June 7, 2007, to discuss and clarify the staff's requests for additional information (RAIs) concerning the James A. FitzPatrick Nuclear Power Plant, license renewal application. The telephone conference call was useful in clarifying the intent of the staff's RAIs.

Enclosure 1 provides a listing of the participants and Enclosure 2 contains a listing of the RAIs discussed with the applicant, including a brief description on the status of the items.

The applicant had an opportunity to comment on this summary.

/RA/

Tommy Le, Sr. Project Manager
License Renewal Branch B
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-333

Enclosures:

1. List of Participants
2. List of Draft Requests for Additional Information

cc w/encls: See next page

July 12, 2007

LICENSEE: Entergy Nuclear Operations, Inc.,
FACILITY: James A. FitzPatrick Nuclear Power Plant
SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON JUNE 7, 2007,
BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND
ENTERGY NUCLEAR OPERATIONS, INC., CONCERNING REQUESTS FOR
ADDITIONAL INFORMATION PERTAINING TO THE JAMES A. FITZPATRICK
NUCLEAR POWER PLANT, LICENSE RENEWAL APPLICATION

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of Entergy Nuclear Operations, Inc., held a telephone conference call on June 7, 2007, to discuss and clarify the staff's requests for additional information (RAIs) concerning the James A. FitzPatrick Nuclear Power Plant, license renewal application. The telephone conference call was useful in clarifying the intent of the staff's RAIs.

Enclosure 1 provides a listing of the participants and Enclosure 2 contains a listing of the RAIs discussed with the applicant, including a brief description on the status of the items.

The applicant had an opportunity to comment on this summary.

/RA/

Tommy Le, Sr. Project Manager
License Renewal Branch B
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-333

Enclosures:

1. List of Participants
2. List of Draft Requests for
Additional Information

cc w/encls: See next page

DISTRIBUTION: See next page

ADAMS Accession No.: **ML071780356**

OFFICE	PM:RLRB:DLR	LA:DLR	PM:RLRB:DLR	BC:RLRB:DLR
NAME	TLe	SFiguroa	K. Howard	RAuluck
DATE	07/10/07	07/03/07	07/10/07	07/12/07

OFFICIAL RECORD COPY

**TELEPHONE CONFERENCE CALL
JAMES A. FITZPATRICK NUCLEAR POWER PLANT
LICENSE RENEWAL APPLICATION**

**LIST OF PARTICIPANTS
JUNE 7, 2007**

PARTICIPANTS

AFFILIATIONS

Tommy Le	US Nuclear Regulatory Commission (NRC)
Kent Howard	NRC
Roy Mathew	NRC
Jim Medoff	NRC
Rick Plasse	Entergy Nuclear Operations (ENO)
Mike Stroud	ENO
Don Fronanbarger	ENO
Alan Cox	ENO
Ted Ivey	ENO
Terry Herrmann	Structural Integrity Associates Inc.

**REQUEST FOR ADDITIONAL INFORMATION
JAMES A. FITZPATRICK NUCLEAR POWER PLANT
LICENSE RENEWAL APPLICATION**

JUNE 7, 2007

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of Entergy Nuclear Operations, Inc., held a telephone conference call on June 7, 2007, to discuss and clarify the following requests for additional information (RAIs) concerning the James A. FitzPatrick Nuclear Power Plant (JAFNPP) license renewal application (LRA).

RAI 4.3.1-1 (Questions submitted previously)

Section 4.3.1 of the License Renewal Application (LRA) addresses the effects fatigue may have on ASME Class I structures, systems, and components. The conference call was for clarification purposes of the previously submitted questions.

Discussion: The applicant agreed, that based on information contained within Structural Integrity Associates report SIR-07-084-NPS, Rev. 1, they would need to update the 60 year cycle projections, due to additional startup/shutdown transients not previously considered in report SIR-07-084-NPS, Rev. 1. The updated projections will be included in the future fatigue management activities described in LRA Commitment #20.

Memo to Entergy Nuclear Operations, Inc., from N. Le dated July 12, 2007

DISTRIBUTION:

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON JUNE 7, 2007,
BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND
ENTERGY NUCLEAR OPERATIONS, INC., CONCERNING REQUESTS FOR
ADDITIONAL INFORMATION PERTAINING TO THE JAMES A. FITZPATRICK
NUCLEAR POWER PLANT, LICENSE RENEWAL APPLICATION

HARD COPY:

DLR RF

E-MAIL:

PUBLIC

SSmith (srs3)

SDuraiswamy

RidsNrrDlr

RidsNrrDlrRlra

RidsNrrDlrRlrb

RidsNrrDlrRlrc

RidsNrrDlrReba

RidsNrrDlrRebb

RidsNrrDci

RidsNrrDra

RidsNrrDe

RidsNrrDeEemb

RidsNrrDeEeeb

RidsNrrDss

RidsOgcMailCenter

RidsNrrAdes

GHunegs, SRI

ECobey

RLaufer

JBoska

FitzPatrick Nuclear Power Plant

cc:

Mr. Gary J. Taylor
Chief Executive Officer
Entergy Operations, Inc.
1340 Echelon Parkway
Jackson, MS 39213

Mr. John T. Herron
Sr. VP and Chief Operating Officer
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. Peter T. Dietrich
Site Vice President
Entergy Nuclear Operations, Inc.
James A. FitzPatrick Nuclear Power Plant
P.O. Box 110
Lycoming, NY 13093

Mr. Kevin J. Mulligan
General Manager, Plant Operations
Entergy Nuclear Operations, Inc.
James A. FitzPatrick Nuclear Power Plant
P.O. Box 110
Lycoming, NY 13093

Mr. Oscar Limpas
Vice President Engineering
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. Christopher Schwartz
Vice President, Operations Support
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. John F. McCann
Director, Licensing
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Resident Inspector's Office
James A. FitzPatrick Nuclear Power Plant
U. S. Nuclear Regulatory Commission
P.O. Box 136
Lycoming, NY 13093

Ms. Charlene D. Faison
Manager, Licensing
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. Michael J. Colomb
Director of Oversight
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. David Wallace
Director, Nuclear Safety Assurance
Entergy Nuclear Operations, Inc.
James A. FitzPatrick Nuclear Power Plant
P.O. Box 110
Lycoming, NY 13093

Mr. James Costedio
Manager, Regulatory Compliance
Entergy Nuclear Operations, Inc.
James A. FitzPatrick Nuclear Power Plant
P.O. Box 110
Lycoming, NY 13093

Assistant General Counsel
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. Charles Donaldson, Esquire
Assistant Attorney General
New York Department of Law
120 Broadway
New York, NY 10271

FitzPatrick Nuclear Power Plant

-2-

cc:

cc:

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Mr. Gordon A. Cleffon
Nuclear Energy Institute
1776 I Street, NW, Suite 400
Washington, DC 20006-3708

Mr. Steven Lyman
Oswego County Administrator
46 East Bridge Street
Oswego, NY 13126

Mr. Peter R. Smith, President
New York State Energy, Research,
and Development Authority
17 Columbia Circle
Albany, NY 12203-6399

Mr. Paul Eddy
New York State Dept. of Public Service
3 Empire State Plaza
Albany, NY 12223-1350

Supervisor
Town of Scriba
Route 8, Box 382
Oswego, NY 13126

Mr. James H. Sniezek
BWR SRC Consultant
5486 Nithsdale Drive
Salisbury, MD 21801-2490

Mr. Michael D. Lyster
BWR SRC Consultant
5931 Barclay Lane
Naples, FL 34110-7306

Mr. Garrett D. Edwards
814 Waverly Road
Kennett Square, PA 19348

Mr. Rick Plasse
Project Manager, License Renewal
Entergy Nuclear Operations, Inc.
James A. FitzPatrick Nuclear Power Plant
P.O. Box 110
Lycoming, NY 13093