June 29, 2007

Mr. J. A. Stall
Senior Vice President, Nuclear and
Chief Nuclear Officer
Florida Power and Light Company
P.O. Box 14000
Juno Beach, Florida 33408-0420

SUBJECT: TURKEY POINT PLANT, UNIT 3 - WITHDRAWAL OF LICENSE AMENDMENT REQUEST REGARDING INOPERABLE ROD POSITION INDICATION (TAC NO. MD5569)

Dear Mr. Stall:

By letter dated May 17, 2007, Florida Power & Light Company applied for an exigent approval of a license amendment to the Turkey Point Unit 3 Facility Renewed Operating License No. DPR-31. The proposed change would have modified the facility technical specifications to allow the use of an alternate method of determining rod position for control rods M-6 and G-5 with inoperable Analog Rod Position Indicators (ARPIs). The ARPI for control rod M-6 in Control Bank C was declared inoperable in August 2006. The ARPI for control rod G-5 in Control Bank A was declared inoperable in April 2007. Subsequently, by letter dated June 13, 2007, you withdrew the amendment request.

The Commission has filed the enclosed Notice of Withdrawal of Application for Amendment to Facility Operating License with the Office of the Federal Register for publication..

Sincerely,

/RA/

Brenda Mozafari, Senior Project Manager
Project Licensing Branch II-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-250

Enclosure: Notice of Withdrawal

cc w/encl: See next page

June 29, 2007

Mr. J. A. Stall
Senior Vice President, Nuclear and
Chief Nuclear Officer
Florida Power and Light Company
P.O. Box 14000
Juno Beach, Florida 33408-0420

SUBJECT: TURKEY POINT PLANT, UNIT 3 - WITHDRAWAL OF LICENSE AMENDMENT REQUEST REGARDING INOPERABLE ROD POSITION INDICATION (TAC NO. MD5569)

Dear Mr. Stall:

By letter dated May 17, 2007, Florida Power & Light Company applied for an exigent approval of a license amendment to the Turkey Point Unit 3 Facility Renewed Operating License No. DPR-31. The proposed change would have modified the facility technical specifications to allow the use of an alternate method of determining rod position for control rods M-6 and G-5 with inoperable Analog Rod Position Indicators (ARPIs). The ARPI for control rod M-6 in Control Bank C was declared inoperable in August 2006. The ARPI for control rod G-5 in Control Bank A was declared inoperable in April 2007. Subsequently, by letter dated June 13, 2007, you withdrew the amendment request.

The Commission has filed the enclosed Notice of Withdrawal of Application for Amendment to Facility Operating License with the Office of the Federal Register for publication.

Sincerely,

/RA/

Brenda Mozafari, Senior Project Manager
Project Licensing Branch II-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-250

Enclosure: Notice of Withdrawal

cc w/encl: See next page

Distribution:
PUBLIC LPL2-2 R/F RidsNrrDorlLpl2-2 RidsNrrPMBMozafari
RidsNrrLABClayton RidsOgcRp RidsAcrsAcnwMailCenter
RidsRgn2MailCenter RidsNrrDorlDpr

ADAMS Accession No.: ML071830527 NRR-106

ORGANIZATION	LPL2-2/PM	LPL2-2/LA	LPL2-2/BC
NAME	BMozafari	BClayton	TBoyce
DATE	06/29/07	06/29/07	06/29/07

OFFICIAL RECORD COPY

cc:
Mr. William E. Webster
Vice President, Nuclear Operations
Florida Power & Light Company
P.O. Box 14000
Juno Beach, FL 33408-0420

M. S. Ross, Managing Attorney
Florida Power & Light Company
P.O. Box 14000
Juno Beach, FL 33408-0420

Marjan Mashhadi, Senior Attorney
Florida Power & Light Company
801 Pennsylvania Avenue, NW.
Suite 220
Washington, DC 20004

William Jefferson, Jr.
Site Vice President
Turkey Point Nuclear Plant
Florida Power and Light Company
9760 SW. 344th Street
Florida City, FL 33035

County Manager
Miami-Dade County
111 Northwest 1 Street, 29th Floor
Miami, Florida 33128

Senior Resident Inspector
Turkey Point Nuclear Plant
U.S. Nuclear Regulatory Commission
9762 SW. 344th Street
Florida City, Florida 33035

Mr. William A. Passetti, Chief
Department of Health
Bureau of Radiation Control
2020 Capital Circle, SE, Bin #C21
Tallahassee, Florida 32399-1741

Mr. Craig Fugate, Director
Division of Emergency Preparedness
Department of Community Affairs
2740 Centerview Drive
Tallahassee, Florida 32399-2100

Attorney General
Department of Legal Affairs
The Capitol
Tallahassee, Florida 32304

Michael O. Pearce
Plant General Manager
Turkey Point Nuclear Plant
Florida Power and Light Company
9760 SW. 344th Street
Florida City, FL 33035

James Connolly, Licensing Manager
Florida Power and Light Company
Turkey Point Nuclear Plant
9760 SW. 344th Street
Florida City, FL 33035

Becky Ferrare
Licensing Department Administrator
Florida Power and Light Company
Turkey Point Nuclear Plant
9760 SW. 344th Street
Florida City, FL 33035

Mark Warner, Vice President
Nuclear Operations Support
Florida Power and Light Company
P.O. Box 14000
Juno Beach, FL 33408-0420

Mr. Rajiv S. Kundalkar
Vice President - Nuclear Engineering
Florida Power & Light Company
P.O. Box 14000
Juno Beach, FL 33408-0420

7590-01-P

UNITED STATES NUCLEAR REGULATORY COMMISSION

FLORIDA POWER AND LIGHT COMPANY

DOCKET NO. 50-250

NOTICE OF WITHDRAWAL OF APPLICATION FOR

AMENDMENT TO FACILITY OPERATING LICENSE

The U.S. Nuclear Regulatory Commission (the Commission) has granted the request of Florida Power and Light Company (the licensee) to withdraw its May 17, 2007, application for proposed amendment to Facility Operating License No. DPR-31 for the Turkey Point Plant, Unit 3 , located in Dade County, Florida. .

The proposed amendment would have revised the Technical Specifications to allow the use of an alternate method of determining rod position for control rods M-6 and G-5 with inoperable Analog Rod Position Indicators. The Commission had previously issued a Notice of Consideration of Issuance of Amendment published in the FEDERAL REGISTER on May 24, 2007 (72 FR 29186). However, by letter dated June 13, 2007, the licensee withdrew the proposed change.

For further details with respect to this action, see the application for amendment dated May 17, 2007, and the licensee's letter dated June 13, 2007, which withdrew the application for license amendment. Documents may be examined, and/or copied for a fee, at the NRC's Public Document Room (PDR), located at One White Flint North, Public File Area O1 F21, 11555 Rockville Pike (first floor), Rockville, Maryland. Publicly available records will be accessible electronically from the Agencywide Documents Access and Management Systems (ADAMS) Public Electronic Reading Room on the internet at the NRC Web site, http://www.nrc.gov/reading-rm.html. Persons who do not have access to ADAMS or who

encounter problems in accessing the documents located in ADAMS should contact the NRC PDR Reference staff by telephone at 1-800-397-4209, or 301-415-4737 or by email to pdr@nrc.gov.

Dated at Rockville, Maryland, this 29th day of June 2007.

FOR THE NUCLEAR REGULATORY COMMISSION

/RA/

Brenda Mozafari, Senior Project Manager
Plant Licensing Branch II-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation