



***Thermal Evaluation
for Amendment 10
of
NUHOMS[®] System
61BTH and 32PTH1***

June 2007

Thermal Evaluation for 61BTH and 32PTH1 Systems

- ▶ ***Heat Loads and DSC Types***
- ▶ ***Analyzed Cases***
- ▶ ***Methodology and Computational Tools***
- ▶ ***Summary***

Thermal Evaluation 61BTH and 32PTH1

▶ 61BTH

- ◆ *Various Heat Load Configurations Based on Basket Type***
- ◆ *Maximum Total Heat Load 31.2 kW***
- ◆ *Maximum Heat per Fuel Assembly 0.54 kW***

▶ 32PTH1

- ◆ *Various Heat Load Configurations Based on Basket Type***
- ◆ *Maximum Total Heat Load 40.8 kW***
- ◆ *Maximum Heat per Fuel Assembly 1.30 kW***

Thermal Evaluation – Heat Loads and DSC Types

To Bound Thermal Evaluations:

▶ For 61BTH

- ◆ Maximum heat loads with borated aluminum neutron absorber are considered for basket plates to provide bounding maximum temperatures***

▶ For 32PTH1

- ◆ The bounding DSC length is considered for all analyses to maximize the heat flux***
- ◆ The lowest conductivity for neutron absorber plates is used in all models***

Thermal Evaluation – Analyzed Cases

Analyzed Cases are the same as those considered for 24PTH

▶ Storage in HSM or HSM-H Module

◆ Normal Conditions (Steady State)

- 0 to 100 °F ambient for 61BTH, 0 to 106 °F ambient for 32PTH1**
- Insolation from 10CFR71 for hot conditions**

◆ Off-Normal Conditions (Steady State)

- -40 to 117 °F ambient**
- Insolation from 10CFR71 for hot conditions**

◆ Hot Accident Conditions (Steady State) Only for 32PTH1

- 133 °F ambient**
- Insolation from 10CFR71 for hot conditions**

◆ Blocked Vent Accident Conditions (Transient)

- Initial conditions at 117 °F ambient with Insolation**

Thermal Evaluation – Analyzed Cases

Analyzed Cases are the same as those considered for 24PTH

- ▶ ***Transfer in OS197/OS197H or OS197FC-B for 61BTH***
 - ◆ ***Operations within Handling Building (Transient)***
 - ***Cask in vertical or horizontal orientation***
 - ***Ambient temperature at 120°F***
 - ***Determines time limit for transfer operations***
 - ◆ ***Normal and Off-Normal Conditions***
 - ***0 to 100°F ambient for normal conditions with Insolance***
 - ***-40 to 117°F ambient for off-normal conditions***
 - ***Steady state evaluation for heat loads ≤ 22.0 kW***
 - ***Transient evaluation for heat loads ≤ 31.2 kW for type 2 basket which determines time limit for transfer operations***

Thermal Evaluation – Analyzed Cases

Analyzed Cases are same as those considered for 24PTH

▶ *Transfer in OS200 / OS200FC for 32PTH1*

◆ *Operations within Handling Building (Transient)*

- Cask in vertical or horizontal orientation***
- Ambient temperature at 120 °F and 140 °F***
- Determines time limit for transfer operations***

◆ *Normal and Off-Normal Conditions*

- 0 to 106 °F ambient for normal conditions with Insolance***
- -40 to 117 °F ambient for off-normal conditions***
- Steady state evaluation for heat loads ≤ 24.0 kW***
- Steady state evaluation for heat loads ≤ 31.2 kW for type 1 basket***
- Transient evaluation for heat loads ≤ 31.2 kW for type 2 basket &***
- Transient evaluation for heat loads ≤ 40.8 kW for type 1 basket which determine time limit for transfer operations***

Thermal Evaluation – Analyzed Cases

Analyzed Cases are the same as those considered for 24PTH

▶ *Transfer for 61BTH and 32PTH1 – continued*

◆ *Accident Conditions*

- *Accidental Cask Drop***
 - *Loss of neutron shield***
 - *Loss of shade if used***
 - *Loss of air circulation if used***
- *Engulfing Fire***
- *Hot Accident Conditions for 133°F – only for 32PTH1***

Thermal Evaluation – Analyzed Cases

▶ Loading and Unloading Conditions

◆ Vacuum Drying (Steady State)

- Helium is used for blow-down**
- Annulus between DSC and Transfer Cask is filled with water**

◆ Reflooding

- Pool water is used to re-flood the DSC**
- Controlling of re-flood flow rate maintains the DSC cavity pressure below 20 psig**

Thermal Design Criteria for 61BTH and 32PTH1 systems are the same as those for 24PTH and NUHOMS® HD systems

Thermal Evaluation – Methodology & Tools

Analysis	Methodology	Previously Reviewed and Accepted by NRC
Exit / Bulk Air Temperature	Loss Coefficient Calculation Verified by Thermal Test	Standardized NUHOMS® UFSAR Appendix P, Section P.4.4.3 NUHOMS® HD SAR, Section 4.13
Storage Module HSM for 61BTH type 1 with \leq 22.0kW	ANSYS 2-D Models of HSM with 24.0 kW	Standardized NUHOMS® UFSAR, Section 8.1.3.1
Storage Module HSM-H	ANSYS 3-D Models of HSM-H Verified by Thermal Test	Standardized NUHOMS® UFSAR Appendix P, Section P.4.4.4 NUHOMS® HD SAR, Section 4.3.1.2 and 4.4.1.2
Transfer Cask OS197, OS197H, and OS197FC	SINDA/FLUINT™ and Thermal Desktop® 3-D Models	Standardized NUHOMS® UFSAR Appendix P, Section P.4.5.1 and P.4.5.2
Transfer Cask OS200 and OS200FC	SINDA/FLUINT™ and Thermal Desktop® 3-D Models	Standardized NUHOMS® UFSAR Appendix P, Section P.4.5.2 NUHOMS® HD SAR, Section 4.9 for Liquid Shield Convection Coefficients

Thermal Evaluation – Methodology & Tools

Analysis	Methodology	Previously Reviewed and Accepted by NRC
Intact Fuel Properties	<p>2-D model of Cross Section for Transverse Conductivity</p> <p>Cladding Area for Axial Conductivity</p> <p>Mass and Volume Average of Cladding and Pellets Materials for Specific Heat and Density</p>	<p>Standardized NUHOMS® UFSAR Appendix K, Section K.4.2 for BWR Fuel Assemblies</p> <p>Standardized NUHOMS® UFSAR Appendix P, Section P.4.8.1 and NUHOMS® HD SAR, Section 4.8 for PWR Fuel Assemblies</p>
Damaged Fuel Properties	Reduction of Transverse and Axial Conductivity based on Configuration	<p>Standardized NUHOMS® UFSAR Appendix K, Section K.4.8.1 for BWR Fuel Assemblies</p> <p>NUHOMS® HD SAR, Section 4.14.3 for PWR Fuel Assemblies</p>

Thermal Evaluation – Summary

- ▶ ***The methodologies to evaluate the thermal performance of 61BTH and 32PTH1 systems were reviewed by NRC in previous applications for amendment 8 (24PTH system) and NUHOMS® HD system***