Jonathan Rowley - LR Commitment Change

PA - LR

From: "Hamer, Mike" <mhamer@entergy.com>
To: "Jonathan Rowley" <JGR@nrc.gov>
Date: 05/21/2007 1:00 PM
Subject: LR Commitment Change
CC: "Michael Modes" <MCM@nrc.gov>, "Mannai, David" <dmannai@entergy.com>, "Dreyfuss, John" <jdreyfu@entergy.com>, "Metell, Mike" <hmetell@entergy.com>, "Lach, David J" <DLach@entergy.com>, "COX, ALAN B" <acox@entergy.com>

Jonathan,

To address a Region 1 issue, we would like to make a small change to LR Commitment 11 as follows (change underlined):

"The Fire Water System Program will be enhanced to specify that wall thickness evaluations of fire protection piping will be performed on system components using non-intrusive techniques (e.g., volumetric testing) to identify evidence of loss of material due to corrosion/MIC (bio-fouling). These inspections will be performed before the end of the current operating term and during the period of extended operation. Results of the initial evaluations will be used to determine the appropriate inspection interval to ensure aging effects are identified prior to loss of intended function."

The Entergy Commitment Tracking D-Base (LRS) has been updated to include this change.

We did not believe that a formal letter was necessary for this change as it only expands on the type of corrosion that we are monitoring to re-affirm to the Region that MIC is included in the Fire Water System Program procedures. Please call me if you have any changes.

Thanks,

Mike Hamer

Licensing Specialist

Entergy Nuclear Vermont Yankee

(802) 258-4226

Mail Envelope Properties (4651D01F.B75 : 7 : 2933)

Subject: LR Commitment Change
Creation Date 05/21/2007 12:57:48 PM
From: "Hamer, Mike" <mhamer@entergy.com>

Created By: mhamer@entergy.com

Recipients
nrc.gov
TWGWPO03.HQGWDO01
JGR (Jonathan Rowley)

nrc.gov
kp1_po.KP_DO
MCM CC (Michael Modes)

entergy.com
acox CC (ALAN B COX)
DLach CC (David J Lach)
hmetell CC (Mike Metell)
jdreyfu CC (John Dreyfuss)
dmannai CC (David Mannai)

Post Office	Route
TWGWPO03.HQGWDO01	nrc.gov
kp1_po.KP_DO	nrc.gov
	entergy.com

Files	Size	Date & Time
MESSAGE	1170	05/21/2007 12:57:48 PM
TEXT.htm	4208	
Mime.822	8343	

Options

Expiration Date:	None
Priority:	Standard
ReplyRequested:	No
Return Notification:	None
Concealed Subject:	No
Security:	Standard

Junk Mail Handling Evaluation Results

Message is eligible for Junk Mail handling
This message was not classified as Junk Mail

Junk Mail settings when this message was delivered
Junk Mail handling disabled by User
Junk Mail handling disabled by Administrator
Junk List is not enabled
Junk Mail using personal address books is not enabled
Block List is not enabled