

July 9, 2007

Mr. G. R. Peterson  
Vice President  
McGuire Nuclear Station  
Duke Power Company LLC  
12700 Hagers Ferry Road  
Huntersville, NC 28078

SUBJECT: MCGUIRE NUCLEAR STATION, UNITS 1 AND 2, RESPONSE TO GENERIC LETTER 2006-02, "GRID RELIABILITY AND THE IMPACT ON PLANT RISK AND THE OPERABILITY OF OFFSITE POWER" (TAC NOS. MD0997 AND MD0998)

Dear Mr. Peterson:

On February 1, 2006, the U.S. Nuclear Regulatory Commission (NRC) issued Generic Letter (GL) 2006-02, "Grid Reliability and the Impact on Plant Risk and the Operability of Offsite Power" (Agencywide Documents Access and Management System (ADAMS) Accession No. ML060180352), to all holders of operating licenses for nuclear power reactors except those who have permanently ceased operations and have certified that fuel has been removed from the reactor vessel.

GL 2006-02 notified licensees of the NRC staff's need for information in four areas as follows:

- (1) use of protocols between the nuclear power plant (NPP) and the transmission system operator (TSO), independent system operator (ISO), or reliability coordinator/authority (RC/RA) and the use of transmission load flow analysis tools (analysis tools) by TSOs to assist NPPs in monitoring grid conditions to determine the operability of offsite power systems under plant technical specifications (TSs). (The TSO, ISO, or RC/RA is responsible for preserving the reliability of the local transmission system. In this GL the term TSO is used to denote these entities);
- (2) use of NPP/TSO protocols and analysis tools by TSOs to assist NPPs in monitoring grid conditions for consideration in maintenance risk assessments;
- (3) offsite power restoration procedures in accordance with Section 2 of NRC Regulatory Guide (RG) 1.155, "Station Blackout;" and
- (4) losses of offsite power caused by grid failures at a frequency equal to or greater than once in 20 site-years in accordance with RG 1.155.

Subsequent to the GL, the NRC issued a Request For Additional Information (RAI), (ADAMS Accession No. ML063380308) regarding the resolution of GL 2006-02 to 63 of 65 holders of operating licenses for nuclear power reactors. The RAI requested licensees respond to questions in the following areas:

G. Peterson

- 2 -

- (1) Switchyard Minimum Voltage;
- (2) Loss of Real-Time Contingency Analysis (RTCA) Capability;
- (3) Verification of RTCA Predicted Post-Trip Voltage;
- (4) Identification of Applicable Single Contingencies;
- (5) Seasonal Variation in Grid Stress (reliability and Loss-of-offsite power (LOOP) Probability);
- (6) Interface With Transmission System Operator During Extended Plant Maintenance.

By letters dated March 30, 2006 (ADAMS Accession No. ML06102020168), and January 31, 2007 (ADAMS Accession No. ML070440175), you responded to the information request of GL 2006-02 and the subsequent RAI. Based on the information you provided, the staff has concluded that compliance is being maintained with NRC regulatory requirements governing electric power sources and associated personnel training and considers your response to GL 2006-02 complete.

If you have any questions, please contact me 301-415-1345.

Sincerely,

**/RA/**

John Stang, Senior Project Manager  
Plant Licensing Branch II-1  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket Nos. 50-369 and 50-370

cc: See next page

G. Peterson

- 2 -

July 9, 2007

- (3) Verification of RTCA Predicted Post-Trip Voltage;
- (4) Identification of Applicable Single Contingencies;
- (5) Seasonal Variation in Grid Stress (reliability and Loss-of-offsite power (LOOP) Probability);
- (6) Interface With Transmission System Operator During Extended Plant Maintenance.

By letters dated March 30, 2006 (ADAMS Accession No. ML06102020168), and January 31, 2007 (ADAMS Accession No. ML070440175), you responded to the information request of GL 2006-02 and the subsequent RAI. Based on the information you provided, the staff has concluded that compliance is being maintained with NRC regulatory requirements governing electric power sources and associated personnel training and considers your response to GL 2006-02 complete.

If you have any questions, please contact me 301-415-1345.

Sincerely,

**/RA/**

John Stang, Senior Project Manager  
 Plant Licensing Branch II-1  
 Division of Operating Reactor Licensing  
 Office of Nuclear Reactor Regulation

Docket Nos. 50-369 and 50-370

cc: See next page

Distribution:

|                        |                               |
|------------------------|-------------------------------|
| Public                 | RidsNrrDorlPl2-1(EMarinos)    |
| LPL2-1 R/F             | RidsNrrPMLJStang (hard copy)  |
| JRobinson, NRR         | RidsNrrDprPgcb                |
| RidsAcrsAcnwMailCenter | RidsNrrLAMO'Brien (hard copy) |
| RidsOgcRp              | RidsRgn2MailCenter(JMoorman)  |

Accession Number: ML071870152

|        |               |               |               |
|--------|---------------|---------------|---------------|
| OFFICE | NRR/LPL2-1/PM | NRR/LPL2-1/LA | NRR/LPL2-1/BC |
| NAME   | JStang:nc     | MO'Brien      | EMarinos      |
| DATE   | 7/9/07        | 7/9/07        | 7/9/07        |

**OFFICIAL RECORD COPY**

McGuire Nuclear Station, Units 1 & 2

cc:

Vice President  
McGuire Nuclear Station  
Duke Power Company, LLC  
12700 Hagers Ferry Road  
Huntersville, NC 28078

Associate General Counsel and Managing  
Attorney  
Duke Energy Carolinas, LLC  
526 South Church Street - EC07H  
Charlotte, North Carolina 28202

County Manager of Mecklenburg County  
720 E. Fourth St.  
Charlotte, NC 28202

Regulatory Compliance Manager  
Duke Energy Corporation  
McGuire Nuclear Site  
12700 Hagers Ferry Road  
Huntersville, NC 28078

Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
12700 Hagers Ferry Road  
Huntersville, NC 28078

Mecklenburg County  
Department of Environmental Protection  
700 N. Tryon St  
Charlotte, NC 28202

Vice President  
Customer Relations and Sales  
Westinghouse Electric Company  
6000 Fairview Road, 12th Floor  
Charlotte, NC 28210

NCEM REP Program Manager  
4713 Mail Service Center  
Raleigh, NC 27699-4713

Assistant Attorney General  
NC Department of Justice  
P.O. Box 629  
Raleigh, NC 27602

Manager  
Nuclear Regulatory Issues &  
Industry Affairs  
Duke Energy Corporation  
526 S. Church St.  
Mail Stop EC05P  
Charlotte, NC 28202

Division of Radiation Protection  
NC Dept of Environment, Health & Natural  
Resources  
3825 Barrett Dr.  
Raleigh, NC 27609-7721

Owners Group (NCEMC)  
Duke Energy Corporation  
4800 Concord Road  
York, SC 29745

Group Vice President, Nuclear Generation  
& Chief Nuclear Officer  
P.O. Box 1006-EC07H  
Charlotte, NC 28201-1006

Senior Counsel  
Duke Energy Carolinas, LLC  
526 South Church Street - EC07H  
Charlotte, NC 28202