

JUN 29 2007

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Serial No. 07-0263A
KPS/LIC/RR: R1
Docket No. 50-305
License No. DPR-43

DOMINION ENERGY KEWAUNEE, INC.
KEWAUNEE POWER STATION
WITHDRAWAL OF LICENSEE EVENT REPORT 2007-003-00

On April 4, 2007, Dominion Energy Kewaunee, Inc. (DEK) submitted Licensee Event Report (LER) 50-305/2007-003-00 pursuant to 10 CFR 50.73(a)(2)(i)(B) and 10 CFR 50.73(a)(2)(v)(B) and (D). This LER discussed emergency diesel generator (EDG) inoperability based on potential additional loads identified that could result in loading for both EDGs in excess of their 18 month Technical Specification (TS) surveillance loading of 2950 kilowatts (kW) based on engine rating curves at elevated temperatures.

An evaluation has been performed and it has been determined that actual loads were less than previously assumed. DEK has determined the station was not in a condition prohibited by the station's Technical Specifications or in a condition that could have prevented the fulfillment of the safety function of structures or systems. Therefore, DEK has concluded that the condition reported in the LER does not meet the criteria for reportability.

Based on the above, LER 50-305/2007-003-00 is hereby withdrawn.

If you have any questions or require additional information, please contact Mr. Thomas Breene at (920) 388-8599.

Very truly yours,



Leslie N. Hartz
Site Vice President, Kewaunee Power Station

Commitments made by this letter: NONE

IE22
NRR

cc: Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
2443 Warrenville Road
Suite 210
Lisle, IL 60532-4352

Ms. Margaret H. Chernoff
Project Manager
U.S. Nuclear Regulatory Commission
Mail Stop O-8G9A
Washington, D. C. 20555

NRC Senior Resident Inspector
Kewaunee Power Station