

**Preliminary Team Response to FAQ 06-0017  
on NUREG/CR-6850, EPRI TR-1011989**

Final Revision – 6/19/2007

Prepared by: S. Nowlen, B. Najafi, D. Funk, F. Joglar and M. Kazarians

**Summary of the FAQ**

FAQ 06-0017 suggests an alternate method for counting low voltage cabinets for the purposes of the high energy arc fault (HEAF) frequency analysis. The apparent intent is to assign a larger fraction of the total plant-wide HEAF fire frequency to medium voltage equipment and away from low voltage equipment arguing that this is more representative of the fire event data set. The FAQ as provided to the EPRI and RES teams is attached to this document for reference.<sup>1</sup>

**Summary of Team Response**

The team disagrees with the proposed resolution for switchgear and load centers, but agrees that some adjustment of the frequency of HEAF events between low- and medium-voltage panels may be appropriate. An alternate solution is offered that recalculates HEAF frequencies separately for low-voltage and for medium-voltage equipment. This should achieve the intent of the FAQ but the proposed team solution stands on a more defensible technical basis and maintains consistency with other aspects of the methodology.

**Detailed Response and Basis**

With respect to counting of electrical panels for the purposes of the HEAF fire events, the team disagrees with the proposed alternate counting method for load centers and low voltage switchgear. Our disagreement is based on the fact that no clear rules of application have been specified so that it may not be applied consistently by analysts. The counting approach also appears rather arbitrary. That said, the state of knowledge regarding HEAF fires continues to evolve. New insights developed since publication of the methodology do indicate that an adjustment of fire frequencies between low- and medium-voltage equipment is warranted.

The electrical power community has, over the past two years, gained significant knowledge about HEAFs. This increased awareness and knowledge base was driven by adoption of new arc flash protection requirements in NFPA 70E, *Standard for Electrical Safety Requirements for Employee Workplaces*. Discussions with experts close to the subject, including a member of the IEEE 1584 standards committee (*Guide for Performing Arc-Flash Hazards Calculations*) revealed that recorded events of HEAFs are

---

<sup>1</sup> Note that the original FAQ included a question on the counting and treatment of bus bar fires. This aspect of the question was deleted in a revision of the FAQ 017 and will be addressed in a separate FAQ. The bus bar question is not included in this response. The attached FAQ is the original version provided to the team for consideration.

actually dominated by incidences involving 480V gear. The experts confirm that the higher incidence of 480V events is partially attributable to the greater population of installed 480V equipment. However, other overlapping factors are also important:

- A majority of arc flash events are initiated by human error.
- Low voltage equipment is worked on/operated more frequently than medium voltage equipment.
- Workers have a more casual attitude when working on 480V gear, i.e., everyone knows that you will probably not get a second chance if you make a mistake working on medium voltage equipment but they tend to perceive 480V gear as less threatening. Additionally, it is more probable that 480V equipment will be worked “hot”; that is, worked on while the equipment is energized.
- Basic design attributes of medium voltage gear decrease the likelihood of initiating a sustained arcing fault. Key elements include insulated bus bars in lieu of open bus bar work, barrier protection, compartmentalization between phases, and increased creepage distances.
- Arcing faults do occur on 208V systems; however, sustained arcing faults at 208V are rare and difficult to reproduce.

With these observations in mind, the intent of the HEAF analysis (per Appendix M) is to capture “higher-consequence” events that may have a *substantive impact outside the cabinet of origin*. Other arc fault events (e.g., events that did not lead to an impact outside the originating panel) are already treated via the general electrical panel fire frequency and this treatment need not be adjusted. Only the “higher-consequence” events are under question here.

Another observation that is evident from the event records amassed by the IEEE standard groups is that, even though the general incidence of arc faults in low-voltage equipment may actually be higher, the fraction of such events leading to substantive impacts outside the initiating cabinet (i.e., higher-consequence events) is actually lower than for similar incidents in medium-voltage equipment. In essence, if a sustained arc fault occurs in a 4.16 kV switchgear, the fault will very likely have an impact beyond the limits of the panel. In contrast, an arc fault in a low voltage panel is more likely to remain confined to the panel and less likely to have impact beyond the panel. This rationale is supported by standardized arc flash calculations; equivalent stand off distances are typically greater for medium voltage equipment, given normal and customary overcurrent protection.

This contention is consistent with both the broader industry experience and with the specific nuclear industry experience as cataloged in Appendix M. That is, the frequency analysis included three events in medium-voltage equipment, and only ½ of an event (i.e., one uncertain event) for low-voltage equipment. This assessment included consideration of whether each reported event actually had impact outside the panel of origin. There are many other low-voltage panel fire events that appear to have involved some degree of arc-flash, but that also remained confined to the panel of origin.

The team’s proposed resolution to the underlying issue raised in the FAQ is to split fire ignition frequency Bin 16, HEAF, into two bins; namely, “16a – HEAF for low-voltage panels (480-1000V)” and “16b – HEAF for medium-voltage panels (greater than 1000V).” For each bin, the method of panel counting would then stand unchanged (i.e., count vertical sections). Given the split into two bins, the counting method, and hence the fire frequency apportioning process, need to be self-consistent within each of the two new bins, but there is no longer any cross-over between the low- and medium-voltage equipment. This also maintains consistency with the counting method for general thermal fires (i.e., the non-HEAF panel fires that must also be treated) which is also a highly desirable feature so that analyst need not maintain two separate population counts for the same set of fire ignition sources.

The net result is a re-partitioning of the “higher-consequence” HEAF events between low and medium-to-high voltage equipment in accordance with the event data. The revised fire frequencies for these two new bins are as follows:

16a: HEAF for Low- Voltage Panels (480 – 1000 V)	
Mean	4.8E-04
Variance	1.4E-03
5%	1.6E-05
50%	2.0E-04
95%	1.5E-03

16b: HEAF for Medium-Voltage Panels (greater than 1000 V)	
Mean	1.4E-03
Variance	1.2E-02
5%	3.8E-05
50%	6.2E-04
95%	4.1E-03

**FAQ Number      06-0017, Revision 0**

Plant:	<u>Oconee</u>	FAQ # <u>06-0017 Rev. 0</u>
Submittal Date:	<u>11-6-06</u>	
Licensee Contact:	<u>Kiang Zee</u>	Tele/email _____
NRC Contact:	_____	Tele/email _____

Distribution: Check all that apply (*NEI Internal Use*)

- FPWG**  **RIRWG**  **NSSS OG**  **NFPA 805 TF**

**Subject:** Clarification/enhancement of Ignition Source counting guidance for High Energy Arcing Faults (HEAF) in NUREG/CR-6850, supporting NFPA-805 Fire PRA application.

**Interpretation of guidance?** Yes

**Proposed new guidance not in NEI 04-02?** Yes

**Details:**

**NEI 04-02 Guidance needing interpretation (include section, paragraph number, and line number):**

New attachment on interpretation issues

**Circumstances requiring guidance interpretation or new guidance:**

The guidance provided in NUREG/CR-6850 for Task 6, Fire Ignition Frequency (Section 6.5.6, Bin 16), states:

Bin 16 – High-Energy Arcing Faults (Plant-Wide Components): High-energy arcing faults are associated with switchgear and load centers. Switchyard transformers and isolation phase buses are not part of this bin. For this bin, similar to electrical cabinets, the vertical segments of the switchgear and load centers should be counted. Additionally, to cover potential explosive failure of oil filled transformers (those transformers that are associated with 4.16 or 6.9kV switchgear and lower voltage load centers) may be included in vertical segment counts of the switchgear.

Pilot discussions and benchmarking of NUREG/CR-6850 for Task 6, Fire Ignition Frequency, has shown inconsistency in the treatment of High Energy Arcing Faults (Bin 16). Strict interpretation of the guidance is that the HEAF count should mimic the electrical cabinet counts for switchgear and load centers. The application of such a counting method is expected to result in reported High Energy Arcing Fault (HEAF) frequency values for an individual plant being inconsistent with industry experience. The industry experience and consequently the HEAF frequency is based on 3 events occurring on medium voltage switchgears and ½ event occurring on a 480 VAC Load Center. Because of the relative numbers of switchgears and load centers at an individual plant, it is expected that the resultant frequency may be inappropriately skewed. There is a concern that the occurrence of a HEAF frequency distribution that departs significantly from the 3 to ½ ratio would cause results to be challenged.

There is also a question of counting Bus Ducts. The specific guidance for NUREG/CR-6850, Task 6 does not require any counting of bus ducts. However, the discussion in Appendix M of NUREG/CR 6850 notes that bus ducts are susceptible to HEAF events.

There is a need to resolve these issues to prevent future rework and to reduce burden associated with uncertainty treatment.

**Detail contentious points if licensee and NRC have not reached agreement**


This topic has impact on the NFPA-805 pilots, non-pilots and other users of NUREG/CR-6850.

**Potentially relevant existing FAQ numbers:**

This guidance is specific to the characterization of electrical cabinets for Bin 16 HEAF determination. The characterization and counting of electrical cabinets for Bin 15 determination is addressed by FAQ 06-0016.


**Response Section**

It is proposed that the existing guidance in NUREG/CR-6850 that recommends counting based on segments be modified. Since industry experience shows that the medium voltage switchgears are most likely to experience this event, it is proposed that each low voltage switchgear (usually referred to as load centers or unit substations) operating at 440 Vac or higher be counted as a single unit regardless of the number of vertical sections or segments. This treatment would ensure that the majority of the HEAF frequency is allocated to the medium voltage switchgears. When performing detailed fire modeling, the HEAF should be distributed by vertical section of the applicable load center.



Medium Voltage Switchgear

9 Breakers and Sections  
Count = 9 for Bin 16



Low Voltage Switchgear  $\geq$  440 Vac  
(Load Centers or Unit Substations)

16 Breakers in 4 Sections  
Count = 1 for Bin 16

In the case of bus ducts a possible approach is to count them as being equivalent to an individual section, regardless of length. However, there have been no reported occurrences of a HEAF event originating at (on) a bus duct and the most likely location for such an event if it were to occur is at the termination point of the bus duct at the switchgear and/or transformer. The treatment of a HEAF event at these terminal ends would already bound the anticipated consequences. Because the specific guidance for NUREG 6850 Task 6 does not require the counting of bus ducts, a HEAF event originating at (on) a bus duct has not occurred, and the potential consequences if it were to occur at its terminal end is bounded by the HEAF treatment of that terminal, it is proposed that no specific treatment or counting of bus ducts be required for fire frequency determination.

**Basis:**

The existing guidance in NUREG/CR-6850 is based on industry data which has only been provided with fidelity adequate to support plant level ignition frequencies for HEAFs. Although the guidance does address the data, it leaves room for variability that can create issues with PRA quality. It is important that the ignition frequency results be of sufficient quality to support not only NFPA-805 transition but also the more broad scope of regulatory inspection and enforcement issues.

The guidance proposed will provide more consistency when determining plant specific electrical cabinet ignition frequencies while working within the bounds of the exiting data provided by the NUREG. This should facilitate the review and acceptability of the results.