

Shutdown CEA Insertion Limits
3.1.6

3.1 REACTIVITY CONTROL SYSTEMS

3.1.6 Shutdown Control Element Assembly (CEA) Insertion Limits

LCO 3.1.6 All shutdown CEAs shall be withdrawn to ≥ 147.75 inches.

APPLICABILITY: MODE 1.
MODE 2 with any regulating CEA not fully inserted.

-----NOTE-----
This LCO is not applicable while performing SR 3.1.5.3.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One shutdown CEA not within limit.	A.1 Restore shutdown CEA to within limit.	2 hours
B. Required Action and associated Completion Time not met.	B.1 Be in MODE 3.	6 hours

Shutdown CEA Insertion Limits
3.1.6

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.1.6.1	Verify each shutdown CEA is withdrawn ≥ 147.75 inches.	12 hours