

**From:** Christian Jacobs  
**To:** chmeden@WCNOC.com  
**Date:** 7/11/2007 9:39:57 AM  
**Subject:** Fwd: RE: CR Fire CDF Value Clarification

Charlie,  
Please provide response to Bob Palla's email (attached).  
Chris

Christian Jacobs  
Environmental Project Manager  
Division of License Renewal  
U.S. Nuclear Regulatory Commission  
301-415-3874  
O-12D11  
cjj@nrc.gov

**Mail Envelope Properties** (4694DDAD.950 : 2 : 36278)

**Subject:** Fwd: RE: CR Fire CDF Value Clarification  
**Creation Date** 7/11/2007 9:39:57 AM  
**From:** Christian Jacobs

**Created By:** [cjj@nrc.gov](mailto:cjj@nrc.gov)

<b>Recipients</b>	<b>Action</b>	<b>Date &amp; Time</b>
WCNOC.com AM chmeden	Transferred	7/11/2007 9:40:35

<b>Post Office</b>	<b>Delivered</b>	<b>Route</b>
		WCNOC.com

<b>Files</b>	<b>Size</b>	<b>Date &amp; Time</b>
MESSAGE Mail	218	7/11/2007 9:39:57 AM

**Options**

**Auto Delete:** No  
**Expiration Date:** None  
**Notify Recipients:** Yes  
**Priority:** Standard  
**ReplyRequested:** No  
**Return Notification:**  
 Send Mail Receipt when Undeliverable

**Concealed Subject:** No  
**Security:** Standard

**To Be Delivered:** Immediate  
**Status Tracking:** Delivered & Opened

**From:** Robert Palla  
**To:** Christian Jacobs  
**Date:** 7/11/2007 9:27:23 AM  
**Subject:** Fwd: RE: CR Fire CDF Value Clarification

Chris - In addition to confirming that the IPEEE control room fire CDF reported in the ER was incorrect (should have been  $1.43E-6$  rather than  $6.31E-5$ ), it would be a good idea to have WCNOG also confirm that the value of  $2.22E-6$  reported in the ER for the fire re-analysis is correct, and that the CR fire frequency actually increased in the fire re-analysis (the ER states that it decreased, but that statement appears incorrect given the correction to the IPEEE value). Bob

>>> Christian Jacobs 07/11/2007 8:41 AM >>>

Bob,

See attached email from Charlie (Wolf Creek). He confirmed that they used the incorrect number, and that you and Bruce are correct in using the IPEEE number. I'm thinking I can just add the email to ADAMS and this will resolve the issue. I don't think I need to ask them to send this info under oath and affirmation since the 1.43 number is something that we can reference from IPEEE. Do you agree?  
Chris

Christian Jacobs  
Environmental Project Manager  
Division of License Renewal  
U.S. Nuclear Regulatory Commission  
301-415-3874  
O-12D11  
cjj@nrc.gov

**CC:** Bmrowca@isinc.com