

From: Christian Jacobs
To: chmeden@WCNOC.com
Date: 7/11/2007 1:28:45 PM
Subject: Re: CR Fire CDF Value Clarification

Thanks Charlie.
I'm forwarding to Bob, but this issue should be considered closed now.
Chris

Christian Jacobs
Environmental Project Manager
Division of License Renewal
U.S. Nuclear Regulatory Commission
301-415-3874
O-12D11
cjj@nrc.gov
>>> "Medenci Charlie M" <chmeden@WCNOC.com> 07/11/07 10:45 AM >>>

The value of 2.22E-6 reported in the ER for the fire re-analysis is correct,
and that the CR fire CDF actually increased in the fire re-analysis from 1.43E-06 to 2.22E-06.

--

-----Original Message-----
From: Robert Palla [mailto:RLP3@nrc.gov]
Sent: Wednesday, July 11, 2007 8:27 AM
To: Christian Jacobs
Cc: bmrowca@isliinc.com
Subject: Fwd: RE: CR Fire CDF Value Clarification

Chris - In addition to confirming that the IPEEE control room fire CDF reported in the ER was incorrect (should have been 1.43E-6 rather than 6.31E-5), it would be a good idea to have WCNOC also confirm that the value of 2.22E-6 reported in the ER for the fire re-analysis is correct, and that the CR fire frequency actually increased in the fire re-analysis (the ER states that it decreased, but that statement appears incorrect given the correction to the IPEEE value). Bob

>>> Christian Jacobs 07/11/2007 8:41 AM >>>
Bob,
See attached email from Charlie (Wolf Creek). He confirmed that they used the incorrect number, and that you and Bruce are correct in using the IPEEE number. I'm thinking I can just add the email to ADAMS and this will resolve the issue. I don't think I need to ask them to send this info under oath and affirmation since the 1.43 number is something that we can reference from IPEEE. Do you agree?
Chris

Christian Jacobs
Environmental Project Manager
Division of License Renewal
U.S. Nuclear Regulatory Commission

301-415-3874
O-12D11
cjj@nrc.gov

Mail Envelope Properties (4695134D.423 : 2 : 36278)

Subject: Re: CR Fire CDF Value Clarification
Creation Date 7/11/2007 1:28:45 PM
From: Christian Jacobs

Created By: cjj@nrc.gov

Recipients	Action	Date & Time
WCNOC.com PM chmeden	Transferred	7/11/2007 1:29:10

Post Office	Delivered	Route
		WCNOC.com

Files	Size	Date & Time
MESSAGE	1777	7/11/2007 1:28:45 PM

Options

Auto Delete: No
Expiration Date: None
Notify Recipients: Yes
Priority: Standard
ReplyRequested: No
Return Notification:
 Send Mail Receipt when Undeliverable

Concealed Subject: No
Security: Standard

To Be Delivered: Immediate
Status Tracking: Delivered & Opened