



JUL 16 2007

L-PI-07-060
10 CFR 50.90

U S Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Prairie Island Nuclear Generating Plant Units 1 and 2
Dockets 50-282 and 50-306
License Nos. DPR-42 and DPR-60

Supplement to License Amendment Request (LAR) for Miscellaneous Technical Specification (TS) Improvements (TAC Nos. MD 2822 and MD 2823)

References: 1. License Amendment Request (LAR) for Miscellaneous Technical Specification (TS) Improvements, dated August 14, 2006, Accession Number ML062270248.

In Reference 1, Nuclear Management Company, LLC (NMC) submitted an LAR to revise the TS for the Prairie Island Nuclear Generating Plant (PINGP) Units 1 and 2 to make miscellaneous improvements, including changes in TS 3.7.10, "Control Room Special Ventilation System (CRSVS)". NMC submits this supplement in accordance with the provisions of 10 CFR 50.90.

The Reference 1 LAR proposed to revise Surveillance Requirement (SR) 3.7.10.4 to verify each CRSVS train delivers the required flow "through the associated CRSVS filter". The purpose of this SR is to verify performance of the fans. The NRC Staff expressed concern that the use of singular "filter" may not adequately describe the system design since each CRSVS train consists of a prefilter, high efficiency particulate air filter and an activated charcoal adsorber section. For clarification, this supplement revises the proposed SR to verify each CRSVS train delivers the required flow "through the associated CRSVS filters". The specific TS wording is provided in Enclosure 1 to this letter.

The supplemental information provided in this letter does not impact the conclusions of the Determination of No Significant Hazards Consideration and Environmental Assessment presented in the August 14, 2006 submittal.

In accordance with 10 CFR 50.91, NMC is notifying the State of Minnesota of this LAR by transmitting a copy of this letter and enclosure to the designated State Official.

Please address any comments or questions regarding this LAR supplement to Mr. Dale Vincent, P.E., at 1-651-388-1121.

Summary of Commitments

This letter contains no new commitments and no revisions to existing commitments.

I declare under penalty of perjury that the foregoing is true and correct.

Executed on **JUL 16 2007**



Michael D. Wadley
Site Vice President, Prairie Island Nuclear Generating Plant Units 1 and 2
Nuclear Management Company, LLC

Enclosures (1)

cc: Administrator, Region III, USNRC
Project Manager, Prairie Island, USNRC
Resident Inspector, Prairie Island, USNRC
State of Minnesota

Enclosure 1

Proposed Technical Specification Changes (final)

Technical Specification Page

3.7.10-3

1 page follows

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.7.10.1	Operate each CRSVS train \geq 15 minutes.	31 days
SR 3.7.10.2	Perform required CRSVS filter testing in accordance with the Ventilation Filter Testing Program (VFTP).	In accordance with VFTP
SR 3.7.10.3	Verify each CRSVS train actuates on an actual or simulated actuation signal.	24 months
SR 3.7.10.4	Verify each CRSVS train in the Emergency Mode delivers 3600 to 4400 cfm through the associated CRSVS filters.	24 months on a STAGGERED TEST BASIS