NORTH INTAKE STRUCTURE

SOUTH INTAKE STRUCTURE

INTAKE STRUCTURE & SERVICE BLDG. TURBINE BLDG.

TURBINE BLDG. AUXILIARY BLDG.

WATER TREATMENT LAB & OFFICE

WEST PENET. RM.

UNIT 2 HALLWAY

MACHINE SHOP AREA

"36"

"36"

DRAWING NOTES

1. THE Q-LIST INFORMATION PROVIDED ON THIS DRAWING IDENTIFIES THE SAFETY RELATED PRESSURE BOUNDARIES (SR-PB).EQUIPMENT WITHIN THE BOUNDARIES IS ALSO CLASSIFIED SR-PB, AS A MINIMUM. THE NUCLEIS MASTER EQUIPMENT LIST MUST BE USED FOR IDENTIFYING SPECIFIC OR ADDITIONAL SAFETY CLASSIFICATION INFORMATION, INCLUDING COMPONENT CLASSIFICATIONS AND ASSOCIATED REQUIREMENTS.
2. PIPING WHICH CONTINUES BEYOND THE SAFETY RELATED (SR-PB) BOUNDARY INDICATED ON THIS DRAWING, IS CLASSIFIED SR-PB UP TO AND INCLUDING THE FIRST SEISMIC ANCHOR.
3. ——— DENOTES SAFETY RELATED PRESSURE BOUNDARIES.
   ——— DENOTES NON-SAFETY RELATED PRESSURE BOUNDARIES.

GENERAL NOTES

FOR GENERAL NOTES SEE DRAWING 60746SH0001

THIS DRAWING CREATED FROM OPERATIONS DRAWING 60746SH0003 (OM-479), REV. 8, DATED 02-09-1994 & PID 60519SH0003 (M-479), REV. 8, DATED 02-09-1994.

REV	DATE	DESCRIPTION	DWN	DSGN	DE	IR	APPROVED
33	2/23/04	AS BUILT DCN 60746SH0003-2011SH0001 ES199900681-000	EAM RKL	—	—	—	RKL
34	5/18/05	AS BUILT DCN 60746SH0003-2010SH0001 ES200200256-000	WHR RKL	—	—	—	RKL
35	12/13/05	AS BUILT DCN 60746SH0003-2013SH0001 ES200300671-000	WHR RKL	—	—	—	RKL
36	1/31/07	AS BUILT DCN 60746SH0003-2012SH0001 ES200400583-000	KWJ	—	—	—	KWJ

PLANT WATER & AIR SERVICE SYSTEM

CALVERT CLIFFS NUCLEAR POWER PLANT
ENGINEERING SERVICES DEPARTMENT
CALVERT CLIFFS UNIT 1&2 — SIZE E — CAT C

SCALE: NONE — VENDOR DWG. NO. — OM-479SH0003 — REV. 36

DWG. NO. 60746SH0003