LETDOWN HEAT EXCHANGER NO.21

NO.21

NO.22

COMP. COOL HEAT EXCHANGERS

CEDM COOLERS

"24"

STM. GEN. NO.21 SUP. COOLERS

STM. GEN. NO.22 SUP. COOLERS

REACTOR VESSEL SUPPORT COOLERS (ALL VALVES OUTSIDE PRIMARY SHIELDING)

SHUTDOWN COOLING HEAT EXCHANGERS

DRAWING NOTES

1. THE Q-LIST INFORMATION PROVIDED ON THIS DRAWING IDENTIFIES THE SAFETY RELATED PRESSURE BOUNDARIES (SR-PB). EQUIPMENT WITHIN THE BOUNDARIES IS ALSO CLASSIFIED SR-PB, AS A MINIMUM. THE NUCLEIS MASTER EQUIPMENT LIST MUST BE USED FOR IDENTIFYING SPECIFIC OR ADDITIONAL SAFETY CLASSIFICATION INFORMATION, INCLUDING COMPONENT CLASSIFICATIONS AND ASSOCIATED REQUIREMENTS.
2. PIPING WHICH CONTINUES BEYOND THE SAFETY RELATED (SR-PB) BOUNDARY INDICATED ON THIS DRAWING, IS CLASSIFIED SR-PB UP TO AND INCLUDING THE FIRST SEISMIC ANCHOR.
3. ——— DENOTES SAFETY RELATED PRESSURE BOUNDARIES.
   ——— DENOTES NON-SAFETY RELATED PRESSURE BOUNDARIES.

THIS DRAWING CREATED FROM OPERATIONS DRAWING 62-710-E SH.2(OM-452), REV.11, DATED 02-11-1993 & P&ID 62-235-E SH.2(M-452), REV. 15, DATED 04-19-1994.

REV	DATE	DESCRIPTION	DWN	DSGN	DE	IR	APPROVED
20		AS BUILT INFO ONLY ESP ES199500003-000					
21		AS BUILT DCN 62710SH0002-2001SH0001 ES199601279-000					
22	2/17/00	AS BUILT INFO ONLY ES199901270-000	MVR	—	—	—	JM
23	11/5/02	AS BUILT INFO ONLY ES200000603-000	WHR KWJ	—	—	—	KWJ
24	1/6/03	AS BUILT INFO ONLY ES200000920-000	KWJ	—	—	—	

COMPONENT COOLING SYSTEM

CALVERT CLIFFS NUCLEAR POWER PLANT
ENGINEERING SERVICES DEPARTMENT
CALVERT CLIFFS UNIT 2

SIZE: E | CAT.: C

SCALE: NONE | VENDOR DWG. NO.: OM-452SH0002 | REV.: 24

INTER NO.: 15562.DGN | CCNPP DWG. NO.: 62710SH0002

LAST USER: W.BODNAR
LAST DATE WORKED: 1/6/03

D-12