BLOWDOWN TANK NO.21

BLOWDOWN HEAT EXCHANGER NO.21

BLOWDOWN HEAT EXCHANGER NO.22

BLOW DOWN FILTERS

BLOWDOWN ION EXCHANGER NO.21

BLOWDOWN ION EXCHANGER NO.22

SPENT RESIN TRANSFER PUMP NO.21

SPENT RESIN DRUMMING STATION

"34"

"34"

GENERAL NOTES

1. FOR P.&I.D. LEGEND SEE DRAWING 6750-M-80, (BGE NO. 60263).
2. FOR INSTRUMENT DATA SHEETS SEE 6750-M-500, (BGE NO. 92401 THRU 92422).
3. FOR EQUIPMENT LIST SEE 6750-M-603, BGE NO. 92722).
4. EQUIPMENT NUMBERS FOR UNIT NO.1 ARE PREFIXED BY THE NUMBER 1 (EXAMPLE NO.11, 12, 13, ETC.). EQUIPMENT NUMBERS FOR UNIT NO.2 ARE PREFIXED BY THE NUMBER 2 (EXAMPLE NO.21, 22, 23, ETC.). EQUIPMENT COMMON TO BOTH UNITS IS NUMBERED AS FOR UNIT NO.1.
5. "RAD TRIP OVERRIDE" POSITION ON HAND SWITCH PERMITS OPENING CV WITH HIGH RADIATION SIGNAL PRESENT FROM RE-4014.
6. FOR DEFINITION OF LINE DESIGNATIONS SEE PIPING CLASS AND SUMMARY SHEETS 6750-M-600, 601.
7. THE Q-LIST INFORMATION PROVIDED ON THIS DRAWING IDENTIFIES THE SAFETY RELATED PRESSURE BOUNDARIES (SR-PB). EQUIPMENT WITHIN THE BOUNDARIES IS ALSO CLASSIFIED SR-PB, AS A MINIMUM. THE NUCLEIS MASTER EQUIPMENT LIST MUST BE USED FOR IDENTIFYING SPECIFIC OR ADDITIONAL SAFETY CLASSIFICATION INFORMATION, INCLUDING COMPONENT CLASSIFICATIONS AND ASSOCIATED REQUIREMENTS.
8. PIPING WHICH CONTINUES BEYOND THE SAFETY RELATED (SR-PB) BOUNDARY INDICATED ON THIS DRAWING, IS CLASSIFIED SR-PB UP TO AND INCLUDING THE FIRST SEISMIC ANCHOR.
9. ——— DENOTES SAFETY RELATED PRESSURE BOUNDARIES.
   ——— DENOTES NON-SAFETY RELATED PRESSURE BOUNDARIES.
10. INSTALLATION OF S/G BLOWDOWN ION EXCHANGER FILTERS IS OPTIONAL PER ES1995017Z3

THIS DRAWING CREATED FROM OPERATIONS DRAWING 62-749-E (OM-465), REV. 21, DATED 06-10-1993 & P&ID 62-760-E (M-465), REV. 20, DATED 08-09-1993.

REV	DATE	DESCRIPTION	DWN	DSGN	DE	IR	APPROVED
33	4/7/03	AS BUILT DCN 62749-2002SH0001, SH0002 ES200100849-001 & 62749-2001SH0001, SH0002 ES200100847-001	WHR KWJ	–	–	–	KWJ
34	[illegible]	ADMIN CHANGE ONLY	[illegible]	–	–	–	[illegible]

STEAM GENERATOR BLOWDOWN RECOVERY SYSTEM

CALVERT CLIFFS NUCLEAR POWER PLANT
ENGINEERING SERVICES DEPARTMENT
CALVERT CLIFFS UNIT 2 — SIZE E — CAT. C

SCALE: NONE — VENDOR DWG. NO. OM-465 — REV. 34
INTER NO. 17762.DGN — DWG. NO. 62749

LEVELS 1234567891111111111222222222233333333344444444455555555556666 / 0123456789012345678901234567890123456789012345678901234567890123 — LAST USER: BILL RICE — LAST DATE WORKED: 12/18/03