

ENCLOSURE 1

REVISED PAGE OF FACILITY OPERATING LICENSE NOS. NPF-4 AND NPF-7

DOCKET NOS. 50-338 AND 50-339

NORTH ANNA POWER STATION, UNIT NOS. 1 AND 2

Replace the following pages of Facility Operating License Nos. NPF-4 and NPF-7. The revised pages are identified by the date of the letter issuing these pages and contain marginal lines indicating the areas of change.

License NPF-4

REMOVE

Page 7

INSERT

Page 7

License NPF-7

REMOVE

Page 7

INSERT

Page 7

G. Mitigation Strategy

Develop and maintain strategies for addressing large fires and explosions and that include the following key areas:

- (1) Fire fighting response strategy with the following elements:
 - a. Pre-defined coordinated fire response strategy and guidance
 - b. Assessment of mutual aid fire fighting assets
 - c. Designated staging areas for equipment and materials
 - d. Command and control
 - e. Training of response personnel

- (2) Operations to mitigate fuel damage considering the following:
 - a. Protection and use of personnel assets
 - b. Communications
 - c. Minimizing fire spread
 - d. Procedures for implementing integrated fire response strategy
 - e. Identification of readily-available pre-staged equipment
 - f. Training on integrated fire response strategy
 - g. Spent fuel pool mitigation measures

- (3) Actions to minimize release to include consideration of:
 - a. Water spray scrubbing
 - b. Dose to onsite responders

H. This renewed license is effective as of the date of issuance and shall expire at midnight on April 1, 2038.

FOR THE NUCLEAR REGULATORY COMMISSION

original signed by:

Samuel J. Collins, Director
Office of Nuclear Reactor Regulation

Attachments:

1. Appendix A, Technical Specifications
2. Appendix B, Environmental Protection Plan

Date of Issuance: March 20, 2003

Renewed License No. NPF-4
Revised by letter dated August 2, 2007

G. Mitigation Strategy

Develop and maintain strategies for addressing large fires and explosions and that include the following key areas:

- (1) Fire fighting response strategy with the following elements:
 - a. Pre-defined coordinated fire response strategy and guidance
 - b. Assessment of mutual aid fire fighting assets
 - c. Designated staging areas for equipment and materials
 - d. Command and control
 - e. Training of response personnel

- (2) Operations to mitigate fuel damage considering the following:
 - a. Protection and use of personnel assets
 - b. Communications
 - c. Minimizing fire spread
 - d. Procedures for implementing integrated fire response strategy
 - e. Identification of readily-available pre-staged equipment
 - f. Training on integrated fire response strategy
 - g. Spent fuel pool mitigation measures

- (3) Actions to minimize release to include consideration of:
 - a. Water spray scrubbing
 - b. Dose to onsite responders

H. This renewed license is effective as of the date of issuance and shall expire at midnight on April 21, 2040.

FOR THE NUCLEAR REGULATORY COMMISSION

original signed by:

Samuel J. Collins, Director
Office of Nuclear Reactor Regulation

Attachments:

1. Appendix A, Technical Specifications
2. Appendix B, Environmental Protection Plan

Date of Issuance: March 20, 2003

Renewed License No. NPF-7
Revised by letter dated August 2, 2007