

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.7.3.1	Verify cooling water temperature supplied to the plant from the CSCS pond is $\leq 101.25^{\circ}\text{F}$.	24 hours
SR 3.7.3.2	Verify sediment level is ≤ 1.5 ft in the intake flume and the CSCS pond.	24 months
SR 3.7.3.3	Verify CSCS pond bottom elevation is ≤ 686.5 ft.	24 months