

# Module 5B – Phase 2 details continued

Steps 2.5-2.9

## Step 2.5 – Fire growth and damage scenarios and 2<sup>nd</sup> check on SSD

- In this step the process of defining specific fire scenarios continues
  - Fire growth and damage scenarios are defined for each combination of a fire ignition source and FDS that we are retaining
- This step includes identification of scenario specific target sets
- Once fire growth and damage scenarios are defined, we re-assess survival of the designated safe shutdown path in context of each fire ignition source

# Step 2.5 – Targets and Target sets

- We need to identify targets by both location and function
  - We want to know where important targets are with as much accuracy as possible
  - Don't start routing cables, but use information made available by licensee
- We are going to group individual targets into target sets
  - Sets correspond to fire ignition source/FDS combination

## Step 2.5 – target sets (cont.)

- We would like to know what function is lost given failure of each target
  - If possible, tie specific targets to specific functions
- As a minimum it is sufficient to know what functions are lost given loss of the entire target set
  - In practice, this is how we use information
  - The greater level of detail is still good information to record as available

# Step 2.5 – Target sets

- If location information is lacking or uncertain, targets are placed in worst plausible location
  - Lacking any other information, assume all target cables are in the tray right above the source
- Some rules of thumb may be applied
  - Power cables tend to be routed in upper trays
  - Control cables are often in lower or mid-level trays
  - Instrument cables usually in the lowest trays
- When uncertain, err towards conservatism, but use available information

## Task 2.5.1 – Fire growth and damage scenarios

- Define fire growth and damage scenarios for each combination of an unscreened fire source and FDS
  - Define the fire ignition source
  - Define the applicable path for fire growth at each applicable FDS
  - Define the associated target set

# Defining FDS1 Scenarios

Start with a fire ignition source and ask yourself:

- Q: Was this fire ignition source retained based on targets within the zone of influence?
  - If yes then we may have an FDS1 scenario to consider
- Or Q: Was this fire ignition source retained based only on potential for hot gas layer damage (not plume/radiant damage)?
  - If yes, then there will be no FDS1 for that source – might still have FDS2 or FDS3

# Defining FDS1 scenarios

- FDS1 involves localized damage near the fire source
- Focus especially on vertical fire spread/damage
- Define logical path of fire spread if one exists
  - Allow fire to grow vertically (i.e. through a stack of cable trays or up a vertical cable riser)
  - Do not postulate substantial horizontal spread – that is for FDS2
- Note: we will cover specifics on cable fire spread rules in Module 6

# Defining FDS1 scenarios

- FDS1 Target set can include any of the following:
  - Targets within zone of influence for radiant heating
    - The ball in the ball and column
  - Targets above the fire source
    - Targets within the column in the ball and column
    - Targets within the range of upward fire spread
      - e.g., Lowest tray in a stack may be within zone of influence, but target may be a tray ignited due to additional fire spread
  - Unprotected cables and components
  - Cable and components “protected” by a highly degraded localized fire barrier system
    - e.g. a non-functional or missing cable wrap

# Defining FDS2 fire scenarios

Start with a fire ignition source:

- Define fire spread path if needed
  - If fire source alone is enough to cause damaging hot gas layer, then fire spread is moot – just worry about the source
  - If fire ignition source is not enough to cause hot gas layer damage without fire spreading, then you must postulate a path of fire spread
    - This time we allow for more extensive horizontal fire spread
    - Define the fire spread path
    - Define in particular, maximum extent of fire possible

# Defining FDS2 scenarios (cont.)

- Define the fire damage target set
  - FDS2 involves widespread damage within the fire area
  - Look for HGL potential and timing
    - If HGL not reasonable or simply takes too long to be risk important (high likelihood of suppression), then FDS2 target set may be limited by extent of direct fire spread
    - If HGL is possible in reasonable time, any and all exposed cables and components anywhere in the room may be damaged
  - Note: anything damaged in the corresponding FDS1 scenario for the same fire source (if you developed one) is also included in the FDS2 target set

# Defining FDS2 scenarios (cont.)

- Cables protected by a moderately degraded localized cable or component fire barrier element are also damaged in FDS2
  - These targets will likely drive the overall damage time
- Cables and components protected by a one-hour fire barrier wrap may be damaged in FDS2 even if wrap is not degraded
  - Recall - we did not credit a one-hour wrap alone in Step 2.1 as meeting independence criteria!
  - Any scenario that requires one hour is likely to be relatively low risk, so a “scoping” calculation may be appropriate:
    - Check product of manual non-suppression probability at one hour and refined fire frequency
  - If non-degraded automatic fire suppression system is present, don't chase these scenarios – they will be low risk
- Don't try to fail a non-degraded three hour wrap

# Defining FDS3 fire scenarios

- The FDS3 scenarios depend a bit on what your finding is – two cases:
  - Finding is not fire confinement
  - Finding is fire confinement

# FDS3 – Fire is not fire confinement

- The inspected area is always the exposing fire area, an adjacent area is the exposed area
- For this case, something in the fire area that you are inspecting is degraded, but it is not the fire area boundaries
- In developing FDS3 scenarios, we are presuming that a fire in the inspected compartment might be more likely to spread to an adjacent compartment
  - i.e., it might go unsuppressed for a longer time than one would normally expect

# If you Step 2.2 didn't drop FDS3 you must have found:

- A somewhat weak barrier to at least one adjacent fire area
- Questionable or non-existent fixed suppression capability in exposing compartment
- Unique and exposed targets in at least one adjoining room
- The potential for fire that can directly challenge the fire barrier

It's not hard to develop a fire scenario out of that situation!

# FDS3 – Finding is fire confinement

- In this case you have a degraded fire barrier between two fire areas
- Fire spreading through the degraded barrier IS the scenario
- Fire might go in either direction, so you may have two scenarios
  - Hopefully the screening question would eliminate fire in one direction or the other
  - e.g., if one fire area has a non-degraded fire sprinkler system, that should not be the exposing fire compartment

# For both cases: Defining the FDS3 scenarios

- Focus only on fire getting through the barrier(s) that did not meet the screening rules
  - The degraded barrier or the one that didn't give at least 2 hours
  - If endurance rating is greater than 20 minutes, but less than 2 hours, your targets in the exposed room should be right near the barrier
  - If it's less than 20 minutes or barrier is degraded, could be anywhere
- Focus on the fire ignition sources that could challenge the fire barrier
  - High hazard
  - Near barrier
  - Direct path for fire spread through the barrier

# Defining FDS3 scenarios (cont.)

- Again start with a fire ignition source
  - Pick the worst one and let it represent the whole set
  - You want one that can spread fire or fire effects into the adjacent area
    - If you applied the screening rules in step 2.2 correctly, then you should have verified at least one such source existed
- Characterize the conditions that lead to fire spread into the adjacent fire area
  - Fire spread along cable trays that penetrate the barrier is typical
  - If you have a high hazard fire source (e.g., oil-filled transformer or other large oil source), it could be a hot gas layer impacting both fire areas

# Defining the FDS3 Scenarios

- Target set should be pretty obvious
- Minimum set:
  - Everything within reach of your fire source (zone of influence)
  - Everything in the path of fire spread
  - The unique targets in the exposed fire area
- Maximum:
  - Everything in both fire areas
- Use your judgment, pick a target set

## Task 2.5.2 – Plant damage state

- For each fire growth and damage scenario determine what failure of the target set means in the context of plant safe shutdown response
  - What functions/systems are lost
  - What is the nature of the failure
    - loss of function, spurious operation, operable but with loss of indication....
  - What is function/system state given failure
    - System may be running
    - Valve may be open or closed...
- Recall – it is enough to know this answer for the set as a whole, but nice if you can tie functions to specific targets

# Plant Damage State (cont.)

- Also define what survives
  - What functions/systems can be credited for safe shutdown
  - Assume systems are lost unless it can be verified with reasonable confidence that the system will survive
- Identify any manual actions needed to support safe shutdown
  - Focus on actions outside the main control room or complex actions within the main control room

# Task 2.5.3 – Re-check SSD path

- In this task the independence of the designated SSD path is re-assessed based on the specific plant damage states
  - Plant damage state will define whether or not the SSD path is available – no more rules/questions needed
- You look at the worst case target set for each fire ignition source
  - If the SSD path survives in this worst case, the CCDP from Step 2.1 can be applied to all scenarios for that fire ignition source

# Step 2.5.4 – Screening check

- In this Step, the SSD path is credited, or not credited, on a fire ignition source specific basis
  - The CCDP for each ignition source is either 1.0 or  $CCDP_{2.1}$  depending on results of 2.5.3
- If the SSD path is lost for at least one fire scenario for each fire ignition source, then this step is skipped
  - You can only improve screening result if you are going to credit the SSD path for at least one fire ignition source
- If you decided earlier that  $CCDP_{2.1}$  applied in general, then there is no benefit to be gained

# Screening check:

$$\Delta CDF_{2.5} = DF \times \sum \{(F_{\text{source}})_i \times (CCDP_{2.1})_i\}$$

- Sum over all fire ignition sources (i=1 to n)

<b>Table A1.8 - Phase 2, Screening Step 5 Quantitative Screening Criteria</b>		
<b>Assigned Finding Category (from Step 1.1):</b>	<b><math>\Delta CDF_{2.5}</math> screening value</b>	
	<b>Moderate Degradation</b>	<b>High Degradation</b>
Fire Prevention and Administrative Controls	N/A	1E-6
Fixed Fire Protection Systems	1E-5	
Fire Confinement	1E-5 <sup>1</sup>	
Localized Cable or Component Protection	1E-5 <sup>1</sup>	
Post-fire SSD	1E-6	

<sup>1</sup> This entry applies to both 'Moderate A' and 'Moderate B' findings against a fire barrier.

# Step 2.6: Damage time

- Analyze the fire growth and damage time for each fire scenario
- Separate “rules” for FDS1, 2, and 3
  - Task 2.6.1 – FDS1
  - Task 2.6.2 – FDS2
  - Task 2.6.3 – FDS3
- FDS1 and FDS2 require use of Fire Dynamics tools (plume, radiant, hot gas layer)
- Fire spread rules also apply

# Task 2.6.1: FDS1

- If all elements of the target set are within the zone of influence then plume/radiant heating is enough – don't need fire spread
  - Calculate plume temperature or radiant flux level at target location
  - Pick damage time off the lookup table
- If target tray is outside the zone of influence, fire spread upwards through the cable tray stack is needed
  - Use the cable tray fire growth rules
  - Details in Attachment 3

# Fire spread in a tray stack:

- If the first tray is within zone of influence it can be ignited and fire will spread
- Fire spreads according to the following rules:
  - Time to ignition of first tray: use plume temperature at height of tray and time to damage/ignition table
    - Call this  $t_1$
    - Note: Early versions of guidance say use five minutes but this was an error and has been corrected in latest version
  - Second tray 4 minutes later (elapsed time  $t_1 + 4$  min.)
  - Third tray 3 minutes later (elapsed time  $t_1 + 7$  min.)
  - Fourth tray 2 minutes later (elapsed time  $t_1 + 9$  min.)
  - Fifth tray 1 minute later (elapsed time  $t_1 + 10$  min.)
  - Higher trays 1 minute later (elapsed time  $t_1 + 11$  min.)
- Cables fail when the tray ignites

## Task 2.6.2 – FDS2 damage time

- Begin with the corresponding FDS1 damage time if there is one for the fire ignition source
  - FDS2 can't be any faster
- Then you need to go after the hot gas layer, and consider time to damage for degraded raceway fire barriers

# FDS2 damage time (cont.)

- Targets with no barrier protection are damaged based on exposure temperature and time to damage table
- If FDS2 target sets include cables or components within a moderately degraded local fire barrier system, add in the remaining performance time given the degradation to get total damage time

# HGL Damage

Check the HGL temperature for the fire ignition source alone (using FDT) – if this is enough:

- If HGL temperature reaches the damage threshold in less than 30 minutes, then ignition source alone is enough to cause damage
  - You may have checked this during screening back in Step 2.4
- First check HGL temperature at 10 minutes
  - If this value exceeds the damage threshold, record the value, use the lookup table to get damage time at this temperature
  - Total damage time is 10 minutes plus time from lookup table
- If HGL temperature reaches damage threshold in greater than 10 minutes:
  - Damage time is time to reach damage threshold plus damage time from lookup table at the threshold temperature (e.g., 28 minutes)

# HGL Damage (2)

If fire spread to cables is needed to get a damaging HGL process requires use of both FDT and the Cable Tray Fire Spread spreadsheets:

- FDT HGL tool: Determine HRR needed to get a damaging HGL in the room of interest
  - Input room parameters (dimensions, ventilation)
  - Adjust HRR for the fire
  - Look at HGL temperature at 10 minutes
  - Compare to damage threshold temperature
  - Iterate until HGL temperature equals or exceeds damage

# HGL Damage (3)

- Fire ignition source contributes to total HRR, so we subtract that out from required HRR
  - The HRR difference needs to come from the cables
- Have to figure out time for fire to spread far enough to create a fire this big:
  - Cable trays are assumed to burn at  $400 \text{ kW/m}^2$
  - We can calculate square feet of tray required to get fire size needed
  - Determine if there are enough trays in the area to get a fire this big
    - If no, then the FDS2 scenario is not credible
    - If yes, need to estimate time for fire to grow this far using cable tray fire spread rules
    - Spreadsheet provided for this case

# HGL Damage (4)

- If there are enough trays, use the Cable Tray spreadsheet:
  - Calculate time to ignition of first tray
    - Using plume temperature at tray and damage time lookup table (as in a FDS1 scenario)
  - Spreadsheet Input: total HRR needed, ignition source HRR, time to ignition of first tray, characteristics of cable trays
  - Manipulate “time of interest” until damaging HGL is indicated
- That puts us at the damage threshold
  - Assume pre-heating of the exposed cables during time of fire growth so no additional time to damage
  - Time to develop damaging HGL is take as time to damage exposed cables for fire propagation scenarios
  - Fire barrier wrapped cables get additional time –  $\frac{1}{2}$  nominal fire barrier rating (after applying penalty for any degradation)

# HGL Damage (5)

- Don't try to get too fine an answer:
  - HRR steps of 50 kW
  - Time steps of integer minutes

## Task 2.6.3: FDS3 Scenarios

- If you have a highly degraded fire barrier as the finding, combine the two areas and treat just like FDS2
  - Inter-area barrier gets no credit
  - Credit only one fire suppression system if more than one exist (i.e. you might have had some coverage in both rooms)

## Task 2.6.3 – FDS3 (cont.)

- If you have a moderate degraded barrier or a finding that is not fire confinement
  - Use one scenario to estimate time for direct fire spread to and through the fire barrier
    - Estimate time for fire to spread to the barrier
  - Use one scenario (same or other) to try to get a damaging hot gas layer
    - Use FDS2 approach to estimate time to reach a damaging hot gas layer in the exposing fire area
  - Pick the shorter time from these two cases to represent all FDS3 fires
    - This is the fire growth time

## Task 2.6.3 – FDS3 (cont.)

- Moderate degradation fire confinement or non-confinement finding (cont.)
  - Add in the fire endurance time allowed for the degraded barrier (e.g., 65% or 35% of nominal if barrier is degraded or full credit if not)
  - If targets in exposed fire area have raceway fire barrier protection, add in the fire endurance rating of this protection

Total fire damage time = (fire growth time) + (endurance of degraded barrier) + (endurance of raceway barriers is present in exposed compartment)

## Step 2.7 – PNS analysis

- This step estimates the probability that suppression fails in the time available before our target set is damaged
- Credit is given to both fixed fire suppression and manual fire suppression
- For the fire brigade, we also need the detection time
  - Detection activates the human response including the fire fighting response

# Task 2.7.1 – Fire detection time

Detection time is a race – shortest time wins:

- Fixed fire detection is estimated using FDT spreadsheet
- Other means of detection
  - Continuous fire watch –  $t_{\text{detection}} = 0$
  - Roving fire watch –  $t_{\text{detection}} = \frac{1}{2}$  repeat time
  - General plant personnel:
    - $t_{\text{detection}} = 5$  minutes if continuously manned
    - $t_{\text{detection}} = 15$  if not manned
  - Maximum detection time is 15 minutes

## Task 2.7.2 – Fixed fire suppression

- Activation of a fixed fire suppression system that is considered effective against the fire ignition source is assumed to end the fire scenario
  - Inspector decides on effectiveness
  - Timing needs to be determined
- Skip this task is no fixed suppression of installed system is highly degraded

# Fixed suppression (cont)

- Use the fire detector tool in FDT to estimate actuation time
  - Sprinkler head is just a fancy heat detector
- Watch for cross-zoned actuation logic
  - Common for auto gas systems and deluge
  - Need to ensure both zones actuate so analyze the detector that is farthest from the fire source
- Add discharge delay time for gaseous systems
  - Minimum of 30 seconds, 1-2 minutes is typical

# Fixed suppression (cont)

- If the suppression system is moderately degraded:
  - If issue is head spacing – model as found
  - If some subset of discharge heads are degraded then assume nearest head won't work, second closest head is modeled
  - If system does not provide adequate coverage to some fire ignition sources, credit only for those source that are covered

# Fixed suppression (cont)

- If fixed system is manually actuated
  - Estimate the fire brigade response time
  - If fire brigade members have full decision making authority to actuate system, allow additional 2 minutes for assessment and decision making process
  - If fire brigade must get authorization (e.g., from MCR, shift supervisor, plant manager) you must assess the time required for such authorization
  - Don't forget delay time for gaseous system discharge applies even when manually actuated

# Task 2.7.1 – PNS<sub>fixed</sub>

- Now that you have a time to actuation and a time to damage the two are weighed to assess the value of PNS<sub>fixed</sub>
  - Take the difference:
    - $t_{\text{damage}} - t_{\text{supp\_fixed}}$
  - Refer to lookup table for PNS
- Point is that both values have uncertainty
  - If difference is small, we don't allow as much credit as when difference is large

# The $PNS_{\text{fixed}}$ lookup table

Probability of Non-suppression for Fixed Fire Suppression Systems Based on the Absolute Difference Between Damage Time and Suppression Time	
Time Delta: ( $t_{\text{Damage}} - t_{\text{Suppress}}$ )	$PNS_{\text{Fixed}}$
Negative Time up to 1 Minute	1.0
> 1 Minute to 2 Minutes	.95
> 2 Minutes to 4 Minutes	.80
> 4 Minutes to 6 Minutes	.5
> 6 Minutes to 8 Minutes	.25
> 8 Minutes to 10 Minutes	.1
> 10 Minutes	0.0

# Task 2.7.2 – Manual suppression

- Manual suppression is based on fire duration curves
  - Analysis of historical event
  - Based on total fire duration so we don't do brigade response time – built into curves
- Several curves for various fire ignition sources
  - Pick the curve that fits your ignition source
  - Example: If fire spreads from a panel to cable trays, the ignition source was the panel, use the electrical fire curve

# Manual suppression

- “Curves” are available in three forms
  - Graphical
  - Lookup table
  - Equation:

$$PNS_{manual} = \exp[-\lambda \times t]$$

- Values of constant are in lookup table

# Task 2.7.4: Final combined PNS

For water-based systems:

$$\begin{aligned} \text{PNS}_{\text{scenario}} = & (0.98 \times \text{PNS}_{\text{fixed-scenario}}) \\ & + (0.02 \times \text{PNS}_{\text{manual-scenario}}) \end{aligned}$$

For Gaseous systems:

$$\begin{aligned} \text{PNS}_{\text{scenario}} = & (0.95 \times \text{PNS}_{\text{fixed-scenario}}) \\ & + (0.05 \times \text{PNS}_{\text{manual-scenario}}) \end{aligned}$$

\*\*  $\text{PNS}_{\text{scenario}} \geq \text{PNS}_{\text{manual-scenario}}$

# And the Degraded Gaseous system – inadequate soak time case

$$\begin{aligned} \text{PNS}_{\text{scenario}} &= 0.95 \times (1 - \text{PNS}_{\text{fixed}}) \times \text{PNS}_{\text{gas\_manual}} \\ &+ [(0.95 \times \text{PNS}_{\text{fixed}}) + 0.05] \times \text{PNS}_{\text{manual}} \end{aligned}$$

## Step 2.7.5 – screening check

- We now have scenario specific PNS
- Combine with duration factor, scenario specific frequency, scenario specific credit for SSD path to get new screening result
- Screen to green if change in CDF is less than  $1E-6$

# Step 2.8 – SSD / CCDP analysis

- I won't go into detail
  - Task 2.8.1 – select plant initiating event worksheet
  - Task 2.8.2 – identify credited systems and functions
  - Task 2.8.3 – identify ex-control room actions
  - Task 2.8.4 – assess failure probability for manual actions
  - Task 2.8.5 – assess CCDP

# Step 2.9 – final quantification

- In this step you take all your best information that now includes a specific CCDP for each individual scenario
- Run them through the risk equation
- Sum scenarios
- Assign a preliminary color