

## 5.6 Reporting Requirements

---

### 5.6.5 Reactor Coolant System (RCS) PRESSURE AND TEMPERATURE LIMITS REPORT (PTLR)

- a. RCS pressure and temperature limits for heat up, cooldown, low temperature operation, criticality, hydrostatic testing, LTOP enabling, and PORV lift settings as well as heatup and cooldown rates shall be established and documented in the PTLR for the following:
  - (1) LCO 3.4.3, "RCS Pressure and Temperature (P/T) Limits"
  - (2) LCO 3.4.6, "RCS Loops-MODE 4"
  - (3) LCO 3.4.7, "RCS Loops-MODE 5, Loops Filled"
  - (4) LCO 3.4.10, "Pressurizer Safety Valves"
  - (5) LCO 3.4.12, "Low Temperature Overpressure Protection (LTOP)"
- b. The analytical methods used to determine the RCS pressure and temperature limits shall be those previously reviewed and approved by the NRC, specifically those described in the NRC Letters dated October 6, 2000, July 23, 2001, and October 18, 2007.
- c. The PTLR shall be provided to the NRC upon issuance for each reactor vessel fluence period and for any revision or supplement thereto.

### 5.6.6 PAM Report

When a report is required by Condition B or F of LCO 3.3.3, "Post Accident Monitoring (PAM) Instrumentation," a report shall be submitted within the following 14 days. The report shall outline the preplanned alternate method of monitoring, the cause of the inoperability, and the plans and schedule for restoring the instrumentation channels of the Function to OPERABLE status.

### 5.6.7 Tendon Surveillance Report

Abnormal conditions observed during testing will be evaluated to determine the effect of such conditions on containment structural integrity. This evaluation should be completed within 30 days of the identification of the condition. Any condition which is determined in this evaluation to have a significant adverse effect on containment structural integrity will be considered an abnormal degradation of the containment structure.

Any abnormal degradation of the containment structure identified during the engineering evaluation of abnormal conditions shall be reported to the