ES-301

Form ES-301-1

Facility: <u>Dresden</u>		Date of Examination: <u>4/23/07</u>
Examination Level: RO 🛛 SI	RO 🗌	Operating Test Number: 2007-301
Administrative Topic (See Note)	Type Code*	Describe activity to be performed
Conduct of Operations	B, R	Verify Iso Condenser Makeup Pump Quarterly Test Generic.2.1.14
Conduct of Operations	D, R	Verify Acceptance Criteria met for the Acoustic Monitor Based on Test Results Generic.2.1.25
Equipment Control	N, R	Verify Reversal of Emergency Diesel Generator Cooling Water Flow Generic.2.2.12
Radiation Control	M, R	Select Personnel for Radiation Work Generic.2.3.4
Emergency Plan		
NOTE: All items (5 total) are required for SROs. RO applicants require only 4 items unless they are retaking only the administrative topics, when 5 are required.		
* Type Codes & Criteria:	(D)irect (N)ew o	of room, (S)imulator, or Class(R)oom from bank (\leq 3 for ROs; \leq 4 for SROs & RO retakes) r (M)odified from bank (\geq 1) us 2 exams (\leq 1; randomly selected)

ES-301

Form ES-301-1

Facility: Dresden	_	Date of Examination: 4/23/07
Examination Level: RO 🗌 SI	RO 🛛	Operating Test Number: 2007-301
Administrative Topic (See Note)	Type Code*	Describe activity to be performed
Conduct of Operations	P, R	Reactivation of an SRO License Generic.2.1.5
Conduct of Operations	D, R	Reportability Determination Generic.2.1.1
Equipment Control	D, R	Verify Semi-Annual HRSS AFU Operability Test Generic.2.2.12
Radiation Control	M, R	Select Personnel for Radiation Work Generic.2.3.4
Emergency Plan	M, R	Authorize Use of KI Generic.2.4.40
NOTE: All items (5 total) are required for SROs. RO applicants require only 4 items unless they are retaking only the administrative topics, when 5 are required.		
* Type Codes & Criteria:	(D)irect (N)ew o	I room, (S)imulator, or Class(R)oom from bank (\leq 3 for ROs; \leq 4 for SROs & RO retakes) r (M)odified from bank (\geq 1) us 2 exams (\leq 1; randomly selected)

Exelon Nuc	lear
Job Performance	e Measure
) (avifu la c. Canadana an Makaum	Duran Querterlu Test
Verify Iso Condenser Makeup	Pump Quarterly Test
JPM Number: A-	1300-03
Revision Num	ber: 01
Date: 03/0)7
Developed By: Instructor	Date
Approved By:	
Facility Representativ	e Date

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 8 through 11 below.

 Task description ar identified. 	nd number, JPM description	on and number are
 2. Knowledge and Ab	ilities (K/A) references are	included.
 Performance locati simulator) 	on specified. (in-plant, cor	ntrol room, or
 4. Initial setup condition	ons are identified.	
 5. Initiating and termin	nating cues are properly id	lentified.
 6. Task standards ide	ntified and verified by SM	E review.
 Critical steps meet with an asterisk (*). 	the criteria for critical step	s and are identified
 current revision of t	e referenced by this JPM that procedure: Date	matches the most
	verbal and visual are free nce time is accurate.	of conflict, and
 10. If the JPM cannot b responses, then re	be performed as written wi vise the JPM.	th proper
 11. When JPM is reval cover page.	idated, SME or Instructor s	sign and date JPM
SME/Instructor		Date
SME/Instructor		Date
SME/Instructor		Date

Revision Record (Summary)

- Revision 00 Bank JPM.
- Revision 01 Revised for ILT 06-1 NRC Exam.

1. None, this is a tabletop JPM.

INITIAL CONDITIONS

- 1. DOS 1300-03 was performed last shift, for running of the 2/3A Iso Condenser Makeup Pump Quarterly Operability, for the 2nd quarter of 2007.
- 2. Lube and Fuel oil samples were NOT required.
- 3. The NLO reported all surveillance requirements were within specifications.

INITIATING CUE

1. The Unit Supervisor has directed you to verify all requirements are within specifications, and paperwork is correct, then return the paperwork to the Unit Supervisor.

.....

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

Information For Evaluator's Use:

UNSAT requires written comments on respective step.

- * Denotes critical steps.
- Denotes critical elements of a critical step.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section at the bottom of the page. The comment section should be used to document the reason that a step is marked as unsatisfactory and to document unsatisfactory performance relating to management expectations.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

JPM Start Time: _____

PEF	RFORMANCE CHECKLIST	STANDARDS	SAT	UNSAT	Comment #
		<u>NOTE:</u>			
	Provide the exam	inee with the completed copy o	of DOS 1300)-03.	
1.	Examinee reviews paperwork.				
* 2.	Student should identify step I.2 (DC VOLTS) is not \geq 25.5 volts and should NOT have been initialed.	Identifies incorrect voltage of 24.5 (correct voltage should be \geq 25.5 volts).			
* 3.	Student should identify step I.2.a and indicate that EMD should have been notified.	Informs examiner that EMD is required to be notified (may make notification at end of JPM).			
* 4.	Student should identify step I.16.c (elapsed time) is not correct, because the engine was NOT run for 30 minutes.	Identifies incorrect time of 26 min (correct elapsed time should be a minimum of 30 minutes).			
5.	Student should identify step I.22.b is N/A'd (Damper Control Switch NOT in AUTO).	Identifies incorrect N/A'd step.			
6.	Notify Unit Supervisor of discrepancies.	Notifies Unit Supervisor, to verify/correct issues.			
		END			

JPM Stop Time:_____

Operator's Name:		
Job Title: RO		
	er Makeup Pump Quarterly Test Revision Number: 01 Perform the administrative duties for c e, special, or complex procedures.	onduct of
K/A Number and Importance: Ger	neric 2.1.14 2.5 / 3.3	
Suggested Testing Environment:	Simulator	
Actual Testing Environment:	Simulator 🗌 Control Room	In-Plant
Testing Method: Simulate Perform	Alternate Path: Yes SRO Only: Yes	⊠ No ⊠ No
Time Critical: 🗌 Yes	∐ No	
Estimated Time to Complete: 10	minutes Actual Time Used:	minutes
References: DOS 1300-03, Rev 16	ō	
EVALUATION SUMMARY: Were all the Critical Elements perfe	ormed satisfactorily? Yes	□ No
The operator's performance was ev determined to be:	aluated against the standards contained Satisfactory Unsatisfac	
Comments:		
Evaluator's Name:		Print)
Evaluator's Signature:	Da	ate:

INITIAL CONDITIONS

- DOS 1300-03 was performed last shift, for running of the 2/3A Iso Condenser Makeup Pump Quarterly Operability, for the 2nd quarter of 2007.
- 2. Lube and Fuel oil samples were NOT required.
- 3. The NLO reported all surveillance requirements were within specifications.

INITIATING CUE

1. The Unit Supervisor has directed you to verify all requirements are within specifications, and paperwork is correct, then return the paperwork to the Unit Supervisor.

	Exelon Nuclear	
	Job Performance Measur	e
	Reactivation of an SRO License	
	JPM Number: A-N-1-S	
	Revision Number: 01	
	Date: 11/06	
Developed By:	Instructor	 Date
Approved By:	Facility Representative	Date

Revision Record (Summary)

- Revision 00 New JPM created for ILT 05-1 NRC Exam.
- **Revision 01** JPM revised for ILT 06-1 NRC Exam.

SIMULATOR SETUP INSTRUCTIONS

1. None, this is a tabletop JPM.

HANDOUT PREPARATION

- 1. Fill out OP-AA-105-102, Attachment 2 up to but not including Shift Manager Approval for a fictitious SRO License holder.
- 2. In the Hours on Shift table, enter 4 shifts of 8 hours as a Unit Supervisor. Enter 1 shift of 8 hours as the WEC supervisor.

INITIAL CONDITIONS

- 1. You are the Shift Manager.
- 2. An SRO is in the process of license reactivation.
- 3. OP-AA-105-102, Attachment 2, Reactivation of License Log, is filled out up to the point of Shift Manager review for the licensee.

INITIATING CUE

1. The Shift Operation Superintendent directs you to "perform the Shift Manager review of OP-AA-105-102, Attachment 2 for the licensee and return it to me".

.....

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

Information For Evaluator's Use:

UNSAT requires written comments on respective step.

- * Denotes critical steps.
- Denotes critical elements of a critical step.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section at the bottom of the page. The comment section should be used to document the reason that a step is marked as unsatisfactory and to document unsatisfactory performance relating to management expectations.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

JPM Start Time:

PERFORMANCE CHECKLIST	STANDARDS	SAT	UNSAT	Comment #
	<u>CUE:</u>			
Provide the Examine	e the provided marked up copy o	f OP-AA-105	-102.	
1. Review OP-AA-105-102, Attachment 2.	Reviews OP-AA-105-102, Attachment 2.			
2. * Check that Hours on Shift are applicable for license reactivation.	Notes that 8 hours listed in the Hours on Shift are for WEC Supervisor which does not count toward the 40 hours required.			
3. * Check that licensee has the required 40 hours.	Determines that licensee has ONLY 32 hours toward the required 40 hours.			
 Report the results of the review to the Shift Operations Superintendent (SOS). 	Returns without signing OP- AA-105-102, Attachment 2 to the SOS. Informs the SOS that the licensee's license CANNOT be reactivated due to insufficient hours on shift.			
	CUE:	I		
As	the SOS, acknowledge the report			
	END			

JPM Stop Time:_____

Operator's Name:	
Job Title: SRO	
JPM Title: Reactivation of SRO Lic JPM Number: A-N-1-S Task Number and Title: 299L024, N	Revision Number: 01
K/A Number and Importance: Gene	ric.2.1.5 2.3 / 3.4
Suggested Testing Environment:	Simulator
Actual Testing Environment:	Simulator Control Room In-Plant
Testing Method: ☐ Simulate	Alternate Path:YesNoSRO Only:YesNo
Time Critical: 🗌 Yes 🛛 🛛] No
Estimated Time to Complete: 15	minutes Actual Time Used: minutes
References: OP-AA-105-102, rev	08
EVALUATION SUMMARY: Were all the Critical Elements perfo	ormed satisfactorily?
The operator's performance was eva determined to be:	aluated against the standards contained in this JPM, and has been Satisfactory Unsatisfactory
Comments:	
Evaluator's Name:	(Print)
Evaluator's Signature:	Date:

INITIAL CONDITIONS

- 1. You are the Shift Manager.
- 2. An SRO is in the process of license reactivation.
- 3. OP-AA-105-102, Attachment 2, Reactivation of License Log, is filled out up to the point of Shift Manager review for the licensee.

INITIATING CUE

1. The Shift Operation Superintendent directs you to "perform the Shift Manager review of OP-AA-105-102, Attachment 2 for the licensee and return it to me".

	Exelon Nuclea	r
Jo	b Performance Me	easure
	Oritoria for Accurtic Monit	
Verity Acceptance	Criteria for Acoustic Monit	or Based on Test Results
	JPM Number: A-N-2	2-R
	Revision Number:	01
	Date: 11/06	
	structor	Date
	cility Representative	Date

Revision Record (Summary)

Revision 00 Bank JPM.

Revision 01 Revised for ILT 06-1 NRC Exam.

SIMULATOR SETUP INSTRUCTIONS

1. None, this is a tabletop JPM.

INITIAL CONDITIONS

- 1. You are the Unit 2 NSO.
- 2. DOS 0250-06 was performed last shift, for the Acoustic Monitor / Temperature Detector Operability Test.
- 3. The off-going NSO was unable to verify the paperwork, and has turned it over to you.
- 4. The NSO reported all surveillance requirements were within specifications.

INITIATING CUE

1. Verify all requirements are within specifications, and paperwork is correct.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

Information For Evaluator's Use:

UNSAT requires written comments on respective step.

- * Denotes critical steps.
- Denotes critical elements of a critical step.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section at the bottom of the page. The comment section should be used to document the reason that a step is marked as unsatisfactory and to document unsatisfactory performance relating to management expectations.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

JPM Start Time:

PERFORMANCE CHECKLIST	STANDARDS	SAT	UNSAT	Comment #
	NOTE:			
	minee with the completed copy of	DOS 0250-0	6.	
 Examinee reviews paperwork. 				
2. * Examinee should identify data sheet valve 203-4B threshold volt is out of spec (see KEY).	Identifies out of spec value.			
3. * Examinee should identify data sheet valve 203-4F threshold volt is out of spec (see KEY).	Identifies out of spec value.			
 4. Examinee should identify data sheet valve 203-4C "Amber Light Out" step that should NOT be N/A'd (see KEY). 	Identifies N/A'd step.			
5. * Examinee should identify data sheet valves 203-3C and 203-4F discharge temps are > 100°F difference (see KEY).	Identifies 2 temperatures > 100°F difference.			
Respo	CUE: nd as needed, as the NLO in the f	ïeld		
	END			

JPM Stop Time:_____

perator's Name:
ob Title: RO
PM Title: Verify Acceptance Criteria for Acoustic Monitor Based on Test Results PM Number: A-N-2-R Revision Number: 01 ask Number and Title: 299L080 Perform the administrative duties for conduct of surveillance, pecial, or complex procedures.
/A Number and Importance: Generic.2.1.25 2.8 / 3.1
uggested Testing Environment: Simulator
ctual Testing Environment: Simulator Control Room In-Plant
esting Method: \Box SimulateAlternate Path: \Box Yes \boxtimes No \Box PerformSRO Only: \Box Yes \boxtimes No
Time Critical: 🗌 Yes 🛛 No
stimated Time to Complete: 10 minutes Actual Time Used: minutes
eferences: DOS 0250-06, rev 13
VALUATION SUMMARY: Vere all the Critical Elements performed satisfactorily?
he operator's performance was evaluated against the standards contained in this JPM, and has been etermined to be:
omments:
Evaluator's Name: (Print)
valuator's Signature: Date:

INITIAL CONDITIONS

- 1. You are the Unit 2 NSO.
- 2. DOS 0250-06 was performed last shift, for the Acoustic Monitor / Temperature Detector Operability Test.
- 3. The off-going NSO was unable to verify the paperwork, and has turned it over to you.
- 4. The NLO reported all surveillance requirements were within specifications.

INITIATING CUE

1. Verify all requirements are within specifications, and paperwork is correct.

Exelon Nuclear				
Job Performance Measure				
	Reportability Determination			
	JPM Number: A-N-2-S			
Revision Number: 01				
Date: 11/06				
Developed By:	Instructor	Date		
		Buit		
Approved By:	Facility Representative	Date		

Revision Record (Summary)

Revision 00 Bank JPM.

Revision 01 Revised for ILT 06-1 NRC Exam.

SIMULATOR SETUP INSTRUCTIONS

1. None, this is a tabletop JPM.

INITIAL CONDITIONS

- 1. You are the Unit Supervisor.
- 2. An event has occurred resulting in the following conditions:
 - A Reactor Operator telephones the Control Room, from home, and informs you that they were convicted of a felony yesterday.

INITIATING CUE

1. Determine the Reportability requirements, including the Event Classification and the Time Limit of any Notifications or Reports, if any.

.....

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

Information For Evaluator's Use:

UNSAT requires written comments on respective step.

- * Denotes critical steps.
- Denotes critical elements of a critical step.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section at the bottom of the page. The comment section should be used to document the reason that a step is marked as unsatisfactory and to document unsatisfactory performance relating to management expectations.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

JPM Start Time: _____

PER	FORMANCE CHECKLIST	STANDARDS	SAT	UNSAT	Comment #
	<u>NOTE:</u>				
	Examinee locates a copy of Reportability Manual LS-AA-1110.				
1.	Determines the event is reportable per SAF 1.41.	Determines the event is reportable per SAF 1.41, Felony Conviction of a Licensed Operator.			
2. *	Determines the time limit to make a written report is 30 days.	Determines the time limit to make a written report is within 30 days of a felony conviction of a licensed operator.			
		END			

JPM Stop Time:_____

Operator's Name:	
Job Title: SRO	
JPM Title: Reportability Determination JPM Number: A-N-2-S Task Number and Title: 299L001, Deter Reportability manual.	Revision Number: 01 rmine Reportability requirements as outlined in station
K/A Number and Importance: Generic.2	2.1.1 3.7 / 3.8
Suggested Testing Environment: Sin	mulator
Actual Testing Environment:	Simulator Control Room In-Plant
Testing Method: Simulate Perform	Alternate Path:YesNoSRO Only:YesNo
Time Critical: 🗌 Yes 🛛 No)
Estimated Time to Complete: 10 min	utes Actual Time Used: minutes
References: Reportability Manual LS-	AA-1110, rev 08
EVALUATION SUMMARY: Were all the Critical Elements performe	d satisfactorily?
· · · ·	ted against the standards contained in this JPM, and has been tisfactory Unsatisfactory
Comments:	
Evaluator's Name:	(Print)
Evaluator's Signature:	Date:

INITIAL CONDITIONS

- 1. You are the Unit Supervisor.
- 2. An event has occurred resulting in the following conditions:
 - A Reactor Operator telephones the Control Room, from home, and informs you that they were convicted of a felony yesterday.

INITIATING CUE

1. Determine the Reportability requirements, including the Event Classification and the Time Limit of any Notifications or Reports, if any.

Exelon Nuclear			
Job Performance Measure			
Verify Reversal of Emergency Diesel Generator Cooling Water Flow			
JPM Number: A-N-3-R			
Revision Number: 00			
Date: 11/06			
Doveloped By:			
Developed By: Date			
Approved By			
Approved By: Facility Representative Date			

Revision Record (Summary)

Revision 00 New JPM created for ILT 06-1 NRC Exam.

SIMULATOR SETUP INSTRUCTIONS

1. None, this is a tabletop JPM.

INITIAL CONDITIONS

- 1. You are the Unit 2 NSO.
- 2. DOS 6600-02, REVERSAL OF EMERGENCY DIESEL GENERATOR COOLING WATER FLOW, has just been completed on the Unit 2 EDG, for an annual PMT.
- 3. The NLO has brought the surveillance to the Control Room for verification.

INITIATING CUE

- 1. The Unit Supervisor directs you to verify the surveillance.
- 2. Return the surveillance to the Unit Supervisor when complete.

.....

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

Information For Evaluator's Use:

UNSAT requires written comments on respective step.

- * Denotes critical steps.
- Denotes critical elements of a critical step.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section at the bottom of the page. The comment section should be used to document the reason that a step is marked as unsatisfactory and to document unsatisfactory performance relating to management expectations.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

JPM Start Time:

PERFORMANCE CHECKLIST		STANDARDS	SAT	UNSAT	Comment #		
	NOTE:						
	Provide the ex	aminee the completed copy of DC	OS 6600-02.				
1.	Examinee reviews the paperwork.						
2.	Examinee should identify step I.5.a as having an incorrect value.	Differential Pressure (DP) should be 4 .					
3. *	Examinee should identify step I.15.a value as being above the Acceptance Criteria value (in step I.16).	Acceptance Criteria (AC) is < 6.0 psid.					
4.	Examinee should identify steps I.20.a and I.20.b as having the same initial as the rest of the initials (NOT independently verified).	Should NOT be initialed by same person as performing rest of surveillance.					
5.	Reports the discrepancies to the Unit Supervisor	Acknowledge report.					
		END					

JPM Stop Time:_____

Operator's Name:	
Job Title: RO	
JPM Title: Verify Reversal of Emergency Diesel Generator Cooling Water F JPM Number: A-N-3-R Revision Num Task Number and Title: 26400LK003, Describe Emergency Diesel Generator including frequency, types of starts, and duration runs.	ber: 00
K/A Number and Importance: Generic.2.2.12 3.0 / 3.4	
Suggested Testing Environment: Simulator	
Actual Testing Environment: Simulator Control Room] In-Plant
Testing Method: \Box SimulateAlternate Path: \Box Yes \boxtimes \boxtimes PerformSRO Only: \Box Yes \boxtimes] No] No
Time Critical: 🗌 Yes 🛛 No	
Estimated Time to Complete: 10 minutes Actual Time Used:	minutes
References: DOS 6600-02, rev 15	
EVALUATION SUMMARY: Were all the Critical Elements performed satisfactorily?] No
The operator's performance was evaluated against the standards contained in determined to be:	
Comments:	
Evaluator's Name: (Prin	t)
Evaluator's Signature: Date:	

INITIAL CONDITIONS

- 1. You are the Unit 2 NSO.
- DOS 6600-02, REVERSAL OF EMERGENCY DIESEL GENERATOR COOLING WATER FLOW, has just been completed on the Unit 2 EDG, for an annual PMT.
- 3. The NLO has brought the surveillance to the Control Room for verification.

INITIATING CUE

- 1. The Unit Supervisor directs you to verify the surveillance.
- 2. Return the surveillance to the Unit Supervisor when complete.

Exelon Nuclear		
Job Performance Measur	e	
Verify Semi-Annual HRSS AFU Operabil	ity Test	
JPM Number: A-N-3-S		
Revision Number: 01		
Date: 11/06		
Developed By:		
Instructor	Date	
Approved By:		
Facility Representative	Date	

Revision Record (Summary)

Revision 00 Bank JPM.

Revision 01 JPM revised for ILT 06-1 NRC Exam.

SIMULATOR SETUP INSTRUCTIONS

1. None, this is a tabletop JPM.

INITIAL CONDITIONS

- 1. You are the Unit 2 Unit Supervisor.
- 2. DOS 8900-01 was performed, last shift, for Unit 2 HRSS AFU.
- 3. The NLO reported all surveillance requirements were within specifications .
- 4. The off-going Unit Supervisor was unable to verify the paperwork, and has turned it over to you.

INITIATING CUE

1. Verify all requirements are within specifications, and paperwork is correct.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

Information For Evaluator's Use:

UNSAT requires written comments on respective step.

- * Denotes critical steps.
- Denotes critical elements of a critical step.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section at the bottom of the page. The comment section should be used to document the reason that a step is marked as unsatisfactory and to document unsatisfactory performance relating to management expectations.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

JPM Start Time: _____

PER	FORMANCE CHECKLIST	STANDARDS	SAT	UNSAT	Comment #
		<u>NOTE:</u>			
	Provide the student with t	he completed (simulated) and ma	rked up DOS	8900-01.	
		<u>NOTE:</u>			
	The follow	ving steps may be identified in any	/ order.		
1.	Examinee reviews paperwork.				
2. *	Examinee should identify, on data sheet 1, that the Filter Exhaust Fan 1 Delta CFM is NOT \geq 200 cfm.	Identifies that Delta CFM is 125 CFM.			
3. *	Examinee should identify, on data sheet 1, that the Filter Exhaust Fan 2 dP is NOT < 6 inches.	Identifies that dP is 7 inches.			
4.	Examinee should identify step I.16.c.(2) not have been N/A'd.	Identifies that the step should NOT have been N/A'd.			
5.	Reports that the surveillance does NOT meet all acceptance criteria and may notify System Engineer.	Acknowledge report.			
		END			

JPM Stop Time:_____

Operator's Name:	
Job Title: SRO	
JPM Title: Verify Semi-Annual JPM Number: A-N-3-S Task Number and Title: 299L0 special, or complex procedures	Revision Number: 01 80 Perform the administrative duties for conduct of surveillance,
K/A Number and Importance: C	Generic.2.2.12 3.0 / 3.4
Suggested Testing Environme	ent: Simulator
Actual Testing Environment:	Simulator Control Room In-Plant
Testing Method: Simula	
Time Critical: 🗌 Yes	🖾 No
Estimated Time to Complete:	10 minutes Actual Time Used: minutes
References: DOS 8900-01, rev	7 09
EVALUATION SUMMARY: Were all the Critical Elements p	
The operator's performance wa determined to be:	s evaluated against the standards contained in this JPM, and has been Satisfactory Unsatisfactory
Comments:	
Evaluator's Name:	(Print)
Evaluator's Signature:	Date:

INITIAL CONDITIONS

- 1. You are the Unit 2 Unit Supervisor.
- 2. DOS 8900-01 was performed, last shift, for Unit 2 HRSS AFU.
- 3. The NLO reported all surveillance requirements were within specifications .
- 4. The off-going Unit Supervisor was unable to verify the paperwork, and has turned it over to you.

INITIATING CUE

1. Verify all requirements are within specifications, and paperwork is correct.

Exelon Nuclear			
	Job Performance Measure		
	Select Personnel for Radiation Work		
	JPM Number: A-N-4-R		
	Revision Number: 00		
	Date: 11/06		
Developed Bv:			
	Instructor	Date	
Approved By:			
	Facility Representative	Date	

Revision Record (Summary)

Revision 00 New JPM created for ILT 06-1 NRC Exam, modified from Quad Cities Bank.

SIMULATOR SETUP INSTRUCTIONS

1. None, this is a tabletop JPM.

INITIAL CONDITIONS

- 1. You will be briefing NLOs to perform a Clearance Order First Hang in the Unit 3 RWCU Pump Room under RWP 10004555.
- 2. Five NLOs are available this shift.
 - None of the five have received dose at any location other than Dresden Station.
 - None of the five have received dose since midnight on any RWPs other than 10004555.
- 3. The Radiation Protection Department has provided the attached Survey map, and the following dose history for the five NLOs to assist you in your planning:

Name	Annual TEDE dose as of Midnight Today	DDE dose received on RWP 10004555 Today
Ben	1940 mrem	0 mrem
Larry	1500 mrem	35 mrem
Jim	1800 mrem	8 mrem
Steve	1900 mrem	5 mrem
Bob	1950 mrem	0 mrem

- 4. The total expected stay time for each NLO will be 45 minutes. Based on past job history, it will breakdown as follows:
- 30 minutes total in the area near the following **two** valves:
 - 3-1201-138 RWCU Aux Pump Suction (at RWCU Aux Pump)
 - 3-1201-139 RWCU Aux Pump Discharge (at RWCU Aux Pump)
- 15 minutes total in the area near the following **one** valve:
 - 3-1201-128A 'A' RWCU Pump Suction (at 'A' RWCU Pump)

INITIATING CUE

1. CALCULATE the expected dose for the work in RWCU Pump Room. DETERMINE which NLO(s) CAN and which NLO(s) CAN NOT be assigned to perform the task. EXPLAIN the basis for your determination.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

Information For Evaluator's Use:

UNSAT requires written comments on respective step.

- * Denotes critical steps.
- Denotes critical elements of a critical step.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section at the bottom of the page. The comment section should be used to document the reason that a step is marked as unsatisfactory and to document unsatisfactory performance relating to management expectations.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

<u>KEY</u>

EVALUATOR: The candidate must determine that dose for the task will be 70 mrem and determine that only two NLO can receive the dose, necessary to complete the task. They are <u>Jim and Steve</u>. See the table below for projected job dose, 24 hour total dose on RWP 10004555, and total Annual TEDE dose for each Operator.

Calculation:

2 valves clearance (at RWCU Aux Pump) projected dose = $0.50 \text{ hr x } 80 \text{ mr/hr} = \frac{40 \text{mrem}}{1 \text{ valve clearance}}$ (at 'A' RWCU Pump) projected dose = $0.25 \text{ hr x } 120 \text{ mr/hr} = \frac{30 \text{mrem}}{1 \text{ valve clearance}}$

Name	DDE dose received on RWP 10004555 today	Annual TEDE dose as of Midnight Today	Projected dose on RWP 10004555 for the 24 hour period	Projected Annual TEDE (including all dose from last 24 hours)
Ben	0 mrem	1940 mrem	(0 + 70 =) <u>70 mrem</u>	(1940 + 70 =) <u>2010 mrem</u>
Larry	35 mrem	1500 mrem	(35 + 70 =) <u>105 mrem</u>	(1500 + 70 =) <u>1570 mrem</u>
Jim	8 mrem	1800 mrem	(8 + 70 =) <u>78 mrem</u>	(1800 + 70 =) <u>1870 mrem</u>
Steve	5 mrem	1900 mrem	(5 + 70 =) <u>75 mrem</u>	(1900 + 70 =) <u>1975 mrem</u>
Bob	0 mrem	1950 mrem	(0 + 70 =) <u>70 mrem</u>	(1950 + 70 =) <u>2020 mrem</u>

40mrem + 30 mrem = <u>70 mrem</u> projected job dose for clearance order hanging

The **bolded** values in the table exceed the applicable Company, RWP, or 10CFR limit.

JPM Start Time: _____

	1			
PERFORMANCE CHECKLIST	STANDARDS	SAT	UNSAT	Comment #
	NOTE:			
Provide the examinee a copy of	the attached RWP and survey ma	ap of the RW	CU pump r	oom.
	NOTE:			
The followir	ng steps may be performed in a ai	ny order.		
 Reviews Survey Maps to determine area dose rates. 				
	<u>NOTE:</u>			
The fo	llowing calculations should be ma	ide:		
2 valve clearance	e projected dose = 0.50 hr x 80 mi	r/hr = 40mre r	n	
1 valve clearance	projected dose = 0.25 hr x 120 m	nr/hr = 30mre	m	
Total projected do	ose for the job = 40mrem + 30 mr	em = 70 mre	m	
 Calculates that the projected dose that will be received for the task is 70 mrem. 	Determines the NLO's will receive 40 mrem on the first 2 valves and 30 on the next 1.			
	CUE:	·		
IF the candidate inquires at to whether or not any of the NLOs has received permission to exceed any dose limits, respond, "None of the Non Licensed Operators have received permission to exceed any limits".				
NOTE:				
The following steps may be performed in any order.				
3. * Determines that Ben CAN NOT perform the job because he would exceed the 2000 mrem Exelon Annual limit.	Ben's total Annual dose would be <u>2010 mrem</u> .			

PER	RFORMANCE CHECKLIST	STANDARDS	SAT	UNSAT	Comment #
4. *	Determines that Larry CAN NOT perform the job because he would exceed the 80 mrem dose alarm on RWP 10004555.	Larry's total dose on RWP 10004555 would be <u>105 mrem</u> .			
5.	Determines that Jim CAN perform the job because no limits will be exceeded.	Jim's total RWP dose and Annual dose will remain below the limits.			
6.	Determines that Steve CAN perform the job because no limits will be exceeded.	Steve's total RWP dose and Annual dose will remain below the limits.			
7. *	Determines that Bob CAN NOT perform the job because he would exceed the 2000 mrem Exelon Annual limit.	Bob's total Annual dose would be <u>2020 mrem</u> .			
		END			

JPM Stop Time:_____

Operator's Name:	
Job Title: RO	
JPM Title: Select Personnel for Radiation Work JPM Number: A-N-4-R I Task Number and Title: 29900LK119, Discuss the items to be o	Revision Number: 00 considered prior to work authorization
K/A Number and Importance: Generic.2.3.4 2.5 / 3.1	
Suggested Testing Environment: Simulator	
Actual Testing Environment: Simulator Control	Room In-Plant
Testing Method:SimulateAlternate Path:PerformSRO Only:	Yes \boxtimes NoYes \boxtimes No
Time Critical: Yes Xo	
Estimated Time to Complete: 10 minutes Actual Time	Used: minutes
References: RP-AA-203, rev 02	
EVALUATION SUMMARY: Were all the Critical Elements performed satisfactorily?	Yes 🗌 No
The operator's performance was evaluated against the standards determined to be:	s contained in this JPM, and has been Unsatisfactory
Comments:	
Evaluator's Name:	(Print)
Evaluator's Signature:	Date:

INITIAL CONDITIONS

- 1. You will be briefing NLOs to perform a Clearance Order First Hang in the Unit 3 RWCU Pump Room under RWP 10004555.
- 2. Five NLOs are available this shift.
 - None of the five have received dose at any location other than Dresden Station.
 - None of the five have received dose since midnight on any RWPs other than 10004555.
- 3. The Radiation Protection Department has provided the attached Survey map, and the following dose history for the five NLOs to assist you in your planning:

Name	Annual TEDE dose as of Midnight Today	DDE dose received on RWP 10004555 Today
Ben	1940 mrem	0 mrem
Larry	1500 mrem	35 mrem
Jim	1800 mrem	8 mrem
Steve	1900 mrem	5 mrem
Bob	1950 mrem	0 mrem

- 4. The total expected stay time for each NLO will be 45 minutes. Based on past job history, it will breakdown as follows:
- 30 minutes total in the area near the following **two** valves:
 - 3-1201-138 RWCU Aux Pump Suction (at RWCU Aux Pump)
 - 3-1201-139 RWCU Aux Pump Discharge (at RWCU Aux Pump)
- 15 minutes total in the area near the following **one** valve:
 - 3-1201-128A 'A' RWCU Pump Suction (at 'A' RWCU Pump)

INITIATING CUE

 CALCULATE the expected dose for the work in RWCU Pump Room. DETERMINE which NLO(s) CAN and which NLO(s) CAN NOT be assigned to perform the task. EXPLAIN the basis for your determination.

Exelon Nuclear			
	Job Performance Measure		
	Select Personnel for Radiation Work		
	JPM Number: A-N-4-S		
	Revision Number: 00		
	Date: 11/06		
Developed By:			
	Instructor	Date	
Approved By:			
	Facility Representative	Date	

Revision Record (Summary)

Revision 00 New JPM created for ILT 06-1 NRC Exam, modified from Quad Cities Bank.

SIMULATOR SETUP INSTRUCTIONS

1. None, this is a tabletop JPM.

INITIAL CONDITIONS

- 1. You will be briefing NLOs to perform a Clearance Order First Hang in the Unit 3 RWCU Pump Room under RWP 10004555.
- 2. Five NLOs are available this shift.
 - None of the five have received dose at any location other than Dresden Station.
 - None of the five have received dose since midnight on any RWPs other than 10004555.
- 3. The Radiation Protection Department has provided the attached Survey map, and the following dose history for the five NLOs to assist you in your planning:

Name	Annual TEDE dose as of Midnight Today	DDE dose received on RWP 10004555 Today
Ben	1940 mrem	0 mrem
Larry	1500 mrem	35 mrem
Jim	1800 mrem	8 mrem
Steve	1900 mrem	5 mrem
Bob	1950 mrem	0 mrem

- 4. The total expected stay time for each NLO will be 45 minutes. Based on past job history, it will breakdown as follows:
- 30 minutes total in the area near the following **two** valves:
 - 3-1201-138 RWCU Aux Pump Suction (at RWCU Aux Pump)
 - 3-1201-139 RWCU Aux Pump Discharge (at RWCU Aux Pump)
- 15 minutes total in the area near the following **one** valve:
 - 3-1201-128A 'A' RWCU Pump Suction (at 'A' RWCU Pump)

INITIATING CUE

1. CALCULATE the expected dose for the work in RWCU Pump Room. DETERMINE which NLO(s) CAN and which NLO(s) CAN NOT be assigned to perform the task. EXPLAIN the basis for your determination.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

Information For Evaluator's Use:

UNSAT requires written comments on respective step.

- * Denotes critical steps.
- Denotes critical elements of a critical step.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section at the bottom of the page. The comment section should be used to document the reason that a step is marked as unsatisfactory and to document unsatisfactory performance relating to management expectations.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

<u>KEY</u>

EVALUATOR: The candidate must determine that dose for the task will be 70 mrem and determine that only two NLO can receive the dose, necessary to complete the task. They are <u>Jim and Steve</u>. See the table below for projected job dose, 24 hour total dose on RWP 10004555, and total Annual TEDE dose for each Operator.

Calculation:

2 valves clearance (at RWCU Aux Pump) projected dose = $0.50 \text{ hr x } 80 \text{ mr/hr} = \frac{40 \text{mrem}}{1 \text{ valve clearance}}$ (at 'A' RWCU Pump) projected dose = $0.25 \text{ hr x } 120 \text{ mr/hr} = \frac{30 \text{mrem}}{1 \text{ mrem}}$

Name	DDE dose received on RWP 10004555 today	Annual TEDE dose as of Midnight Today	Projected dose on RWP 10004555 for the 24 hour period	Projected Annual TEDE (including all dose from last 24 hours)
Ben	0 mrem	1940 mrem	(0 + 70 =) <u>70 mrem</u>	(1940 + 70 =) <u>2010 mrem</u>
Larry	35 mrem	1500 mrem	(35 + 70 =) <u>105 mrem</u>	(1500 + 70 =) <u>1570 mrem</u>
Jim	8 mrem	1800 mrem	(8 + 70 =) <u>78 mrem</u>	(1800 + 70 =) <u>1870 mrem</u>
Steve	5 mrem	1900 mrem	(5 + 70 =) <u>75 mrem</u>	(1900 + 70 =) <u>1975 mrem</u>
Bob	0 mrem	1950 mrem	(0 + 70 =) <u>70 mrem</u>	(1950 + 70 =) <u>2020 mrem</u>

40mrem + 30 mrem = <u>70 mrem</u> projected job dose for clearance order hanging

The **bolded** values in the table exceed the applicable Company, RWP, or 10CFR limit.

JPM Start Time: _____

				•	
PERFORMANCE CHECKLIST	STANDARDS	SAT	UNSAT	Comment #	
	<u>NOTE:</u>				
Provide the examinee a copy of	the attached RWP and survey ma	ap of the RW	CU pump r	oom.	
	<u>NOTE:</u>				
The followir	ng steps may be performed in a ai	ny order.			
 Reviews Survey Maps to determine area dose rates. 	Reviews the survey maps and determines area dose rates to be 120 mr/hr for the first group of 2 valves and 80 mr/hr for the remaining valve.				
	<u>NOTE:</u>				
The fo	llowing calculations should be ma	de:			
2 valve clearance	e projected dose = 0.50 hr x 80 mi	r/hr = 40mre r	n		
1 valve clearance	projected dose = 0.25 hr x 120 m	r/hr = 30mre	m		
Total projected do	ose for the job = 40mrem + 30 mr	em = 70 mre	m		
 Calculates that the projected dose that will be received for the task is 70 mrem. 	Determines the NLO's will receive 40 mrem on the first 2 valves and 30 on the next 1.				
	<u>CUE:</u>				
IF the candidate inquires at to whether or not any of the NLOs has received permission to exceed any dose limits, respond, "None of the Non Licensed Operators have received permission to exceed any limits".					
3. * Determines that Ben CAN NOT perform the job because he would exceed the 2000 mrem Exelon Annual limit.	Ben's total Annual dose would be <u>2010 mrem</u> .				
4. * Determines that Larry CAN NOT perform the job because he would exceed the 80 mrem dose alarm on RWP 10004555.	Larry's total dose on RWP 10004555 would be <u>105 mrem</u> .				

PER	RFORMANCE CHECKLIST	STANDARDS	SAT	UNSAT	Comment #
5.	Determines that Jim CAN perform the job because no limits will be exceeded.	Jim's total RWP dose and Annual dose will remain below the limits.			
6.	Determines that Steve CAN perform the job because no limits will be exceeded.	Steve's total RWP dose and Annual dose will remain below the limits.			
7. *	Determines that Bob CAN NOT perform the job because he would exceed the 2000 mrem Exelon Annual limit.	Bob's total Annual dose would be <u>2020 mrem</u> .			
		END			

JPM Stop Time:_____

Operator's Name:	
Job Title: SRO	
JPM Title: Select Personnel for Radiation Wo JPM Number: A-N-4-S Task Number and Title: 29900LK119, Discus	rk Revision Number: 00 s the items to be considered prior to work authorization
K/A Number and Importance: Generic.2.3.4	2.5 / 3.1
Suggested Testing Environment: Simulate	or
Actual Testing Environment:	Ilator Control Room In-Plant
Testing Method:SimulateAlt \boxtimes Perform	ternate Path: Yes No SRO Only: Yes No
Time Critical: 🗌 Yes 🛛 No	
Estimated Time to Complete: 10 minutes	Actual Time Used: minutes
References: RP-AA-203, rev 02	
EVALUATION SUMMARY: Were all the Critical Elements performed satis	sfactorily? 🗌 Yes 🗌 No
The operator's performance was evaluated ag determined to be:	ainst the standards contained in this JPM, and has been tory Unsatisfactory
Comments:	
Evaluator's Name:	(Print)
Evaluator's Signature:	Date:

INITIAL CONDITIONS

- 1. You will be briefing NLOs to perform a Clearance Order First Hang in the Unit 3 RWCU Pump Room under RWP 10004555.
- 2. Five NLOs are available this shift.
 - None of the five have received dose at any location other than Dresden Station.
 - None of the five have received dose since midnight on any RWPs other than 10004555.
- 3. The Radiation Protection Department has provided the attached Survey map, and the following dose history for the five NLOs to assist you in your planning:

Name	Annual TEDE dose as of Midnight Today	DDE dose received on RWP 10004555 Today
Ben	1940 mrem	0 mrem
Larry	1500 mrem	35 mrem
Jim	1800 mrem	8 mrem
Steve	1900 mrem	5 mrem
Bob	1950 mrem	0 mrem

- 4. The total expected stay time for each NLO will be 45 minutes. Based on past job history, it will breakdown as follows:
- 30 minutes total in the area near the following **two** valves:
 - 3-1201-138 RWCU Aux Pump Suction (at RWCU Aux Pump)
 - 3-1201-139 RWCU Aux Pump Discharge (at RWCU Aux Pump)
- 15 minutes total in the area near the following **one** valve:
 - 3-1201-128A 'A' RWCU Pump Suction (at 'A' RWCU Pump)

INITIATING CUE

 CALCULATE the expected dose for the work in RWCU Pump Room. DETERMINE which NLO(s) CAN and which NLO(s) CAN NOT be assigned to perform the task. EXPLAIN the basis for your determination.

Exelon Nuclear			
	Job Performance Measure		
	Authorize Use of KI		
	JPM Number: A-N-5-S		
	Revision Number: 00		
Date: 03/07			
Developed By:	Instructor	 Date	
Approved By:	Facility Representative	Date	

Revision Record (Summary)

Revision 00 New JPM created for ILT 06-1 NRC Exam (modified from LaSalle 2006 exam).

SIMULATOR SETUP INSTRUCTIONS

1. None, this is a tabletop JPM.

INITIAL CONDITIONS

- 1. You are the Station Emergency Director.
- 2. A General Emergency has been declared.
- 3. There is an offsite release in progress.
- 4. Fuel Failure has occurred, together with a failure of the RCS.
- 5. Containment is currently being challenged.
- 6. The TSC has NOT been activated, but the appropriate EAL has been declared.
- 7. An Emergency life saving operation MUST be performed.
- 8. The operation will take between 15 and 20 minutes in a 100 R/hr field (CDE) with unknown fission product gas concentration in the room.
- 9. The operation requires two people to enter the field.
- 10. Fred Mertz and Harvey Korman have volunteered.
- 11. Fred and Harvey have never received an emergency exposure before.
- 12. Authorization for Emergency Exposure (EP-AA-113-F-02 forms) have been filled out for Fred and Harvey.

INITIATING CUE

1. Perform a KI assessment, per section 4.4 of EP-AA-113.

.....

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

Information For Evaluator's Use:

UNSAT requires written comments on respective step.

- * Denotes critical steps.
- Denotes critical elements of a critical step.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section at the bottom of the page. The comment section should be used to document the reason that a step is marked as unsatisfactory and to document unsatisfactory performance relating to management expectations.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

JPM Start Time: _____

PERFORMANCE CHECKLIST	STANDARDS	SAT	UNSAT	Comment #
	NOTE:		·	
	Provide the examinee copies of:			
EP-A	A-113, Personnel Protective Actio	ons		
Filled out copies (2) of I	P-AA-113-F-02, Authorization Of	Emergency E	Exposure	
EP-AA-113	-F-03, Thyroid Blocking Agent Aut	horization		
1. Applicant determines need for emergency action.	Emergency action is needed per initiating cue.			
2. Applicant recognizes per the initiating cue that authorization to take KI must also be completed prior to the emergency workers entering the space.	Recognizes that authorization to take KI must also be completed.			
3. * Determines from step 4.4.1.B that workers will be entering an unknown radiological atmosphere that is suspected to have a high iodine concentration. (Based on initial cue.) Determines KI must be issued.	Determines KI must be issued.			
4. * Documents the decision to issue KI using Thyroid Blocking Agent Authorization Form (EP-AA- 113-F-03). Both individuals entering the space must be listed with correct social security numbers.	Fred Mertz, SSN# 012-34- 5678; Harvey Korman, SSN# 123-45-6789.			
NOTE: If asked, inform examinee the Occupational Health (Medical) Services Department has been notified.				

PE	RFORMANCE CHECKLIST	STANDARDS	SAT	UNSAT	Comment #
5.	Provides EP-AA-113-F-03 form to Radiation Protection Manager for review.	Examinee states that he/she would provide EP-AA-113-F-03 form to Radiation Protection Manager for review.			
	NOTE:				
JPM is complete when applicant provides EP-AA-113-F-03 form to RP Manager for review.					
		END			

JPM Stop Time:_____

Operator's Name:	
Job Title: SRO	
JPM Title: Authorize Use of KI JPM Number: A-N-5-S Task Number and Title: Perform the duties of the Shift F	Revision Number: 00 Emergency Director
K/A Number and Importance: Generic.2.4.40 2.3 / 4.0)
Suggested Testing Environment: Simulator	
Actual Testing Environment: Simulator	ontrol Room In-Plant
Testing Method:SimulateAlternate PathImage: PerformImage: SRO Only	h: \Box Yes \boxtimes Noy: \boxtimes Yes \Box No
Time Critical: 🗌 Yes 🛛 No	
Estimated Time to Complete: 20 minutes Actua	l Time Used: minutes
References: EP-AA-112-100-F-01, rev F; EP-AA-113,	rev 7; EP-AA-113-F-03, rev B
EVALUATION SUMMARY: Were all the Critical Elements performed satisfactorily?	Yes No
The operator's performance was evaluated against the st determined to be:	andards contained in this JPM, and has been Unsatisfactory
Comments:	
Evaluator's Name:	(Print)
Evaluator's Signature:	Date:

INITIAL CONDITIONS

- 1. You are the Station Emergency Director.
- 2. A General Emergency has been declared.
- 3. There is an offsite release in progress.
- 4. Fuel Failure has occurred, together with a failure of the RCS.
- 5. Containment is currently being challenged.
- 6. The TSC has NOT been activated, but the appropriate EAL has been declared.
- 7. An Emergency life saving operation MUST be performed.
- 8. The operation will take between 15 and 20 minutes in a 100 R/hr field (CDE) with unknown fission product gas concentration in the room.
- 9. The operation requires two people to enter the field.
- 10. Fred Mertz and Harvey Korman have volunteered.
- 11. Fred and Harvey have never received an emergency exposure before.
- 12. Authorization for Emergency Exposure (EP-AA-113-F-02 forms) have been filled out for Fred and Harvey.

INITIATING CUE

1. Perform a KI assessment, per section 4.4 of EP-AA-113.