

Beaver Valley Power Station Route 168 P.O. Box 4 Shippingport, PA 15077-0004

L-07-110 August 8, 2007

Ms. Kareen Milcic Permits Chief Water Management Program Southwest Region Pennsylvania Department of Environmental Protection 400 Waterfront Drive Pittsburgh, PA 15222-4745

# Renewal Application for Beaver Valley Power Station NPDES Outfall 012 <u>NPDES Permit No. PA0025615</u>

Dear Ms. Milcic:

Enclosed please find three copies of the Pennsylvania Department of Environmental Protection (DEP) NPDES Permit renewal application for First Energy Nuclear Operating Company (FENOC) Beaver Valley Power Station NPDES Outfall 012. The evaporative coolers serving the HVAC unit for the Emergency Response Facility were replaced in December of 2006. Sampling was completed in January of 2007. This should complete our application package.

Should you have any questions regarding the attached documents, please direct them to Mr. Michael Banko, at 724-682-4117.

Sincerely,

Kavin L. Ostrowske

Kevin L. Ostrowski Director, Site Operations

Enclosures

cc: US Nuclear Regulatory Commission (Note: No new NRC commitments are contained in this submittal.)

NER

1001

Applicant Name: FirstEnergy Nuclear Operating Company (FENOC) Beaver Valley Power Station



#### COMMONWEALTH OF PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION BUREAU OF WATER STANDARDS AND FACILITY REGULATION

# ANALYSIS RESULTS TABLE POLLUTANT GROUP 2 MODULE 5

					MODOL						
Befor	e completing this form, read the s	step-by-step	instruction	s provided in A	Appendix 1	•					
APPL	CANT NAME FirstEnergy N	luclear Opera	ating Comp	any - Beaver V	alley Powe	er Station					udhaaan adk in
	Outfall Number Outfall 012     Intake Sampling Results - Op     Background Sampling Result	(Show locatio tional (Specif s - Optional (S	n of samplin y Source: Specify Loca	g point on Line ) ition:)	Drawing)		· · ·			· ·	
	Treatment Facility Influent Sa	mpling Result	ts (Show loc	ation of samplir	ng point on	Line Drawing)					•
	New Discharge (Basis for Info	ormation:	)								
	Bypass or Sewer System Ove	erflow (Descri	be:)	<u>1.</u>		•	·······		, I	· · ·	
POLLUTANT GROUP 2 1. MDL Metals Metals 2. E 1. MDL Used* (µg/L) Used*		2. EPA Method	a. Max Daily Value		3. Level Present b. Average of Analysis		с.	4. Units		5. Coefficient of Effluent	
		Used* (µg/L)	Number Used	Concentration	Mass	Concentration	Mass	Number of Analysis	Concentration	Mass	Variability (CV)
1M	Antimony, Total	2	200.7	15	0.0001			1	ug/l	lb/day	
2M	Arsenic, Total	10	200.7	14	0.0001			1	ug/l	lb/day	
ЗM	Beryllium, Total	2	200.7	2	0.00002			· 1	ug/l	lb/day	
4M	Cadmium, Total	2	200.7	ND	·			1	ug/l	lb/day	
5M	Chromium III	2	200.7	30	0.0003	6	0.0001	6	ug/l	lb/day	
5M	Chromium VI	10	218.4	ND ·				1	ug/l	lb/day	
6M	Copper, Total	<b>2</b> .	200.7	135	0.0011	57	0.0005	7	ug/l	lb/day	
7M	Lead, Total	2	200.7	ND	. <b></b>			1	ug/l	lb/day	
8M	Mercury, Total	0.2	245.2	ND				1	ug/l	lb/day	
9M	Nickel, Total	5	200.7	ND				. 1	ug/i	lb/day	
10M	Selenium, Total	8	200.7	ND				1	ug/l	lb/day	
11M	Silver, Total	1	200.7	8	0.0001			1	ug/i	lb/day	

3. If other data is available (i.e., DMR data, etc.), the past year of data may be used to determine 3a, 3b, 3c, and 5.

3.a. Maximum Daily Value - Report the highest daily value or daily average value from the last year of data. Report both mass and concentration.

3.b. Average of Analysis – Determine the average of all samples taken within the past year. Report both mass and concentration.

3.c. A minimum of 3 Sampling Events required for process wastewater discharges, and a minimum of 1 Sampling Event for all other discharges, treatment facility influent, intake water and background.

- 1 -

It is in the applicant's interest to achieve the lowest level of detection possible. This will minimize uncertainty and therefore the need for additional analysis or potential for establishing a large number of effluent limits and/or monitoring requirements in the final NPDES permit.

#### 3800-PM-WSFR0008h Rev. 3/2006 Module 5

#### Applicant Name: FirstEnergy Nuclear Operating Company (FENOC) Beaver Valley Power Station

POLLUTANT GROUP 2 Metals					3. Level Present						
		1. MDL	2. EPA Method Number Used	a. Max Daily Value		b. Average of Analysis		c.	4. Units		5. Coefficient of Effluent
		Used* (µg/L)		Concentration	Mass	Concentration	Mass	Number of Analysis	Concentration	Mass	Variability (CV)
12M	Thallium, Total	. 10	200.7	ND				1	ug/l	lb/day	
13M	Zinc, Total	8	200.7	408	0.0034	148	0.0012	7	ug/l	lb/day	
14M	Cyanide, Total						<u> </u>				
14M	Cyanide, Free						<u></u>				
15M	Phenols, Total						•				

3. If other data is available (i.e., DMR data, etc.), the past year of data may be used to determine 3a, 3b, 3c, and 5.

3.a. Maximum Daily Value – Report the highest daily value or daily average value from the last year of data. Report both mass and concentration.

3.b. Average of Analysis – Determine the average of all samples taken within the past year. Report both mass and concentration.

3.c. A minimum of 3 Sampling Events required for process wastewater discharges, and a minimum of 1 Sampling Event for all other discharges, treatment facility influent, intake water and background.

2

It is in the applicant's interest to achieve the lowest level of detection possible. This will minimize uncertainty and therefore the need for additional analysis or potential for establishing a large number of effluent limits and/or monitoring requirements in the final NPDES permit.

#### 3800-PM-WSFR0008g Rev. 3/2006 Module 4

 $\square$ 

# Applicant Name: FirstEnergy Nuclear Operating Company (FENOC) - Beaver Valley Power Station

Outfall: 012

#### COMMONWEALTH OF PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION BUREAU OF WATER STANDARDS AND FACILITY REGULATION

## ANALYSIS RESULTS TABLE POLLUTANT GROUP 1 MODULE 4

Before completing this form, read the step-by-step instructions provided in Appendix 1.

APPLICANT NAME FirstEnergy Nuclear Operating Company (FENOC) - Beaver Valley Power Station

**Outfall Number** <u>012</u> (Show location of sampling point on Line Drawing)

Intake Sampling Results - Optional (Specify Source: \_\_\_\_)

Background Sampling Results - Optional (Specify Location of Sample: I

Treatment Facility Influent Sampling Results (Show location of sampling point on Line Drawing)

New Discharge (Basis for Information: \_\_\_\_\_)

Bypass or Sewer System Overflow (Describe: \_\_\_\_\_)

		1. LEV	2. UI	3.				
POLLUTANT GROUP 1	a. Maximun	n Daily Value	b. Average	of Analysis	c. No. of	а.		Coefficient of Effluent Variability (CV)
	(1) Concentration	(2) Mass	(1) Concentration	(2) Mass	Analysis	Concentration	<ul> <li>b. Mass</li> </ul>	
Biochemical Oxygen Demand, BOD	14	0.117			1	mg/l	lb/day	
Chemical Oxygen Demand, COD	<20	·			1	mg/l	lb/day	
Hardness (CaCO <sub>3</sub> )	240	2.00			1	CaCO3	lb/day	
Total Suspended Solids, TSS	<4				1	mg/l	lb/day	
Total Dissolved Solids, TDS	512	4.27	461	3.84	6	mg/l	lb/day	
Ammonia as N	<0.1				1	. mg/i	lb/day	-
Nitrate-Nitrite (as N)	3.00	0.025			1	mg/l	lb/day	
Total Kjeldahl Nitrogen (TKN)	0.416	0.003		·	1	mg/l	lb/day	
Phosphorus (as P), Total	<0.05				1	mg/l	lb/day	
Temperature winter	17.9 Value			Value	1	С		
Temperature summer	Va	lue	Va	alue	1	С		
рН	Min. 7.75 Max. 8.58				7	Standard units	Standard units	Standard units

1.a. Maximum Daily Value - Report the highest daily value or daily average value from the last year of data. Report both mass and concentration.

1.b. Average of Analysis - The average of all values within the last year and report both the mass and concentration.

1.c. A minimum of 3 Sampling Events required for process wastewater discharges, and a minimum of 1 Sampling Event for all other discharges, treatment facility influent, intake water and background.

3800-PM-WSFR0008g Rev. 3/2006 Module 4

### Applicant Name: FirstEnergy Nuclear Operating Company (FENOC) -Beaver Valley Power Station

Outfall	012	

			2. EPA Method Number	3. Level Present					· · · · · · · · · · · · · · · · · · ·		
POLLUTANT GROUP 1	Believed	1. MDL		a. Max Daily Value		b. Average of Analysis		c. Number of	4. Units		of Effluent Variability
· · · · · · · · · · · · · · · · · · ·	Absent	(µg/L)	Used	Concentration	Mass	Concentration	Mass	Analysis	Concentration	Mass	(CV)
Color	$\boxtimes$	25	110.2	ND				1	Units		1
Fecal Coliform	$\square$	2	SM9222 D	ND				1.	counts/100ml		
Fluoride		40	340.2	0.3	0.003			1 .	mg/l	lb/day	
Oil and Grease	$\square$	5000	1664A	ND				1	mg/l	lb/day	
Bromide	$\square$	50	300	ND				1	mg/L	lb/day	
Chlorine, Total Residual	$\square$	0.05	330.5	ND				, 1	mg/L	lb/day	
Sulfate		100	300	109	0.909		1 .	1	mg/i	lb/day	· .
Sulfide	$\square$	2000	9030A	ND				<u>e 1</u>	mg/l	lb/day	
Sulfite	$\square$	2000	377.1	ND				1	∍ mg/l	lb/day	
Surfactants	$\square$	0.1	5540C	ND	· ·			1	mg/l	lb/day	
Aluminum, Total		4	200.7	36	0.0003			1	ug/l	lb/day	
Barium, Total		15	200.7	63	0.0005			1	ug/l	lb/day	
Boron, Total		50	212.3	73	0.0006			1	ug/l	lb/day	
Cobalt, Total		2	200.7	13	0.0001			1	ug/l	lb/day	
Iron, Total		2	200.7	50	0.0004			1	ug/l	lb/day	
Iron, Dissolved		2	200.7	16	0.0001			. 1 .	ug/l	lb/day	
Manganese, Total		4	200.7	14	0.0001			· 1	ug/l	lb/day	
Radioactivity (Total Alpha and Beta)		1.0	900.0	2.9				1	pCi/L		
Total Organic Carbon, TOC		1000	9060	<1				1	mg/i	lb/day	· · ·
Radium, Total		1.8	903.1 & Ra-05	· ND				. 1	pCi/L		
Magnesium		30	200.7	17100	0.143			1	ug/i	lb/day	
Molybdenum		10	200.7	1,6	0.0001			1	ug/l	lb/day	
Tin, Total	$\square$	80	200.7	ND				1	ug/l	lb/day	
Titanium, Total		2	200.7	3	0.00003			1	ug/i	lb/day	

3. If other data is available (i.e., DMR data, etc.), the past year of data may be used to determine 3a, 3b, 3c, and 5.

3.a. Maximum Daily Value – Report the highest daily value or daily average value from the last year of data. Report both mass and concentration.

3.b. Average of Analysis – Determine the average of all samples taken within the past year. Report both mass and concentration.

3.c. A minimum of 3 Sampling Events required for process wastewater discharges, and a minimum of 1 Sampling Event for all other discharges, treatment facility influent, intake water and background.

\* It is in the applicant's interest to achieve the lowest level of detection possible. This will minimize uncertainty and therefore the need for additional analysis or potential for establishing a large number of effluent limits and/or monitoring requirements in the final NPDES permit.