



Tennessee Valley Authority, Post Office Box 2000, Soddy-Daisy, Tennessee 37379-2000

August 14, 2007

State of Tennessee
Department of Environment and Conservation
Division of Water Pollution Control
Enforcement & Compliance Section
6th Floor, L & C Annex
401 Church Street
Nashville, Tennessee 37243-1534

Dear Mr. Hannah:

SEQUOYAH NUCLEAR PLANT - DISCHARGE MONITORING REPORT FOR JULY 2007

Enclosed is the July 2007 Discharge Monitoring Report for Sequoyah Nuclear Plant. Please contact me at (423) 843-6700 if you have any questions or comments.

Sincerely,

Stephanie A. Howard
Principal Environmental Engineer
Signatory Authority for
J. Randy Douet
Site Vice President
Sequoyah Nuclear Plant

Enclosure

cc (Enclosure):

Chattanooga Environmental Assistance Center
Division of Water Pollution Control
State Office Building, Suite 550
540 McCallie Avenue
Chattanooga, Tennessee 37402-2013

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE SB-2A)
SODDY - DAISY TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Location **HAMILTON COUNTY**

MAJOR
 (SUBR 01)

TN0026450 **101 G**
 PERMIT NUMBER DISCHARGE NUMBER

F - FINAL
 DIFFUSER DISCHARGE
 EFFLUENT

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
07	07	01	07	07	31

From

To

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form.

ATTN: Stephanie A. Howard

PARAMETER	SAMPLE MEASUREMENT / PERMIT REQUIREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
TEMPERATURE, WATER DEG. CENTIGRADE 00010 Z 0 0 INSTREAM MONITORING	SAMPLE MEASUREMENT	*****	*****	**	*****	*****	30.2	04	0	31 / 31	MODEL
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	30.5 DAILY MX	DEG. C.		SEE PERMIT	CK REQ
TEMPERATURE, WATER DEG. CENTIGRADE 00010 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****	42.1	04	0	31 / 31	RCORDR
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	REPORT DAILY MX	DEG. C.		SEE PERMIT	CK REQ
TEMP. DIFF. BETWEEN SAMP. & UPSTRM DEG.C 00016 1 S 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****	2.7	04	0	31 / 31	CALCTD
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	3.0 DAILY MX	DEG. C.		CONTINUOUS	CALCTD
PH 00400 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	**	7.3	*****	7.6	12	0	6 / 31	GRAB
	PERMIT REQUIREMENT	*****	*****	****	6.0 MINIMUM	*****	9.0 MAXIMUM	SU		WEEKLY	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	**	*****	4	4	19	0	1 / 31	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	30 MO AVG	100 DAILY MX	MG/L		MONTHLY	GRAB
OIL AND GREASE 00556 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	**	*****	<6	<6	19	0	1 / 31	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	15 MO AVG	20 DAILY MX	MG/L		MONTHLY	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	1629	03	*****	*****	*****	**	0	31 / 31	RCORDR
	PERMIT REQUIREMENT	*****	REPORT DAILY MX	MGD	*****	*****	*****	****		CONTINUOUS	RCORDR

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER J. Randy Douet Site Vice President TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT <i>Stephanie A. Howard</i> Principal Environmental Engineer	TELEPHONE		DATE		
			423	843-6700	07	08	14
			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 No closed mode operation. The following information is included in an attachment: CCW data.

July 2007 DMR Attachment

July 2007 CCW Data

CCW TRENCH				
Date/Time Collected	Extractable Petroleum Hydrocarbons	Analysis Date/Time	Analyst	Method
07/12/2007 @ 1035	0.44 mg/L	07/17/2007 @ 0915	TSF	EPA 8015
CCW CHANNEL				
Date/Time Collected	Extractable Petroleum Hydrocarbons	Analysis Date/Time	Analyst	Method
07/12/2007 @ 1030	<0.10 mg/L	07/17/2007 @ 0926	TSF	EPA 8015

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE SB-2A)
SODDY - DAISY TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Location **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MAJOR
 (SUBR 01)

Form Approved.
 OMB No. 2040-0004

TN0026450 **101 G**
 PERMIT NUMBER DISCHARGE NUMBER

F - FINAL
 DIFFUSER DISCHARGE
 EFFLUENT

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
07	07	01	07	07	31


From To

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

ATTN: Stephanie A. Howard

PARAMETER	SAMPLE MEASUREMENT / PERMIT REQUIREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION			NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM				UNITS
CHLORINE, TOTAL RESIDUAL	SAMPLE MEASUREMENT	*****	*****	**	*****	0.022	0.037	19	0	26 / 31	GRAB
50060 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	0.10 MO AVG	0.10 INST MAX	MG/L		WEEK-DAYS	CALCTD
TEMPERATURE - C, RATE OF CHANGE	SAMPLE MEASUREMENT	*****	0	62	*****	*****		**	0	31 / 31	CALCTD
82234 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	2 DAILY MX	DEG C/HR	*****	*****	*****	***		CONTINUOUS	CALCTD
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER J. Randy Douet Site Vice President TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 Stephanie A. Howard Principal Environmental Engineer SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
			AREA CODE	NUMBER	YEAR	MO	DAY
			423	843-6700	07	08	14

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

The following injections occurred: 1. Biodetergent 73551 (max. calc. conc. was 0.018mg/L--limit 2.0mg/L) 2. MSW-101 (max. calc. conc. was 0.091mg/L--limit 0.2mg/L) 3. H-150M (max. calc. conc. was 0.036mg/L--limit 0.050mg/L) 4. H-150M (low detection level analytical method was <0.020mg/L--limit 0.050mg/L)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE SB-2A)
SODDY - DAISY TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Location **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MAJOR
(SUBR 01)

Form Approved.
OMB No. 2040-0004

TN0026450 **101 T**
 PERMIT NUMBER DISCHARGE NUMBER

F - FINAL
BIOMONITORING FOR OUTFALL 101

MONITORING PERIOD
 From

YEAR	MO	DAY
07	07	01

 To

YEAR	MO	DAY
07	07	31

EFFLUENT
 *** NO DISCHARGE ***

NOTE: Read instructions before completing this form.

ATTN: Stephanie A. Howard

PARAMETER	X	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
IC25 STATRE 7DAY CHR CERIODAPHNIA	SAMPLE MEASUREMENT	*****	*****	**	Monitoring Not Required	*****	*****	23			
TRP3B 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	45.2 MINIMUM	*****	*****	PERCENT		SEE PERMIT	COMPOS
IC25 STATRE 7DAY CHR PIMEPHALES	SAMPLE MEASUREMENT	*****	*****	**	Monitoring Not Required	*****	*****	23			
TRP6C 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	45.2 MINIMUM	*****	*****	PERCENT		SEE PERMIT	COMPOS
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER J. Randy Douet Site Vice President TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
		723 843-6700		07	08	14
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 Toxicity was not sampled in July 2007.

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name TVA - SEQUOYAH NUCLEAR PLANT
 Address P.O. BOX 2000
(INTEROFFICE SB-2A)
SODDY - DAISY TN 37384
 Facility TVA - SEQUOYAH NUCLEAR PLANT
 Location HAMILTON COUNTY

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MAJOR
 (SUBR 01)

Form Approved.
 OMB No. 2040-0004

TN0026450 101 Y
 PERMIT NUMBER DISCHARGE NUMBER

F - FINAL
 ANNUAL MONITORING (PCBS)
 EFFLUENT

MONITORING PERIOD
 From

YEAR	MO	DAY
06	08	01

 To

YEAR	MO	DAY
07	07	31

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form.

ATTN: Stephanie A. Howard

PARAMETER	X	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
POLYCHLORINATED BIPHENYLS	SAMPLE MEASUREMENT	*****	*****	**	*****	*****	<0.0	19	0	1 / 365	GRAB
39521 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	0.0	MG/L		ANNUAL	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER J. Randy Douet Site Vice President TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
		423	843-6700	07	08	14
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PCB samples were taken on 07/05/2007 @ 1035.

Name TVA - SEQUOYAH NUCLEAR PLANT
 Address P.O. BOX 2000
(INTEROFFICE SB-2A)
SODDY - DAISY TN 37384
 Facility TVA - SEQUOYAH NUCLEAR PLANT
 Location HAMILTON COUNTY

(SUBR 01)

OMB No. 2040-0004

TN0026450 103 G
 PERMIT NUMBER DISCHARGE NUMBER

F - FINAL

LOW VOL. WASTE TREATMENT POND

MONITORING PERIOD

EFFLUENT

From

YEAR	MO	DAY
07	07	01

 To


YEAR	MO	DAY
07	07	31

*** NO DISCHARGE ***

ATTN: Stephanie A. Howard

NOTE: Read instructions before completing this form.

PARAMETER	X	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
PH	SAMPLE MEASUREMENT	*****	*****	**	7.4	*****	9.0	12	0	16 / 31	GRAB
00400 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	**	6.0 MINIMUM	*****	9.0 MAXIMUM	SU		THREE/ WEEK	GRAB
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	68	97	26	*****	10	14	19	0	4 / 31	GRAB
00530 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	380 MO AVG	1250 DAILY MX	LBS/DY	*****	30 MO AVG	100 DAILY MX	MG/L		WEEKLY	GRAB
OIL AND GREASE	SAMPLE MEASUREMENT	<44	<54	26	*****	<6	<8	19	0	4 / 31	GRAB
00556 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	190 MO AVG	250 DAILY MX	LBS/DY	*****	15 MO AVG	20 DAILY MX	MG/L		WEEKLY	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	0.823	0.893	03	*****	*****	*****	**	0	31 / 31	TOTALZ
50050 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT MO AVG	REPORT DAILY MX	MGD	*****	*****	*****	**		SEE PERMIT	TOTALZ
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER J. Randy Douet Site Vice President TYPED OR PRINTED	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 Stephanie A. Howard Principal Environmental Engineer SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
			423	843-6700	07	08	14
			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

Name TVA - SEQUOYAH NUCLEAR PLANT
Address P.O. BOX 2000
(INTEROFFICE SB-2A)
SODDY - DAISY TN 37384
Facility TVA - SEQUOYAH NUCLEAR PLANT
Location HAMILTON COUNTY

TN0026450 107 G
PERMIT NUMBER DISCHARGE NUMBER

F - FINAL
METAL CLEANING WASTE POND
EFFLUENT

MONITORING PERIOD

From

YEAR	MO	DAY
07	07	01

 To

YEAR	MO	DAY
07	07	31

*** NO DISCHARGE ***

ATTN: Stephanie A. Howard

NOTE: Read instructions before completing this form.

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
PH		*****	*****	**		*****		12			
00400 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	6.0 MINIMUM	*****	9.0 MAXIMUM	SU		DAILY	GRAB
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		19			
00530 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	30 DAILY MX	MG/L		DAILY	COMPOS
OIL AND GREASE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		19			
00556 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	15 DAILY MX	MG/L		DAILY	GRAB
PHOSPHORUS, TOTAL (AS P)	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		19			
00665 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	1.0 DAILY MX	MG/L		DAILY	COMPOS
COPPER, TOTAL (AS CU)	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		19			
01042 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	1.0 DAILY MX	MG/L		DAILY	COMPOS
IRON, TOTAL (AS FE)	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		19			
01045 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	1.0 DAILY MX	MG/L		DAILY	COMPOS
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT			03	*****	*****	*****	**			
50050 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT MO AVG	REPORT DAILY MX	MGD	*****	*****	*****	****		DAILY	CALCTD

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER J. Randy Douet Site Vice President TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Stephanie A. Howard Principal Environmental Engineer SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
			423	843-6700	07	08	14
			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

No Discharge this Period

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE SB-2A)
SODDY - DAISY TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Location **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MAJOR (SUBR 01)

Form Approved.
 OMB No. 2040-0004

TN0026450 110 G
 PERMIT NUMBER DISCHARGE NUMBER

F - FINAL
 RECYCLED COOLING WATER
 EFFLUENT

MONITORING PERIOD
 From **07 07 01** To **07 07 31**

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form.

ATTN: Stephanie A. Howard

PARAMETER	SAMPLE MEASUREMENT / PERMIT REQUIREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION			NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
TEMPERATURE, WATER DEG. CENTIGRADE 00010 Z 0 0 INSTREAM MONITORING	SAMPLE MEASUREMENT	*****	*****	04	*****	*****				
	PERMIT REQUIREMENT	*****	*****	DEG C	*****	*****	38.3 DAILY MX	DEG C	DAILY	GRAB-4
PH 00400 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	**		*****		12		
	PERMIT REQUIREMENT	*****	*****	***	6.0 MINIMUM	*****	9.0 MAXIMUM	SU	WEEKLY	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		19		
	PERMIT REQUIREMENT	*****	*****	***	*****	*****	30 DAILY MX	MG/L	DAILY	COMPOS
OIL AND GREASE 00556 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		19		
	PERMIT REQUIREMENT	*****	*****	***	*****	*****	15 DAILY MX	MG/L	DAILY	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT			03	*****	*****	*****	**		
	PERMIT REQUIREMENT	REPORT MO AVG	REPORT DAILY MX	MGD	*****	*****	*****	***	DAILY	CALCTD
CHLORINE, TOTAL RESIDUAL 50060 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		19		
	PERMIT REQUIREMENT	*****	*****	***	*****	*****	0.10 DAILY MX	MG/L	WEEKLY	GRAB-4
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER J. Randy Douet Site Vice President TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT <i>Stephanie A. Howard</i>	TELEPHONE		DATE		
			AREA CODE	NUMBER	YEAR	MO	DAY
			423	843-6700	07	08	14

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

No Discharge this Period

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE SB-2A)
SODDY - DAISY TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Location **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MAJOR
 (SUBR 01)

Form Approved.
 OMB No. 2040-0004

TN0026450 **110 T**
 PERMIT NUMBER DISCHARGE NUMBER

F - FINAL
 RECYCLED COOLING WATER
 EFFLUENT

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
07	07	01	07	07	31

From

To

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form.

ATTN: Stephanie A. Howard

PARAMETER	X	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
IC25 STATRE 7DAY CHR CERIODAPHNIA	SAMPLE MEASUREMENT	*****	*****	**		*****	*****	23			
TRP3B 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	***	45.2 MINIMUM	*****	*****	PERCENT		SEMI ANNUAL	COMPOS
IC25 STATRE 7DAY CHR PIMEPHALES	SAMPLE MEASUREMENT	*****	*****	**		*****	*****	23			
TRP6C 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	***	45.2 MINIMUM	*****	*****	PERCENT		SEMI ANNUAL	COMPOS
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER J. Randy Douet Site Vice President TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	<i>Stephanie A. Howard</i> Principal Environmental Engineer SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
			423	843-6700	07	08	14
			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

No Discharge this Period

Name **TVA - SEQUOYAH NUCLEAR PLANT**
Address **P.O. BOX 2000**
(INTEROFFICE SB-2A)
SODDY - DAISY TN 37384
Facility **TVA - SEQUOYAH NUCLEAR PLANT**
Location **HAMILTON COUNTY**

TN0026450 **116 G**
PERMIT NUMBER DISCHARGE NUMBER

MONITORING PERIOD
From **07 07 01** To **07 07 31**

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form.

ATTN: Stephanie A. Howard

PARAMETER	X	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
DEBRIS, FLOATING (SEVERITY)	SAMPLE MEASUREMENT	*****	*****	**	*****	*****	0	9A	0	1 / 31	VISUAL
01345 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	***	*****	*****	REPORT MO TOTAL	PASS=0 FAIL=1		SEE PERMIT	VISUAL
OIL AND GREASE VISUAL	SAMPLE MEASUREMENT	*****	0	94	*****	*****	*****	**	0	1 / 31	VISUAL
84066 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	REPORT MO TOTAL	YES=1 NO=0	*****	*****	*****	***		SEE PERMIT	VISUAL
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER J. Randy Douet Site Vice President TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	<i>Stephanie A. Howard</i> Principal Environmental Engineer SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
			423 843-6700	07 08 14			
			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
Operations performs visual inspections for floating debris and oil and grease during all backwashes.

Name TVA - SEQUOYAH NUCLEAR PLANT
 Address P.O. BOX 2000
 (INTEROFFICE SB-2A)
SODDY - DAISY TN 37384
 Facility TVA - SEQUOYAH NUCLEAR PLANT
 Location HAMILTON COUNTY

TN0026450 117 G
 PERMIT NUMBER DISCHARGE NUMBER

MONITORING PERIOD

From

YEAR	MO	DAY
07	07	01

 To

YEAR	MO	DAY
07	07	31

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form.

ATTN: Stephanie A. Howard

PARAMETER	X	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
DEBRIS, FLOATING (SEVERITY)	SAMPLE MEASUREMENT	*****	*****	**	*****	*****	0	9A	0	1 / 31	VISUAL
01345 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	REPORT MO TOTAL	PASS=0 FAIL=1		SEE PERMIT	VISUAL
OIL AND GREASE VISUAL	SAMPLE MEASUREMENT	*****	0	94	*****	*****	*****	**	0	1 / 31	VISUAL
84066 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	REPORT MO TOTAL	YES=1 NO=0	*****	*****	*****	***		SEE PERMIT	VISUAL
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER J. Randy Douet Site Vice President TYPED OR PRINTED	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	<i>Stephanie A. Howard</i> Principal Environmental Engineer SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
			AREA CODE	NUMBER	YEAR	MO	DAY
			423	843-6700	07	08	14

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 Operations performs visual inspections for floating debris and oil and grease during all backwashes.

Name TVA - SEQUOYAH NUCLEAR PLANT
Address P.O. BOX 2000
(INTEROFFICE SB-2A)
SODDY - DAISY TN 37384
Facility TVA - SEQUOYAH NUCLEAR PLANT
Location HAMILTON COUNTY

TN0026450 118 G
PERMIT NUMBER DISCHARGE NUMBER

MONITORING PERIOD
From

YEAR	MO	DAY
07	07	01

 To

YEAR	MO	DAY
07	07	31

F - FINAL
WASTEWATER & STORM WATER
EFFLUENT

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form.

ATTN: Stephanie A. Howard

PARAMETER	X	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
OXYGEN, DISSOLVED (DO) 00300 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	**		*****	*****	19			
	PERMIT REQUIREMENT	*****	*****	****	2.0 DAILY MN	*****	*****	MG/L		TWICE/ WEEK	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		19			
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	100 DAILY MX	MG/L		TWICE/ WEEK	GRAB
SOLIDS, SETTLEABLE 00545 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		25			
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	1.0 DAILY MX	ML/L		ONCE/ MONTH	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT			03	*****	*****	*****	**			
	PERMIT REQUIREMENT	REPORT MO AVG	REPORT DAILY MX	MGD	*****	*****	*****	*		ONCE/ BATCH	ESTIMA
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER J. Randy Douet Site Vice President TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	<i>Stephanie A. Howard</i> Principal Environmental Engineer	TELEPHONE		DATE		
			423	843-6700	07	08	14
		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
During this reporting period, there has been no flow from the Dredge Pond other than that resulting from rainfall.