

**TRAINING PROGRAM:** 

# **OPERATOR TRAINING**

TITLE:

# **RPS Motor Generator Startup**

New Materia	al 🛛 Minor	Revision	Major Revision	Cancellation
REASON FOR RE THIS DOCUMEN	<u>EVISION</u> : <u>T REPLACES</u> :	Clarification f	for NRC Exam. 27100, REV. 0	
REVIEW / APPR	OVAL (Print N	ame): TEAI	R Approval (TEAR #	)
Prepared By:				
_		**Preparer		Date
<b>Ops Review</b> <sup>++:</sup>	]	R. T. Errington		7/27/06
_	Technical Revie	wer (e.g., SME, line	e management)	Date
Validated By:		Steve Reeves		7-13-06

vanuarea Dy.		/ 15 00
	Training Representative	Date
Approved By:	M. L. Chase	8/7/06
	<sup>+</sup> Discipline Training Supervisor	Date

Approval Date:\*

\* Indexing Information

\*\* The requirements of the Training Material Checklist have been met.

<sup>+</sup> Indicates that the LP has been reviewed by the Training Supervisor for inclusion of Management Expectations and items referenced on TQJA-201- DD06, Training Material Checklist.

<sup>++</sup> Indicates that Operations has reviewed and approved this material for exam use.

#### **FLEET/REGIONAL PROGRAM CONCURRENCE:**

Fleet	ENS ENN	Not Applicable		
DATE TRANSMITTED TO RM	INITIAL RECEIPT BY RM (DATE/INITIAL)	RETURNED FOR CORRECTIONS (DATE/INITIAL)	RETURN RECEIPT (DATE/INITIAL)	FINAL ACCEPTANCE BY RM (DATE/INITIALS)



# **Generic Instructions**

- 1. Standards and cues for valve operation:
  - a. MOVs:
    - "Turn the valve's handswitch on (panel #)(section#, as applicable) in the (clockwise or 1) counter-clockwise) direction and observe that the valve's red light is (energized or de-energized) and its green light is (energized or de-energized)".
  - b. Manual valves
    - "Turn the valve's handwheel (or other manual operating device) in the (clockwise or 1) counter-clockwise) direction until resistance is felt."
- 2. The Evaluator should indicate simulated analog gauge readings by pointing a pen or equivalent to the intended place on the gauge.
- 3. Other methods of simulating control, operation and data collection is at the discretion of the Evaluator.
- 4. It is expected that the candidate shall locate controlled copies of any required procedures and describe how copies of these procedures would be prepared for use in the field. Only at this time should the evaluator give the candidate previously prepared copies of the procedure(s). This entire procedure need only be performed or simulated once during the entire exam. These activities are not required for JPMs conducted in the Simulator.
- 5. Consideration of electrical safety must be made during the performance of certain tasks involving electrical circuits and circuit breakers. The performer should be aware that working on or near energized equipment requires, at a minimum, wearing 100% cotton clothing and low voltage (Class 0) gloves while removing or securing shock hazards such as chains, jewelry, watches and metal-framed eyeglasses. Operating or racking circuit breakers may require additional PPE. Details can be found in Att. 2 of the Electrical Safety Rulebook and General Operating procedure 04-S-04-2 (Operation of Electrical Circuit Breakers)
- 6. Obtain Shift Management's permission before opening any control panel or compartment. Avoid placing any tools, flashlights, pointing devices or any part of your body inside the panel or compartment in a manner that could disturb the operation of any component within or potentially result in an electric shock).
- 7. Use of lasers as a pointing tool requires Engineering's prior approval of the specific tool for safe use in the Control area. (specifically, the laser's emissions must be verified as not interfering with any component's intended operation or function).
- 8. During activities within the CAA, consideration must be given to area dose rates. When in a posted Radiation Area, check your EAD for dose rates and minimize time spent in the area. Entry into High Radiation Areas or Contamination Areas is prohibited.

# Under no circumstances is any candidate allowed to operate any equipment outside the simulator without the permission of the Evaluator and Shift Management.



ENTERGY NUCLEAR Number: GJPM-OPS-C7101

Number: GJPM-OPS-C710 Revision: 0 Page: 3 of 272

JOB PERFORMANCE MEASURE

# <u>C71 Task 1</u>: RPS Motor/Generator Startup

Setting:	Plant (Outside CAA)
<u>Type</u> :	NLO
<u>Task</u> :	NOB-C71-002; NOB-C71-003; NOB-C71-005; CRO-C71-004
<u>K&amp;A</u> :	212000 A2.01: 3.7/3.9; A1.01: 2.8/2.9; A1.03: 2.4/2.5;
	G2.1.30: 3.9/3.4
Safety Function:	Instrumentation (7)
Time Required:	18 minutes
Time Critical:	No
Faulted:	No
Performance:	Simulate
Reference(s):	04-1-01-C71-1
Handout(s):	04-1-01-C71-1
<u># Manipulations:</u>	4
# Critical Steps:	4
<u>Group #</u> :	1

#### Simulator Setup/Required Plant Conditions:

• Area is accessible

#### Safety Concerns:

- Do NOT operate plant equipment.
- Extreme caution should be taken around the RPS Motor Generator Set to prevent accidental contact with the controls.
- Use care when working around or near rotating equipment.
- Adjust which RPS Room to go to based on plant Protected Train.

#### Initial Condition(s):

- The plant is operating at 100% power.
- Repairs have been completed on RPS A(B) Motor/Generator.
- 04-1-01-N32-1 Manual Valve Lineup Checksheet has been completed for C71-PT-N005A – D and C71-PT-N006A - H
- 04-1-01-C71-1 Handswitch Lineup Checksheet, Attachment V, has been completed, as required.
- 04-1-01-C71-1 Electrical Lineup Checksheet, Attachment III, has been completed, as required.
- RPS A(B) Bus is being supplied by the Alternate Feed.

#### Initiating Cue(s):

• You have been directed to perform section 4.1 of the SOI to startup the RPS A(B) Motor/Generator.



ENTERGY NUCLEAR Number: GJPM-OPS-C7101 **Revision: 0** Page: 4 of 272

**JOB PERFORMANCE MEASURE** 

#### **RPS Motor/Generator Startup** <u>C71 Task 1</u>:

#### Notes:

- 1. JPM may be performed on either RPS A or B Motor/Generator, depending on plant conditions.
- 2. Att. 1, on page 10, is a drawing of a typical EPA.

# **Task Overview:**

This task is to perform a startup of the RPS Motor Generator and align the RPS Bus to the Normal Supply per the SOI. This task is performed to return RPS power to the Normal Supply.

# **Task Justification**

The following JPM does not meet the minimum requirements of 14-S-02-18. It either does not have the required number of manipulations or critical steps. However it has been deemed a valid JPM in accordance with 14-S-02-18 step 6.3.13 due to the following:

The task has high importance, significant consequences if improperly performed and/or complexity in controlling important plant parameters such as reactivity or reactor water level during transient conditions.

#### AND

This is a trip critical evolution performed by the non-licensed operators.

Due to a possible loss of offsite power the operator would be required to engerize the RPS system to restore to ability to insert control rods. This task requires the operator to restart the RPS electrical system.



JOB PERFORMANCE MEASURE

# <u>C71 Task 1</u>: RPS Motor/Generator Startup

# **<u>Tasks</u>** : Critical tasks are underlined, italicized, and denoted by an (\*)

Note : The sequence for the following steps *is not* critical.

Check open GENERATOR OUTPUT circuit breaker on panel 1C71-S001A(B) on MG set
 <u>Standard</u>: Verifies that the circuit breaker's operating handle is in the "down" position, indicating an open breaker
 <u>Cue</u>: Circuit breaker handle is down.

Notes:

 Check open RPS MG A(B) Output Breakers 1C71-S003A(B) and 1C71-S003C(D)
 <u>Standard:</u> Verifies that the EPAs' operating handles are in the "OFF/RESET OPEN" position
 Cue: Circuit breakers are in the OFF position.

Notes:

 Check test switches on RPS MG A(B) output breakers are in the NORM position <u>Standard:</u> Verifies that the "Undervoltage", "Overvoltage" and "Underfrequency" test switches on RPS MG A(B) Output Breakers 1C71-S003A(B) and 1C71-S003C(D) are in the NORM position Cue: All switches in NORM

Notes:

#### Note : The sequence for the following steps *is* critical.

Starts RPS MG A(B)
Standard: Simulates depressing the "MOTOR ON" pushbutton on panel 1C71-S001A(B) until redlight is lit
<u>Cue:</u> Red ON light is lit
<u>Notes:</u>



Number: GJPM-OPS-C7101 Revision: 0 Page: 6 of 272

JOB PERFORMANCE MEASURE

 Check generator output voltage
 <u>Standard:</u> Observes voltmeter on motor generator control panel 1C71-S001A(B) is indicating between 122 and 128 VAC
 <u>Cue</u>: As indicated (if MG is running. 124V if not running)) Notes:

Close GENERATOR OUTPUT circuit breaker
 Standard: Simulates pulling up on the circuit breaker's operating handle on panel 1C71-S001A(B) to close the breaker
 Cue: Circuit breaker handle is up. Notes:

Check 1C71-S003A(B) indicating power coming in and power available to go out <u>Standard</u> Check the ELECT PROT ASSY INPUT and the POWER SUPPLY OUTPUT red lights are lit at the 1C71-S003A(B) ELECTRICAL PROTECTION ASSEMBLY panel

**<u>Cue</u>:** Red lights are lit

Notes:

□ Verify the EPA's trip targets are reset

Standard: Verifies the absence of orange "trip target" lights on the following 1C71-S003A(B) relays:

- -- UNDER VOLTAGE
- -- OVER VOLTAGE
- -- UNDER FREQUENCY

<u>Cue</u>: No orange lights noticed Notes:



Number: GJPM-OPS-C7101 Revision: 0 Page: 7 of 272

JOB PERFORMANCE MEASURE

 Close breaker 1C71-S003A(B)
 Standard: Simulates closing breaker 1C71-S003A(B) by rotating its operating handle counter-clockwise until it snaps into the "ON" position
 Cue: Circuit Breaker handle is in the ON position. Notes:

Check that power is going out of EPA 1C71-S003A(B)
 <u>Standard</u>: Checks that the red ELECT PROT ASSY OUTPUT light on 1C71-S003A(B) is lit
 <u>Cue</u>: Red light is lit
 Notes:

 Check 1C71-S003C(D) indicating power coming in and power available to go out <u>Standard</u> Check the ELECT PROT ASSY INPUT and the POWER SUPPLY OUTPUT red lights are lit at the 1C71-S003C(D) ELECTRICAL PROTECTION ASSEMBLY panel
 Cue: Red lights are lit

<u>Cue</u>: Red lights

Notes:

□ Verify the EPA's trip targets are reset

Standard: Verifies the absence of orange "trip target" lights on the following 1C71-S003C(D) relays:

- -- UNDER VOLTAGE
- -- OVER VOLTAGE
- -- UNDER FREQUENCY

<u>Cue</u>: No orange lights noticed Notes:



ENTERGY NUCLEAR Number: GJPM-OPS-C7101 **Revision: 0** Page: 8 of 272

**JOB PERFORMANCE MEASURE** 

Close breaker 1C71-S003C(D) \* Standard: Simulates closing breaker 1C71-S003C(D) by rotating its operating handle counter-clockwise until it snaps into the "ON" position **<u>Cue</u>**: Circuit Breaker handle is in the ON position. Notes:

Check that power is going out of EPA 1C71-S003C(D) Standard: Checks that the red ELECT PROT ASSY OUTPUT light on 1C71-S003C(D) is lit Cue: Red light is lit Notes:

Check GENERATOR A(B) NORMAL FEED AVAILABLE white light are lit on 1H13-P610 Standard: N/A Cue: RO reports that the white light is lit, and he/she will pick up the task from here Notes:

Task Standard(s): RPS A(B) Motor/Generator is running at rated speed and voltage.

Name: \_\_\_\_\_ Time Start: \_\_\_\_\_ Time Stop: \_\_\_\_\_



JOB PERFORMANCE MEASURE Revision: 0 Page: 9 of 272

Number: GJPM-OPS-C7101

# <u>C71 Task 1</u>: RPS Motor/Generator Startup

Follow-Up Questions & Answers:

Comments:



Number: GJPM-OPS-C11015 **Revision: 01** Page: 10 of 272



Page 10 of 272

**Att. 1 Electric Protective Assembly** 



# **RPS Motor/Generator Startup**

# Give this page to the student

Initial Condition(s):

- The plant is operating at 100% power. •
- Repairs have been completed on RPS A(B) Motor/Generator. •
- 04-1-01-N32-1 Manual Valve Lineup Checksheet has been completed for C71-PT-• N005A - D and C71-PT-N006A - H
- 04-1-01-C71-1 Handswitch Lineup Checksheet, Attachment V, has been completed, as • required.
- 04-1-01-C71-1 Electrical Lineup Checksheet, Attachment III, has been completed, as • required.
- RPS A(B) Bus is being supplied by the Alternate Feed. •

Initiating Cue(s):

- You have been directed to perform section 4.1 of the SOI to startup the RPS A(B) • Motor/Generator.
- This task is not time critical.



**JOB PERFORMANCE** 

**MEASURE** 

#### **TRAINING PROGRAM:**

# **OPERATOR TRAINING**

TITLE:

# **CRD** Pump Suction Filter Rotation

New Material	🔀 Minor Revisi	on	Major Revision	Cancellation
<u>REASON FOR REVISIO</u> THIS DOCUMENT REF	<u>)N</u> : Clari PLACES: GJP	ifications M-OPS-C	for NRC Examinati 211015, rev 0	ion.
REVIEW / APPROVA	L (Print Name):	TEAI	R Approval (TEAR #	# )
Prepared By:				

	**Preparer	Date
<b>Ops Review</b> <sup>++:</sup>	R. T. Errington	7/30/06
	Technical Reviewer (e.g., SME, line management)	Date
Validated By:	Mike Harrower	6/18/06
	Training Representative	Date
A	Marrin Chase	9 2 06
Approved By:	<sup>+</sup> Discipline Training Supervisor	8-3-00 Date
Approval Date:*	Discipline Training Supervisor	Zuit

\* Indexing Information

\*\* The requirements of the Training Material Checklist have been met.

Indicates that the LP has been reviewed by the Training Supervisor for inclusion of Management Expectations and items referenced on TQJA-201- DD06, Training Material Checklist.

<sup>++</sup> Indicates that Operations has reviewed and approved this material for exam use.

#### FLEET/REGIONAL PROGRAM CONCURRENCE:

Fleet	ENS ENN	Not Applicable		
DATE TRANSMITTED TO RM	INITIAL RECEIPT BY RM (DATE/INITIAL)	RETURNED FOR CORRECTIONS (DATE/INITIAL)	RETURN RECEIPT (DATE/INITIAL)	FINAL ACCEPTANCE BY RM (DATE/INITIALS)



# **Generic Instructions**

- 1. Standards and cues for valve operation:
  - a. MOVs:
    - "Turn the valve's handswitch on (panel #)(section#, as applicable) in the (clockwise or counter-clockwise) direction and observe that the valve's red light is (energized or de-energized) and its green light is (energized or de-energized)".
  - b. Manual valves
    - 1) "Turn the valve's handwheel (or other manual operating device) in the (clockwise or counter-clockwise) direction until resistance is felt."
- 2. The Evaluator should indicate simulated analog gauge readings by pointing a pen or equivalent to the intended place on the gauge.
- 3. Other methods of simulating control, operation and data collection is at the discretion of the Evaluator.
- 4. It is expected that the candidate shall locate controlled copies of any required procedures and describe how copies of these procedures would be prepared for use in the field. Only at this time should the evaluator give the candidate previously prepared copies of the procedure(s). This entire procedure need only be performed or simulated once during the entire exam. <u>These activities are not required for JPMs conducted in the Simulator</u>.
- 5. Consideration of electrical safety must be made during the performance of certain tasks involving electrical circuits and circuit breakers. The performer should be aware that working on or near energized equipment requires, at a minimum, wearing 100% cotton clothing and low voltage (Class 0) gloves while removing or securing shock hazards such as chains, jewelry, watches and metal-framed eyeglasses. Operating or racking circuit breakers may require additional PPE. Details can be found in Att. 2 of the Electrical Safety Rulebook and General Operating procedure 04-S-04-2 (Operation of Electrical Circuit Breakers)
- 6. Obtain Shift Management's permission before opening any control panel or compartment. Avoid placing any tools, flashlights, pointing devices or any part of your body inside the panel or compartment in a manner that could disturb the operation of any component within or potentially result in an electric shock).
- 7. Use of lasers as a pointing tool requires Engineering's prior approval of the specific tool for safe use in the Control area. (specifically, the laser's emissions must be verified as not interfering with any component's intended operation or function).
- 8. During activities within the CAA, consideration must be given to area dose rates. When in a posted Radiation Area, check your EAD for dose rates and minimize time spent in the area. Entry into High Radiation Areas or Contamination Areas is prohibited.

# Under no circumstances is any candidate allowed to operate any equipment outside the simulator without the permission of the Evaluator and Shift Management.



ENTERGY NUCLEAR Number: GJPM-OPS-C11015 **Revision: 01** Page: 14 of 272

**JOB PERFORMANCE MEASURE** 

#### **CRD Pump Suction Filter Rotation** <u>C11-1B Task 5</u>:

Setting:	Plant (Inside CAA)
<u>Type</u> :	NLO
Task:	AON-C11-011
<u>K&amp;A</u> :	201001 A2.06: 2.9/2.9
	GENERIC: 2.1.20 – 4.3/4.2
Safety Function:	1, Reactivity Control
Time Required:	15 minutes
Time Critical:	No
Faulted:	No
Performance:	Simulated
Reference(s):	04-1-01-C11-1/5.3
Handout(s):	04-1-01-C11-1/5.3
<u># Manipulations</u> :	5
# Critical Steps:	3
Group:	2

Simulator Setup/Required Plant Conditions:

• CRD Pump Suction Filter Station, Auxiliary Building accessible

Safety Concerns:

- Wear standard safety gear for work in the Auxiliary Building.
- Precautions may be taken against accumulation of radioactive gas on clothing.

#### Initial Condition(s):

The in-service CRD suction water filter indicates the need for rotation •

Initiating Cue(s):

- You have been directed to rotate CRD suction water filters. • • The standby filter is clean.
- Close the inlet valve for the off-going filter.
- A hose is installed on the vent valve for the on-coming filter.
- This task is not time critical. •



JOB PERFORMANCE P MEASURE

# **<u>C11-1B Task 5</u>**: CRD Pump Suction Filter Rotation

# Notes: (Notes to Evaluator)

- Simulate rotation from the filter that is actually in service to the filter that is actually in standby.
- This task is located on 93 ft elevation Auxiliary Building area 9.
- The area is a Radiation Area.

# Task Overview: (Detailed description of task)

The purpose of this task is to rotate the CRD pump suction filters, to prevent the malfunction of and damage to the CRD pumps and the components served by this system.



#### **C11-1B Task 5: CRD Pump Suction Filter Rotation**

# Tasks : Critical tasks are underlined, italicized, and denoted by an (\*)

Note : The sequence for the following steps is critical

 $\square$ Check d-p indicator C11-PDIS-N015 in service Standard: Operator checks instrument valves are lockwired and the iinstrument is indicating. Cue: None Notes: Located on column near CRD Pump B.

NOTE: When the meter is indicating and the instrument root valves are lockwired in position this indicates I&C has placed the instrument in service.

Check closed drain valve C11-F113A(B) for on-coming filter. Standard: Operator checks drain valve closed by slightly rotating handwheel in the clockwise direction until resistance is felt **Cue:** You feel resistance in the clockwise direction Notes:

- Check closed vent valve C11-F112A(B) for on-coming filter. Standard: Operator checks vent valve closed by slightly rotating handwheel in the clockwise direction until resistance is felt **Cue:** You feel resistance in the clockwise direction Notes:
- Check closed drain valve C11-F425A(B) for on-coming filter. Standard: Operator checks drain valve closed by slightly rotating handwheel in the clockwise direction until resistance is felt **<u>Cue</u>**: You feel resistance in the clockwise direction

Notes:



ENTERGY NUCLEAR Number: GJPM-OPS-C11015 **Revision: 01** Page: 17 of 272

**JOB PERFORMANCE MEASURE** 

Check open inlet valve C11-F115A(B) for on-coming filter Standard: Operator checks inlet valve open by slightly rotating handwheel in the counter-clockwise direction until resistance is felt. Cue: Resistance is felt in the counter-clockwise direction. Notes:

Open vent valve C11-F112A(B) for on-coming filter Standard:

- 1) Candidate describes standard fill and vent activities per 04-S-04-1
- 2) Operator opens vent valve by rotating handwheel in the counter-clockwise direction until resistance is felt

Cue: You feel resistance in the counter-clockwise direction Notes:

### **NOTE TO EVALUATOR**

When a non-hardpipe system vent is called for, the standard for successful completion should require the candidate's brief explanation of the need for connecting and routing a vent hose in a manner that complies with radiological control requirements.

Ensure all air is vented from on-coming filter Standard: Operator verifies solid stream of water from vent Cue: Solid stream of water Notes:

\* *Close vent valve C11-F112A(B) for on-coming filter* Standard: Operator closes vent valve by rotating handwheel clockwise direction until resistance is felt Cue: You feel resistance in the clockwise direction Notes:



**MEASURE** 

Slowly open outlet valve C11-F114A(B) for on-coming filter \* Standard: Operator opens outlet valve by rotating handwheel in the counter-clockwise direction until resistance is felt. Cue: You feel resistance in the counter-clockwise direction. Notes:

#### Another Operator is observing C11-PDIS-N015

_*	Slowly close outlet valve C11-F114A(B) for off-going filter
	Standard: Operator slowly closes outlet valve by rotating handwheel in the
	clockwise direction
	<u>Cue</u> : As the other operator Filter DP is stable.
	You feel resistance in the clockwise direction
	Notes: If A filter was placed in-service this will be the B filter valves.

Close inlet valve C11-F115A(B) for off-going filter Standard: Operator closes inlet valve by rotating handwheel in the clockwise direction until resistance is felt **Cue:** You feel resistance in the clockwise direction Notes: If A filter was placed in-service this will be the B filter valves.

Task Standard(s):

CRD Pump Suction Filters have been rotated per 04-1-01-C11-1.

Name: \_\_\_\_\_ Time Start: \_\_\_\_\_ Time Stop: \_\_\_\_\_



**MEASURE** 

ENTERGY NUCLEAR Number: GJPM-OPS-C11015 Revision: 01 Page: 19 of 272

# **<u>C11-1B Task 5</u>**: CRD Pump Suction Filter Rotation

Follow-Up Questions & Answers:

Comments:



# **CRD Pump Suction Filter Rotation**

# Give this page to the student

Initial Condition(s):

• The in-service CRD suction water filter indicates the need for rotation

Initiating Cue(s):

- You have been directed to rotate CRD suction water filters.
  - The standby filter is clean.
- Close the inlet valve for the off-going filter.
- A hose is installed on the vent valve for the on-coming filter.
- This task is not time critical.



**TRAINING PROGRAM:** 

# **OPERATOR TRAINING**

TITLE:

Perform Co	ntrol Room Action	s in Response to I	Fire in Plant
🔀 New Material	Minor Revision	Major Revision	Cancellation
REASON FOR REV THIS DOCUMENT	ISION: NEW JPM REPLACES: N/A	1	
<b>REVIEW / APPRO</b>	VAL (Print Name):	EAR Approval (TEAR #	)
Prepared By:	**D		Dete
Ops Review <sup>++:</sup>	**Preparer		Date

- <b>F</b> =		
-	Technical Reviewer (e.g., SME, line management)	Date
Validated By:		
	Training Representative	Date
Approved By:		
	<sup>+</sup> Discipline Training Supervisor	Date
<b>Approval Date:</b> *		

\* Indexing Information

\*\* The requirements of the Training Material Checklist have been met.

<sup>+</sup> Indicates that the LP has been reviewed by the Training Supervisor for inclusion of Management Expectations and items referenced on TQJA-201- DD06, Training Material Checklist.

<sup>++</sup> Indicates that Operations has reviewed and approved this material for exam use.

#### FLEET/REGIONAL PROGRAM CONCURRENCE:

Fleet	ENS ENN	Not Applicable		
DATE TRANSMITTED TO RM	INITIAL RECEIPT BY RM (DATE/INITIAL)	RETURNED FOR CORRECTIONS (DATE/INITIAL)	RETURN RECEIPT (DATE/INITIAL)	FINAL ACCEPTANCE BY RM (DATE/INITIALS)



# **Generic Instructions**

- 1. Standards and cues for valve operation:
  - a. MOVs:
    - "Turn the valve's handswitch on (panel #)(section#, as applicable) in the (clockwise or 1) counter-clockwise) direction and observe that the valve's red light is (energized or de-energized) and its green light is (energized or de-energized)".
  - b. Manual valves
    - "Turn the valve's handwheel (or other manual operating device) in the (clockwise or 1) counter-clockwise) direction until resistance is felt."
- 2. The Evaluator should indicate simulated analog gauge readings by pointing a pen or equivalent to the intended place on the gauge.
- 3. Other methods of simulating control, operation and data collection is at the discretion of the Evaluator.
- 4. It is expected that the candidate shall locate controlled copies of any required procedures and describe how copies of these procedures would be prepared for use in the field. Only at this time should the evaluator give the candidate previously prepared copies of the procedure(s). This entire procedure need only be performed or simulated once during the entire exam. These activities are not required for JPMs conducted in the Simulator.
- 5. Consideration of electrical safety must be made during the performance of certain tasks involving electrical circuits and circuit breakers. The performer should be aware that working on or near energized equipment requires, at a minimum, wearing 100% cotton clothing and low voltage (Class 0) gloves while removing or securing shock hazards such as chains, jewelry, watches and metal-framed eyeglasses. Operating or racking circuit breakers may require additional PPE. Details can be found in Att. 2 of the Electrical Safety Rulebook and General Operating procedure 04-S-04-2 (Operation of Electrical Circuit Breakers)
- 6. Obtain Shift Management's permission before opening any control panel or compartment. Avoid placing any tools, flashlights, pointing devices or any part of your body inside the panel or compartment in a manner that could disturb the operation of any component within or potentially result in an electric shock).
- 7. Use of lasers as a pointing tool requires Engineering's prior approval of the specific tool for safe use in the Control area. (specifically, the laser's emissions must be verified as not interfering with any component's intended operation or function).
- 8. During activities within the CAA, consideration must be given to area dose rates. When in a posted Radiation Area, check your EAD for dose rates and minimize time spent in the area. Entry into High Radiation Areas or Contamination Areas is prohibited.

# Under no circumstances is any candidate allowed to operate any equipment outside the simulator without the permission of the Evaluator and Shift Management.



ENTERGY NUCLEAR Number: GJPM-OPS-P6404

Number: GJPM-OPS-P6404 Revision: 00 Page: 23 of 272

JOB PERFORMANCE MEASURE

# **<u>P64 Task 4</u>:** Perform Control Room Actions in Response to Fire in Plant

Control Room
RO
CRO-P64-004
286000 A4.05: 3.3/3.3; A2.09: 2.7/2.8
Generic 2.4.25: 2.9/3.4; 2.4.27: 3.0/3.5; 2.1.30: 3.9/3.4;
2.1.31: 4.2/3.9; 2.1.16: 2.9/2.8
Plant Systems (8)
5 minutes
No
No
Simulate
10-S-03-2
10-S-03-2
5
5
2

#### Simulator Setup/Required Plant Conditions:

- Area is accessible
- Do not operate plant equipment.
- Notify the Shift Manager and Control Room Supervisor of JPM Performance.

#### Safety Concerns:

• DO NOT manipulate Control Room Controls.

#### Initial Condition(s):

- The plant is operating at 100% power.
- The control room has just been informed there is heavy black smoke in the Auxiliary Building in Area 9 139 ft. elevation.
- All Auxiliary Building air operated isolation valves have failed closed.

#### Initiating Cue(s):

- You have been directed to perform the Control Room Actions in response to the fire and ensure the Fire Brigade has an adequate supply of water for fire suppression.
- This task is not time critical.



#### **P64 Task 4: Perform Control Room Actions in Response to Fire in Plant**

### Notes:

- 1. JPM is to be simulated in the Unit 1 Control Room at the H13-P862 panel.
- 2. DO NOT OPERATE CONTROL ROOM CONTROLS.
- 3. Simulate making Plant PA and Radio announcements.

### **Task Overview:**

This task is to perform a start the Motor Driven Fire Pump and align Fire Water to the Unit 1 Auxiliary Building to support Fire Suppression per 10-S-03-2 Response to Fires.



#### **P64 Task 4: Perform Control Room Actions in Response to Fire in Plant**

# Tasks : Critical tasks are underlined, italicized, and denoted by an (\*)

Note : The sequence for the following steps is not critical.

\* Activate the Fire Alarm and Announce over the plant PA system. Standard: Makes an announcement over the plant PA system as to the location of the fire and for the Fire Brigade to respond to the scene. During this announcement activate the Site Fire Alarm. Cue: PA Announcement and activation of alarm are complete. Notes: Do NOT allow candidate to make PA announcement or sound alarm. This would activate the actual Fire Brigade.

Candidate should locate the Site Fire Alarm and describe its operation.

Announcement should be similar to this:

"Attention all personnel! There is a (type if known) fire reported at area 9 139 foot elevation in the Auxiliary Building. Fire Brigade to the scene."

CUE: If asked, as Shift Manager direct the candidate to perform the Control Room Actions of the Repsonse to Fires Procedure.

\* Announce over the plant radio system. Standard: Makes an announcement over the plant radio system as to the location of the fire and for the Fire Brigade to respond to the scene. Cue: Radio Announcement is complete. Notes: Do NOT allow candidate to make Radio announcement. This would activate the actual Fire Brigade.

Announcement should be similar to this:

"Attention all personnel! There is a (type if known) fire reported at area 9 139 foot elevation in the Auxiliary Building. Fire Brigade to the scene."



Number: GJPM-OPS-P6404 Revision: 00 Page: 26 of 272

JOB PERFORMANCE MEASURE

 Verify running or start the motor Driven Fire Pump. Standard: Starts the Motor Driven Fire Pump by depressing the START pushbutton on P862 and observes red light on green light off <u>Cue</u>: If asked prior to manipulation cue candidate the green light is on red light is off. Once the candidate performs the action cue red light on green light off <u>Notes</u>: DO NOT allow candidate to operate control room controls.

 Check open or open 1P64-F010A Fire Water Header Auxiliary Building Isolation

 Bypass.

<u>Standard:</u> Observes 1P64-F010A is closed and opens the valve by rotating the handswitch clockwise and observing red light on green light off.

<u>Cue</u>: If asked prior to manipulation cue candidate the green light is on red light is off. Once the candidate performs the action cue red light on green light off

Notes: Handswitch is on P862.

 Check open or open 1P64-F010B Fire Water Header Auxiliary Building Isolation

 Bypass.

<u>Standard:</u> Observes 1P64-F010B is closed and opens the valve by rotating the handswitch clockwise and observing red light on green light off.

<u>Cue</u>: If asked prior to manipulation cue candidate the green light is on red light is off. Once the candidate performs the action cue red light on green light off

Notes: Handswitch is on P862.



Task Standard(s):

Fire Brigade has been dispatched and the Motor Driven Fire Pump is operating and fire water is aligned to the Auxiliary Building.

Name:	Time Start:	Time Stop:



Number: GJPM-OPS-P6404 Revision: 00 Page: 28 of 272

JOB PERFORMANCE MEASURE

# **<u>P64 Task 4</u>:** Perform Control Room Actions in Response to Fire in Plant

Follow-Up Questions & Answers:

Comments:



# **Perform Control Room Actions in Response to Fire in Plant**

# Give this page to the student

Initial Condition(s):

- The plant is operating at 100% power. •
- The control room has just been informed there is heavy black smoke in the Auxiliary • Building in Area 9 139 ft. elevation.
- All Auxiliary Building air operated isolation valves have failed closed. •

#### Initiating Cue(s):

- You have been directed to perform the Control Room Actions in response to the fire and ensure the Fire Brigade has an adequate supply of water for fire suppression.
- This task is not time critical. •



#### **TRAINING PROGRAM:**

# **OPERATOR TRAINING**

TITI F.

<b>Operate Turbine Pressure Control / SRVs</b>				
New Material	Minor Revision Major Revision	Cancellation		
REASON FOR RE	VISION: NEW JPM <u>CREPLACES</u> : N/A			
REVIEW / APPRO	<b>DVAL (Print Name):</b> TEAR Approval (TEAR #	)		
Prepared By:	**Dranarar	Date		
Ops Review <sup>++:</sup>	Tachnical Daviawar (a.g. SME line management)	Date		
Validated By:	rechnical Reviewer (e.g., Sivie, line management)	Date		
valuateu by.				
Approved By:	Training Representative	Date		
Approved By: _	Training Representative <sup>+</sup> Discipline Training Supervisor	Date		

TQJA-201- DD06, Training Material Checklist.

<sup>++</sup> Indicates that Operations has reviewed and approved this material for exam use.

#### FLEET/REGIONAL PROGRAM CONCURRENCE:

Fleet	ENS ENN	Not Applicable		
DATE TRANSMITTED TO RM	INITIAL RECEIPT BY RM (DATE/INITIAL)	RETURNED FOR CORRECTIONS (DATE/INITIAL)	RETURN RECEIPT (DATE/INITIAL)	FINAL ACCEPTANCE BY RM (DATE/INITIALS)



# **Generic Instructions**

- 1. Standards and cues for valve operation:
  - a. MOVs:
    - "Turn the valve's handswitch on (panel #)(section#, as applicable) in the (clockwise or counter-clockwise) direction and observe that the valve's red light is (energized or de-energized) and its green light is (energized or de-energized)".
  - b. Manual valves
    - 1) "Turn the valve's handwheel (or other manual operating device) in the (clockwise or counter-clockwise) direction until resistance is felt."
- 2. The Evaluator should indicate simulated analog gauge readings by pointing a pen or equivalent to the intended place on the gauge.
- 3. Other methods of simulating control, operation and data collection is at the discretion of the Evaluator.
- 4. It is expected that the candidate shall locate controlled copies of any required procedures and describe how copies of these procedures would be prepared for use in the field. Only at this time should the evaluator give the candidate previously prepared copies of the procedure(s). This entire procedure need only be performed or simulated once during the entire exam. <u>These activities are not required for JPMs conducted in the Simulator</u>.
- 5. Consideration of electrical safety must be made during the performance of certain tasks involving electrical circuits and circuit breakers. The performer should be aware that working on or near energized equipment requires, at a minimum, wearing 100% cotton clothing and low voltage (Class 0) gloves while removing or securing shock hazards such as chains, jewelry, watches and metal-framed eyeglasses. Operating or racking circuit breakers may require additional PPE. Details can be found in Att. 2 of the Electrical Safety Rulebook and General Operating procedure 04-S-04-2 (Operation of Electrical Circuit Breakers)
- 6. Obtain Shift Management's permission before opening any control panel or compartment. Avoid placing any tools, flashlights, pointing devices or any part of your body inside the panel or compartment in a manner that could disturb the operation of any component within or potentially result in an electric shock).
- 7. Use of lasers as a pointing tool requires Engineering's prior approval of the specific tool for safe use in the Control area. (specifically, the laser's emissions must be verified as not interfering with any component's intended operation or function).
- 8. During activities within the CAA, consideration must be given to area dose rates. When in a posted Radiation Area, check your EAD for dose rates and minimize time spent in the area. Entry into High Radiation Areas or Contamination Areas is prohibited.

# Under no circumstances is any candidate allowed to operate any equipment outside the simulator without the permission of the Evaluator and Shift Management.



Number: GJPM-OPS-B2110 Revision: 00 Page: 32 of 272

JOB PERFORMANCE MEASURE

# **<u>B21 Task 10</u>**: Operate Turbine Pressure Control / SRVs

<u>Setting</u> :	Simulator
<u>Type</u> :	RO
<u>Task</u> :	CRO-B21-010; CRO-N32(2)-009
<u>K&amp;A</u> :	241000 A2.03 - 4.1/4.2; A3.08 - 3.8/3.8; A4.06 - 3.9/3.9
	239002 A4.01 - 4.4/4.4; A4.05 - 4.3/4.3
	295025 EA1.02 - 3.8/3.8; EA1.03 - 4.4/4.4
Safety Function:	3
Time Required:	10 minutes
Time Critical:	No
Faulted:	YES
Performance:	Actual
Reference(s):	04-1-01-N32-2 Att V; 04-1-01-B21-1
Handout(s):	None
<u># Manipulations:</u>	4
<u># Critical Steps:</u>	4
Group:	1

Simulator

Simulator Setups:

- IC 19
- Insert malfunctions
  - o c11164@20% Scram Discharge volumen hydraulic block
  - o tc079@ 0% Pressure Controller failure on Trigger 1
  - o tc082a@0% Bypass Control Valve A closed Trigger 2
  - o tc082b@0% Bypass Control Valve B closed Trigger 2
  - o tc082c@0% Bypass Control Valve C closed Trigger 2
- Take Simulator out of freeze and place the mode switch to SHUTDOWN.
- Initiate ATWS ARI.
- Initiate and override HPCS.
- Inhibit ADS.

Turn simulator over to candidate.

Safety Concerns:

• None



#### **Operate Turbine Pressure Control / SRVs B21 Task 10**:

Initial Condition(s):

- The plant was operating at 100% power when a scram occurred.
- All Control rods did not fully insert.
- Emergency Operating Procedure 2A has been entered.

Initiating Cue(s):

- You have been directed to take RPV Pressure Control and lower pressure reference • setpoint to 900 psig. Maintain RPV pressure 800 – 1060 psig.
- Other operators will control other plant parameters.
- Report when pressure is being controlled on the Main Turbine Bypass Valves at • 900 psig.



#### **Operate Turbine Pressure Control / SRVs B21 Task 10:**

#### Notes

1. All controls will be from panels P601 and P680 in the Main Control Room.

### **Task Overview:**

This task places the Turbine Pressure Control System operating on the Manual Bypass Jack followed by a failure of the Bypass Valves to open. This requires an alternate method of RPV pressure control using SRVs and a band of 800 to 1060 psig.

### **Task Justification:**

The following JPM does not meet the minimum requirements of 14-S-02-18. It either does not have the required number of manipulations or critical steps. However it has been deemed a valid JPM in accordance with 14-S-02-18 step 6.3.13 due to the following:

This task involves observing the reaction of the Main Steam Bypass Control Valves under ATWS conditions when they are to be used to control RPV pressure. The candidate will have to evaluate the response of the valves to changing RPV pressure. Once the valves fail alternate pressure control methods will be employed.

This task is selected because RPV Pressure Control during an ATWS is a critical parameter to limit the cycling of the RPV, the problems presented to the operator controlling RPV water level and the power oscillations that occur when RPV pressure cycles.

In all cases preferred heat sink for the RPV is the Main Condenser either through the Main Turbine, Main Steam Bypass Valves, or Main Steam Line Drains. An accepted means of RPV pressure control is the use of SRVs. This is least desired during an ATWS due to the amount of heat being dumped into Primary Containment and the challenge it may present.

This JPM uses two different means of RPV pressure control.



JOB PERFORMANCE MEASURE

# **<u>B21 Task 10</u>**: Operate Turbine Pressure Control / SRVs

**<u>Tasks</u>**: critical tasks are underlined, italicized and denoted by (\*)

Note: Sequence is critical for critical tasks unless otherwise noted.

Example 2 Example

SIMULATOR OPERATOR: Once candidate reports Turbine Pressure reference is at 900psig (± 30 psig), ACTIVATE Trigger 1. (Turbine Bypass Control Valves will fail closed.)

<u>CUE:</u> When candidate reports failure of the Turbine Bypass Valves closed, as Control Room Supervisor order the candidate to attempt to control pressure using the Manual Bypass Jack in a pressure band 800 – 1060 psig.



Number: GJPM-OPS-B2110 **Revision: 00** Page: 36 of 272

**JOB PERFORMANCE MEASURE** 

€\* Energize Manual Bypass Valve Controller by simultaneously depressing MANUAL BYPASS CONTROL RELEASE pushbutton and the MANUAL BYPASS VALVE CONTROLLER ON pushbutton until ON pushbutton remains illuminated.

On P680 section 9C energizes Manual Bypass Valve Controller by Standard: simultaneously depressing MANUAL BYPASS CONTROL RELEASE pushbutton and the MANUAL BYPASS VALVE CONTROLLER ON pushbutton until ON pushbutton remains illuminated

#### Cue: As Indicated

Notes: In some cases this may take more than one try, this is acceptable as long as the task is accomplished.

*E*\* Using the RAISE and/or L<u>OWER pushbuttons open the Turbine Bypass Control</u> Valves to maintain RPV pressure 800 – 1060psig

Depresses RAISE and /or LOWER pushbuttons to open the Turbine Standard: Bypass Control Valves.

#### Cue: As Indicated

Notes: Valve indication is located on P680-9D meters N11-R602A, B, C. These valves are slow to react.

When Bypass valves open slightly demonstrating the candidate can open the valves, **SIMULATOR OPERATOR Activate Trigger 2.** (Turbine Bypass Control Valves failed closed.)

**CUE: When candidate reports failure of the Turbine Bypass Valves** closed, as Control Room Supervisor order the candidate to attempt to control pressure using SRVs in a pressure band 800 – 1060 psig.


€\* <u>Manually open SRVs to maintain RPV pressure 800 – 1060psig</u> Manually opens SRVs on P601 by rotating their handswitches Standard: clockwise and observing the red light on and green light off to maintain RPV pressure 800 - 1060psig. Cue: As Indicated Notes: Valve controls are located on P601-19C. Pressure indication is on P601 section 20B B21-UR-R623A and section 17B B21-UR-R623B Post Accident Recorders.

Candidate may verify Reactor Power and Pressure then observe the already open SRVs then adjust number of open SRVs as required to establish RPV pressure in band.

#### When the Evaluator is satisfied with control the JPM may be terminated.

Task Standard(s):

RPV Pressure is being maintained using SRVs between 800 – 1060 psig..

Name: \_\_\_\_\_\_Time Start: \_\_\_\_\_Time Stop: \_\_\_\_\_



JOB PERFORMANCE MEASURE

# **<u>B21 Task 10</u>**: Operate Turbine Pressure Control / SRVs

Follow-Up Questions & Answers:

Comments:



# **Operate Turbine Pressure Control**

## Give this page to the student

Initial Condition(s):

- The plant was operating at 100% power when a scram occurred.
- All Control rods did not fully insert.
- Emergency Operating Procedure 2A has been entered.

Initiating Cue(s):

- You have been directed to take RPV Pressure Control and lower pressure reference setpoint to 900 psig. Maintain RPV pressure 800 – 1060 psig.
- Other operators will control other plant parameters.
- Report when pressure is being controlled on the Main Turbine Bypass Valves at 900 psig.



#### **TRAINING PROGRAM:**

# **OPERATOR TRAINING**

TITLE:

# **Return Recirc Loop to Service at Power**

New Material	Minor Revision	Major Revision	Cancellation
REASON FOR REV THIS DOCUMENT	VISION: NEW J <u>REPLACES</u> : N/A	РМ	
REVIEW / APPRO	OVAL (Print Name):	] TEAR Approval (TEAR #	)
Prepared By:			
	**Prepa	rer	Date
<b>Ops Review</b> <sup>++:</sup>			
_	Technical Reviewer (e.g., S	ME, line management)	Date
Validated By:			
• _	Training Repre	esentative	Date
Approved By:			
	<sup>+</sup> Discipline Trainir	ng Supervisor	Date
Approval Date:*_			
* Indexing Information ** The requirements of the Tr Indicates that the LP has be	aining Material Checklist have been een reviewed by the Training Supervi	met. sor for inclusion of Management Expecta	ations and items referenced on

TQJA-201- DD06, Training Material Checklist.

<sup>++</sup> Indicates that Operations has reviewed and approved this material for exam use.

#### FLEET/REGIONAL PROGRAM CONCURRENCE:

Fleet	ENS ENN	Not Applicable		
DATE TRANSMITTED TO RM	INITIAL RECEIPT BY RM (DATE/INITIAL)	RETURNED FOR CORRECTIONS (DATE/INITIAL)	RETURN RECEIPT (DATE/INITIAL)	FINAL ACCEPTANCE BY RM (DATE/INITIALS)



# **Generic Instructions**

- 1. Standards and cues for valve operation:
  - a. MOVs:
    - "Turn the valve's handswitch on (panel #)(section#, as applicable) in the (clockwise or counter-clockwise) direction and observe that the valve's red light is (energized or de-energized) and its green light is (energized or de-energized)".
  - b. Manual valves
    - 1) "Turn the valve's handwheel (or other manual operating device) in the (clockwise or counter-clockwise) direction until resistance is felt."
- 2. The Evaluator should indicate simulated analog gauge readings by pointing a pen or equivalent to the intended place on the gauge.
- 3. Other methods of simulating control, operation and data collection is at the discretion of the Evaluator.
- 4. It is expected that the candidate shall locate controlled copies of any required procedures and describe how copies of these procedures would be prepared for use in the field. Only at this time should the evaluator give the candidate previously prepared copies of the procedure(s). This entire procedure need only be performed or simulated once during the entire exam. <u>These activities are not required for JPMs conducted in the Simulator</u>.
- 5. Consideration of electrical safety must be made during the performance of certain tasks involving electrical circuits and circuit breakers. The performer should be aware that working on or near energized equipment requires, at a minimum, wearing 100% cotton clothing and low voltage (Class 0) gloves while removing or securing shock hazards such as chains, jewelry, watches and metal-framed eyeglasses. Operating or racking circuit breakers may require additional PPE. Details can be found in Att. 2 of the Electrical Safety Rulebook and General Operating procedure 04-S-04-2 (Operation of Electrical Circuit Breakers)
- 6. Obtain Shift Management's permission before opening any control panel or compartment. Avoid placing any tools, flashlights, pointing devices or any part of your body inside the panel or compartment in a manner that could disturb the operation of any component within or potentially result in an electric shock).
- 7. Use of lasers as a pointing tool requires Engineering's prior approval of the specific tool for safe use in the Control area. (specifically, the laser's emissions must be verified as not interfering with any component's intended operation or function).
- 8. During activities within the CAA, consideration must be given to area dose rates. When in a posted Radiation Area, check your EAD for dose rates and minimize time spent in the area. Entry into High Radiation Areas or Contamination Areas is prohibited.

## Under no circumstances is any candidate allowed to operate any equipment outside the simulator without the permission of the Evaluator and Shift Management.



Number: GJPM-OPS-B3311 Revision: 00 Page: 42 of 272

JOB PERFORMANCE MEASURE

# **<u>B33 Task 11</u>**: Return Recirc Loop to Service at Power

Setting:	Simulator
Type:	RO
<u>Task</u> :	CRO-B33(1)-011
<u>K&amp;A</u> :	202001 A2.05 - 3.8/4.0; A2.24 - 3.1/3.1; A3.01 - 3.1/3.1;
	A3.02 – 3.1/3.0; A3.06 – 3.6/3.6; A4.01 – 3.7/3.7; A4.02 – 3.5/3.4;
	A4.12 - 3.9/3.8
	202002 A1.01 – 3.2/3.2; A1.05 – 3.6/3.6; A1.06 – 3.4/3.3;
	A1.07 – 3.1/3.1; A1.08 – 3.4/3.4; A3.01 – 3.6/3.4; A4.04 – 3.8/3.8;
	A4.08 – 3.3/3.3; A4.09 – 3.2/3.3
	295014 AA1.02 - 3.6/3.8; AA2.03 - 4.0/4.3
Safety Function:	1/4
Time Required:	30 minutes
Time Critical:	No
Faulted:	YES
Performance:	Actual
Reference(s):	04-1-01-B33-1; 05-1-02-III-3; EN-OP-115
Handout(s):	04-1-01-B33-1
<u># Manipulations</u> :	6 or 7
# Critical Steps:	5 or 6
Group:	2

Simulator

Simulator Setups:

- IC 13 Raise power with control rods to 45% power and shift Recirc Pump A to Fast Speed.
- Trip Recirc Pump B and close the Flow Control Valve to MIN ED position.
- Depress STOP LOCK pushbutton for Recirc Pump B.
- Insert malfunction
  - o rr173b Ramp from 0% to 100% Recirc Flow Control Valve ramp open.

Safety Concerns:

• None



#### **Return Recirc Loop to Service at Power B33 Task 11:**

Initial Condition(s):

- The plant was operating at 45% power when Recirc Pump B tripped on transfer to Fast Speed.
- Electricians corrected the problem with CB-5B that resulted in the Control Power Fuse blowing.
- Recirc Pump 'A' is operating in Fast Speed.
- Seal Purge to Recirc Pump 'B' has been verified at normal pressures.
- Reactor Engineering has verified the plant is operating at < 75% Rod Line and that FCBB is < 1.0.
- Recirc Flow Control Valve is at the MIN ED position.
- Unit 1 Instrument Air Compressor is in lead.
- FCTR has been placed in the SETUP mode.
- Recirc Loop 'A' is operating < 22,300 gpm.
- ALL annunciators associated with the 'B' Hydraulic Power Unit and cooling to Recirc Pump 'B' are clear.
- Chemistry and Radiation Protection have been notified of the Recirc Pump start.
- The Idle Loop Startup Surveillance 06-OP-1B33-V-0005 is being performed by • another operator.
- Reactor Water level has been raised to 40 inches.
- All Recirc Pump Temperatures are normal.
- Feedwater flow is > 4.5 Mlbm/hr.
- Reactor Dome temperature is >7.4 degrees above Recirc Loop B. •

Initiating Cue(s):

- You have been directed to return Recirc Loop B to service.
- Other operators will control other plant parameters.



JOB PERFORMANCE MEASURE

# **<u>B33 Task 11</u>**: Return Recirc Loop to Service at Power

## **Notes**

1. All controls will be from panels P680 and P807 in the Main Control Room.

## Task Overview:

This task returns a Reactor Recirc Loop to service with the plant above 30% power with conditions such that the pump should operate in Fast Speed. Following the pump start the Flow Control Valve will ramp to full open on its own. This will require operator action to reduce the impact on the Reactor.



#### **Return Recirc Loop to Service at Power B33 Task 11:**

Tasks: critical tasks are underlined, italicized and denoted by (\*)

Note: Sequence is critical for critical tasks unless otherwise noted.

€ Check the following Breaker positions for Recirc Pump B:

CB-3B, RECIRC PMP FDR B DRIVE MOTOR BKR 252-1205B CLOSED

\_\_\_\_ CB-4B, RECIRC PMP FDR 252-1205C CLOSED

CB-1B, LFMG B MTR FDR 152-1411 OPEN

\_\_CB-2B, LFMG B GEN FDR 252-1205A OPEN

CB-5B, RECIRC PMP B FDR 252-1205 OPEN

Observes Breaker indication for Recric Pump B CB-3B and 4B should Standard: be red light on green light off, CB-1B, 2B and 5B should be green light on red light off on P680.

#### **Cue: As Indicated**

Notes: Indications are on P680 section 3C.

NOTE: Candidate may verify Recirc Pump B seal pressures and HPU operation. These were given in the Initial Conditions and are as indicated.

€\* Raise BOP Transformer tap setting to raise bus voltage on bus 12HE to about 7.2KV.

On P807 raises tap setting on BOP Transformer for bus 12HE to about Standard: 7.2 KV as indicated on R22-R603 section 2B of P807.

As Indicated Cue: Notes:

#### CUE: Surveillance 06-OP-1B33-V-0005 was just completed one minute ago satisfactorily.

€\* <u>Depress RELEASE pushbutton on the RECIRC PMP B STOP/STOP LOCK</u>

pushbutton.

Depresses RELEASE pushbutton on Recirc Pump B Stop/Stop Lock Standard: pushbutton.

#### Cue: As Indicated

Notes: Pushbutton is located on P680 section 3C.



€\* <u>Depress START pushbutton on RECIRC PMP B TRANS TO LFMG/START</u> pushbutton. Standard: Depresses START pushbutton on RECIRC PMP B TRANS TO LFMG/START pushbutton. As Indicated Cue: Notes: Pushbutton is located on P680 section 3C.

€ Observe the following for Recirc Pump B: CB-5B, RECIRC PMP B FDR 252-1205 CLOSE (red light on green light off) \_\_\_ RECIRC PMP B amps increase \_ RECIRC PMP B rpm increase to 1800 rpm Observes indications for Recric Pump B on P680. Standard: **Cue: As Indicated** Notes: Indications are on P680 section 3B & C.

- € Lower BOP Transformer tap setting to lower bus voltage on bus 12HE to about 7KV. Standard: On P807 lowers tap setting on BOP Transformer for bus 12HE to about 7 KV as indicated on R22-R603 section 2B of P807. As Indicated Cue: Notes:
- € Check proper pump and Jet pump operation on P680. On P680 section 3B looks at indications for jet pump flows, Recirc Standard: Loop Flow, Core Flow, Seeal Pressures. Cue: As Indicated Notes:



€\* <u>Balance flow between Recirc Loops A and B to establish less than 10% differential</u> by opening on Recirc Pump B Flow Control Valve B. Raises Recirc Loop B 0Flow Control Valve position to raise Recirc Standard: Loop B flow. Cue: As Indicated Notes: Slide switch on P680 section 3D indication is on section 3B recorder 1C51-FR-R614 (Loop B is the red pen indication.).

#### SIMULATOR OPERATOR when candidate raises on Loop Flow, ACTIVATE

Trigger 1

#### The candidate may attempt one of several options.

€ Attempt to lower on the B Loop Flow Control Valve Control. Places Recirc Loop B Flow Control Valve control to LOWER position Standard: to lower Recirc Loop B flow. Cue: As Indicated Notes: Slide switch on P680 section 3D indication is on section 3B recorder 1C51-FR-R614 (Loop B is the red pen indication.). THIS ACTION WILL HAVE NO

EFFECT.

#### **Option 1**

*€*\* <u>Trip Recirc Pump B Hydraulic Power Unit to stop valve movement.</u>

Arms and depresses HPU B SHUTDN pushbutton on P680. Standard: Cue: As Indicated

Notes: Armed collar pushbutton on P680 section 3C. This action will stop valve movement.

This action keeps the Recirc Pump operating, however Reactor Engineering will have to determine the affects on the core.



#### **Option 2**

€\* <u>Trip Recirc Pump B by depressing STOP or STOP LOCK pushbutton.</u> Standard: Trips Recirc Pump B by depressing STOP or STOP LOCK pushbutton on P680 indication will be green light on red light off for CB-5B. As Indicated Cue: Notes: Pushbutton on P680 section 3C. This action will trip the Recirc pump to off.

#### **Option 3**

This action will require entry into the Reduction of Recirculation Flow ONEP 05-1-02-III-3.

€\* Close RECIRC <u>PMP B DISCH VLV B33-F067B.</u>

Closes B33-F067B by depressing CLOSE pushbutton on P680 Standard: indication will be green light on red light off.

#### **As Indicated** Cue:

Notes: Pushbutton on P680 section 3C. This action will be performed if the option of Tripping the Recirc pump is taken. If the Recirc Pump remains operating this item is not critical.

#### € Plot operation on Power to Flow map.

Standard: Plots operation using rms and depresses HPU B SHUTDN pushbutton on P680.

#### **As Indicated** Cue:

Notes: Plot should be in the Monitor Region.

Task Standard(s):

Actions have been taken to limit reactor power rise due to the Recirc Flow Control Valve malfunction.

Name:	Time Start:	Time Stop:
-------	-------------	------------



ENTERGY NUCLEAR JOB PERFORMANCE

**MEASURE** 

# **<u>B33 Task 11</u>**: Return Recirc Loop to Service at Power

Follow-Up Questions & Answers:

Comments:



# **Return Recirc Loop to Service at Power**

## Give this page to the student

Initial Condition(s):

- The plant was operating at 45% power when Recirc Pump B tripped on transfer to Fast Speed.
- Electricians corrected the problem with CB-5B that resulted in the Control Power Fuse blowing.
- Recirc Pump 'A' is operating in Fast Speed.
- Seal Purge to Recirc Pump 'B' has been verified at normal pressures. •
- Reactor Engineering has verified the plant is operating at < 75% Rod Line and that • FCBB is < 1.0.
- Recirc Flow Control Valve is at the MIN ED position.
- Unit 1 Instrument Air Compressor is in lead. •
- FCTR has been placed in the SETUP mode.
- Recirc Loop 'A' is operating < 22,300 gpm. •
- ALL annunciators associated with the 'B' Hydraulic Power Unit and cooling to Recirc Pump 'B' are clear.
- Chemistry and Radiation Protection have been notified of the Recirc Pump start. •
- The Idle Loop Startup Surveillance 06-OP-1B33-V-0005 was completed satisfactorily • 1 minute ago.
- Reactor Water level has been raised to 40 inches. •
- All Recirc Pump Temperatures are normal.
- Feedwater flow is > 4.5 Mlbm/hr. •
- Reactor Dome temperature is >7.4 degrees above Recirc Loop B. •

Initiating Cue(s):

- You have been directed to return Recirc Loop B to service.
- Other operators will control other plant parameters.



# **OPERATOR TRAINING**

TITLE:

Start SSW A & B and supply all loads from Remote Shutdown Panels			
New Material Minor	Revision	Major Revision	Cancellation
<u>REASON FOR REVISION</u> : <u>THIS DOCUMENT REPLACES</u> :	NEW JPM. N/A		
<b>REVIEW / APPROVAL (Print Name):</b> TEAR Approval (TEAR # )			

Prepared By:		
	**Preparer	Date
<b>Ops Review</b> <sup>++:</sup>		
_	Technical Reviewer (e.g., SME, line management)	Date
Validated By:		
	Training Representative	Date
Approved By:	+D:	
	Discipline Training Supervisor	Date
Approval Date:*		

\* Indexing Information

\*\* The requirements of the Training Material Checklist have been met.

Indicates that the LP has been reviewed by the Training Supervisor for inclusion of Management Expectations and items referenced on TQJA-201- DD06, Training Material Checklist.

<sup>++</sup> Indicates that Operations has reviewed and approved this material for exam use.

#### FLEET/REGIONAL PROGRAM CONCURRENCE:

Fleet	ENS ENN	Not Applicable		
DATE TRANSMITTED TO RM	INITIAL RECEIPT BY RM (DATE/INITIAL)	RETURNED FOR CORRECTIONS (DATE/INITIAL)	RETURN RECEIPT (DATE/INITIAL)	FINAL ACCEPTANCE BY RM (DATE/INITIALS)



# **Generic Instructions**

- 1. Standards and cues for valve operation:
  - a. MOVs:
    - "Turn the valve's handswitch on (panel #)(section#, as applicable) in the (clockwise or counter-clockwise) direction and observe that the valve's red light is (energized or de-energized) and its green light is (energized or de-energized)".
  - b. Manual valves
    - 1) "Turn the valve's handwheel (or other manual operating device) in the (clockwise or counter-clockwise) direction until resistance is felt."
- 2. The Evaluator should indicate simulated analog gauge readings by pointing a pen or equivalent to the intended place on the gauge.
- 3. Other methods of simulating control, operation and data collection is at the discretion of the Evaluator.
- 4. It is expected that the candidate shall locate controlled copies of any required procedures and describe how copies of these procedures would be prepared for use in the field. Only at this time should the evaluator give the candidate previously prepared copies of the procedure(s). This entire procedure need only be performed or simulated once during the entire exam. <u>These activities are not required for JPMs conducted in the Simulator</u>.
- 5. Consideration of electrical safety must be made during the performance of certain tasks involving electrical circuits and circuit breakers. The performer should be aware that working on or near energized equipment requires, at a minimum, wearing 100% cotton clothing and low voltage (Class 0) gloves while removing or securing shock hazards such as chains, jewelry, watches and metal-framed eyeglasses. Operating or racking circuit breakers may require additional PPE. Details can be found in Att. 2 of the Electrical Safety Rulebook and General Operating procedure 04-S-04-2 (Operation of Electrical Circuit Breakers)
- 6. Obtain Shift Management's permission before opening any control panel or compartment. Avoid placing any tools, flashlights, pointing devices or any part of your body inside the panel or compartment in a manner that could disturb the operation of any component within or potentially result in an electric shock).
- 7. Use of lasers as a pointing tool requires Engineering's prior approval of the specific tool for safe use in the Control area. (specifically, the laser's emissions must be verified as not interfering with any component's intended operation or function).
- 8. During activities within the CAA, consideration must be given to area dose rates. When in a posted Radiation Area, check your EAD for dose rates and minimize time spent in the area. Entry into High Radiation Areas or Contamination Areas is prohibited.

## Under no circumstances is any candidate allowed to operate any equipment outside the simulator without the permission of the Evaluator and Shift Management.



ENTERGY NUCLEAR Number: GJPM-OPS-C6109 **Revision: 00** Page: 53 of 272

**JOB PERFORMANCE MEASURE** 

#### Start SSW A & B and supply all loads from <u>C61 Task 9</u>: **Remote Shutdown Panels**

Setting:	Plant (Outside CAA)
Type:	RO
Task:	CRO-C61-009
K&A:	295016 Generic 2.1.30 - 3.9/3.4
	400000 A4.01 3.1/3.0
Safety Function:	7/8
Time Required:	10 minutes
Time Critical:	No
Faulted:	No
Performance:	Actual
Reference(s):	05-1-02-II-1
Handout(s):	05-1-02-II-1
# Manipulations:	16
<u># Critical Steps:</u>	16
Group:	1

Plant / Low Power / Emergency - Abnormal Operations

Simulator Setups:

o N/A

Safety Concerns:

• None

#### Initial Condition(s):

- The Control Room has been abandoned due to toxic gas.
- The Reactor has been scrammed and RPS reset.
- All control rods are fully inserted.
- Control is being established at the Remote Shutdown Panels.

Initiating Cue(s):

You have been directed to start Standby Service Water (SSW) A and B and supply • all available loads.



Number: GJPM-OPS-C6109 Revision: 00 Page: 54 of 272

JOB PERFORMANCE MEASURE

# <u>C61 Task 9</u>: Start SSW A & B and supply all loads from Remote Shutdown Panels

#### <u>Notes</u>

1. All controls will be from panels P150 and P151 in the Remote Shutdown Panel Room.

#### **Task Overview:**

This task aligns Standby Service Water in operation through all loads from the Remote Shutdown Panels. This action would be taken in the event of Control Room Abandonment for toxic gas, fire, or terrorist control of the Main Control Room.



#### Start SSW A & B and supply all loads from <u>C61 Task 9</u>: **Remote Shutdown Panels**

Tasks: critical tasks are underlined, italicized and denoted by (\*)

Note: Sequence is critical for critical tasks unless otherwise noted.

May elect to perform SSW A first or B order of systems is NOT critical.

SSW A (Attachment VIII section 3.8.1a)

## **Panel H22-P150**

€ Check open/open P41-F068A, SSW OUTL FM RHR HX A VLV. Observes P41-F068A open red light on green light off. Standard: Cue: Red light on Green light off Notes:

€\* <u>Start P41-C001A, SSW PMP A.</u> Standard: Starts SSW Pump A by rotating handswitch on P150 clockwise to START and observing red light on green light off. Cue: Red light on Green light off Notes:

€\* Open P41-F001A, SSW PMP DISCH VLV.

Standard: Opens P41-F001A, SSW PMP DISCH VLV by rotating the key lock switch clockwise on P150 and observing red light on green light off. Cue: Red light on Green light off Notes:



€\* Open P41-F014A, SSW INL TO RHR HX A VLV. Standard: Opens P41-F014A, SSW INL TO RHR HX A VLV by rotating the handswitch clockwise on P150 and observing red light on green light off. Cue: Red light on Green light off Notes: The interlock between P41-F006A and F014A is bypassed at the Remote Shutdown Panels.

€\* Open P41-F005A, SSW LOOP A RTN TO CLG TWR A.

Standard: Opens P41-F005A, SSW LOOP A RTN TO CLG TWR A by rotating the handswitch clockwise on P150 and observing red light on green light off. Cue: Red light on Green light off Notes:

#### If asked, Cue P41-F006A is Red Light ON Green Light OFF.

€\* Close P41-F006A, SSW LOOP A RECIRC VLV.

Closes P41-F006A, SSW LOOP A RECIRC VLV by rotating the Standard: handswitch counter-clockwise on P150 and observing green light on red light off. **Cue: Green light on Red light off** 

Notes: Order NOT Critical. The interlock between P41-F006A and F014A is bypassed at the Remote Shutdown Panels.

€\* Start P41-C003A, SSW CLG TWR FAN A.

Starts P41-C003A, SSW CLG TWR FAN A by rotating the Standard: handswitch clockwise on P150 and observing red light on green light off. **Cue: Red light on Green light off** 

Notes: Order for Fan A and Fan B is NOT critical.



Number: GJPM-OPS-C6109 Revision: 00 Page: 57 of 272

JOB PERFORMANCE MEASURE

€\* <u>Start P41-C003B, SSW CLG TWR FAN B.</u>

Standard: Starts P41-C003B, SSW CLG TWR FAN B by rotating the handswitch clockwise on P150 and observing red light on green light off. Cue: Red light on Green light off Notes: Order for Fan A and Fan B is NOT critical.

 $\in^* \underline{Open P41-F018A, SSW INL TO DG11 WTR CLR.}$ 

Standard: Opens P41-F018A, SSW INL TO DG11 WTR CLR by rotating the handswitch clockwise on P150 and observing red light on green light off. Cue: Red light on Green light off Notes: Order NOT Critical.

Section 3.6.2 of 05-1-02-II-1



ENTERGY NUCLEAR Number: GJPM-OPS-C6109 **Revision: 00** Page: 58 of 272

**JOB PERFORMANCE MEASURE** 

## May elect to perform SSW A first or B order of systems is NOT critical.

SSW B (Attachment IX section 3.8.2a)

## Panel H22-P151

€ Check open/open P41-F068B, SSW OUTL FM RHR HX B VLV. Standard: Observes P41-F068B open red light on green light off. Cue: Red light on Green light off Notes:

€\* <u>Start P41-C001B, SSW PMP B.</u>

Standard: Starts SSW Pump B by rotating handswitch on P151 clockwise to START and observing red light on green light off. Cue: Red light on Green light off Notes:

€\* <u>Open P41-F001B, SSW PMP DISCH VLV.</u>

Opens P41-F001B, SSW PMP DISCH VLV by rotating the key lock Standard: switch clockwise on P151 and observing red light on green light off. Cue: Red light on Green light off Notes:



ENTERGY NUCLEAR Number: GJPM-OPS-C6109 **Revision: 00** Page: 59 of 272

**JOB PERFORMANCE MEASURE** 

€\* Open P41-F014B, SSW INL TO RHR HX B VLV. Standard: Opens P41-F014B, SSW INL TO RHR HX B VLV by rotating the handswitch clockwise on P151 and observing red light on green light off. Cue: Red light on Green light off Notes: The interlock between P41-F006B and F014B is bypassed at the Remote Shutdown Panels.

€\* Open P41-F005B, SSW LOOP B RTN TO CLG TWR B.

Standard: Opens P41-F005B, SSW LOOP B RTN TO CLG TWR B by rotating the handswitch clockwise on P151 and observing red light on green light off. **Cue: Red light on Green light off** Notes:

#### If asked, Cue P41-F006B is Red Light ON Green Light OFF.

€\* Close P41-F006B, SSW LOOP B RECIRC VLV.

Closes P41-F006B, SSW LOOP B RECIRC VLV by rotating the Standard: handswitch counter-clockwise on P151 and observing green light on red light off. **Cue: Green light on Red light off** 

Notes: Order NOT Critical. The interlock between P41-F006B and F014B is bypassed at the Remote Shutdown Panels.

€\* Start P41-C003C, SSW CLG TWR FAN C.

Starts P41-C003C, SSW CLG TWR FAN C by rotating the Standard: handswitch clockwise on P151 and observing red light on green light off. **Cue: Red light on Green light off** 

Notes: Order for Fan C and Fan D is NOT critical.



ENTERGY NUCLEAR Number: GJPM-OPS-C6109

Number: GJPM-OPS-C6109 Revision: 00 Page: 60 of 272

JOB PERFORMANCE MEASURE

€\* <u>Start P41-C003D, SSW CLG TWR FAN D.</u>

<u>Standard</u>: Starts P41-C003D, SSW CLG TWR FAN D by rotating the handswitch clockwise on P151 and observing red light on green light off. <u>Cue</u>: Red light on Green light off Notes: Order for Fan C and Fan D is NOT critical.

€\* <u>Open P41-F018B, SSW INL TO DG12 WTR CLR.</u> <u>Standard</u>: Opens P41-F018B, SSW INL TO DG12 WTR CLR by rotating the handswitch clockwise on P151 and observing red light on green light off. **Cue: Red light on Green light off** 

Notes: Order NOT Critical.

Section 3.6.2 of 05-1-02-II-1

Task Standard(s):

SSW A & B are operating through the RHR Heat Exchangers and Diesel Generators 11 and 12 with the Cooling Tower fans operating from the Remote Shutdown Panels H22-P150 and P151.

 Name:
 \_\_\_\_\_\_Time Start:
 \_\_\_\_\_\_Time Stop:



ENTERGY NUCLEAR Number: GJPM-OPS-C6109

Number: GJPM-OPS-C6109 Revision: 00 Page: 61 of 272

JOB PERFORMANCE MEASURE

# <u>C61 Task 9</u>: Start SSW A & B and supply all loads from Remote Shutdown Panels

Follow-Up Questions & Answers:

Comments:

Page 61 of 272



# Start SSW A & B and supply all loads from Remote Shutdown **Panels**

## Give this page to the student

Initial Condition(s):

- The Control Room has been abandoned due to toxic gas.
- The Reactor has been scrammed and RPS reset.
- All control rods are fully inserted.
- Control is being established at the Remote Shutdown Panels.

<u>Initiating Cue(s)</u>:

• You have been directed to start Standby Service Water (SSW) A and B and supply all available loads.



ENTERGY NUCLEAR Number: GJPM-OPS-E1201 **Revision: 1** Page: 63 of 272

**JOB PERFORMANCE MEASURE** 

#### **TRAINING PROGRAM:**

# **OPERATOR TRAINING**

TITLE:

# **Startup Shutdown Cooling B**

New Material	Minor Revision	Major Revision	Cancellation
REASON FOR REV THIS DOCUMENT	<u>VISION</u> : Update JF <u>REPLACES</u> : N/A	'M for NRC	
REVIEW / APPRO	<b>)VAL (Print Name):</b> 🗌 T	EAR Approval (TEAR #	)
Prepared By:	**Preparer	_	Date
Ops Review <sup>++:</sup>			
Validated By:	Technical Reviewer (e.g., SME	, line management)	Date
	Training Represer	ntative	Date
Approved By:	<sup>+</sup> Discipline Training S	Supervisor	Date
Approval Date:*			
* Indexing Information ** The requirements of the Tr	aining Material Checklist have been met		

Indicates that the LP has been reviewed by the Training Supervisor for inclusion of Management Expectations and items referenced on TQJA-201- DD06, Training Material Checklist.

<sup>++</sup> Indicates that Operations has reviewed and approved this material for exam use.

#### FLEET/REGIONAL PROGRAM CONCURRENCE:

Fleet	ENS ENN	Not Applicable		
DATE TRANSMITTED TO RM	INITIAL RECEIPT BY RM (DATE/INITIAL)	RETURNED FOR CORRECTIONS (DATE/INITIAL)	RETURN RECEIPT (DATE/INITIAL)	FINAL ACCEPTANCE BY RM (DATE/INITIALS)



# **Generic Instructions**

- 1. Standards and cues for valve operation:
  - a. MOVs:
    - "Turn the valve's handswitch on (panel #)(section#, as applicable) in the (clockwise or counter-clockwise) direction and observe that the valve's red light is (energized or de-energized) and its green light is (energized or de-energized)".
  - b. Manual valves
    - 1) "Turn the valve's handwheel (or other manual operating device) in the (clockwise or counter-clockwise) direction until resistance is felt."
- 2. The Evaluator should indicate simulated analog gauge readings by pointing a pen or equivalent to the intended place on the gauge.
- 3. Other methods of simulating control, operation and data collection is at the discretion of the Evaluator.
- 4. It is expected that the candidate shall locate controlled copies of any required procedures and describe how copies of these procedures would be prepared for use in the field. Only at this time should the evaluator give the candidate previously prepared copies of the procedure(s). This entire procedure need only be performed or simulated once during the entire exam. <u>These activities are not required for JPMs conducted in the Simulator</u>.
- 5. Consideration of electrical safety must be made during the performance of certain tasks involving electrical circuits and circuit breakers. The performer should be aware that working on or near energized equipment requires, at a minimum, wearing 100% cotton clothing and low voltage (Class 0) gloves while removing or securing shock hazards such as chains, jewelry, watches and metal-framed eyeglasses. Operating or racking circuit breakers may require additional PPE. Details can be found in Att. 2 of the Electrical Safety Rulebook and General Operating procedure 04-S-04-2 (Operation of Electrical Circuit Breakers)
- 6. Obtain Shift Management's permission before opening any control panel or compartment. Avoid placing any tools, flashlights, pointing devices or any part of your body inside the panel or compartment in a manner that could disturb the operation of any component within or potentially result in an electric shock).
- 7. Use of lasers as a pointing tool requires Engineering's prior approval of the specific tool for safe use in the Control area. (specifically, the laser's emissions must be verified as not interfering with any component's intended operation or function).
- 8. During activities within the CAA, consideration must be given to area dose rates. When in a posted Radiation Area, check your EAD for dose rates and minimize time spent in the area. Entry into High Radiation Areas or Contamination Areas is prohibited.

## Under no circumstances is any candidate allowed to operate any equipment outside the simulator without the permission of the Evaluator and Shift Management.



ENTERGY NUCLEAR Number: GJPM-OPS-E1201 **Revision: 1** Page: 65 of 272

**JOB PERFORMANCE MEASURE** 

#### **Startup Shutdown Cooling B** E12 Task 1:

Setting:	Simulator
Type:	RO
<u>Task</u> :	CRO-E12-008
<u>K&amp;A</u> :	205000 A4.01 - 3.7/3.7; A4.02 - 3.6/3.5; A4.03 - 3.6/3.5
Safety Function:	4
Time Required:	15 minutes
Time Critical:	No
Faulted:	No
Performance:	Actual
Reference(s):	04-1-01-E12-2 sect 4.2.2c
Handout(s):	None
<u># Manipulations:</u>	10
<u># Critical Steps</u> :	8
Group:	1

Simulator / Low Power

#### Simulator Setups:

- IC 1 Secure RHR A SDC and SSW A
- SSW B in operation to the RHR B heat exchangers
- B21-F065A; E12- F004B; F008; F064B; F009; F053B and F006B are closed.
- B21-F065B is open.

#### Safety Concerns:

None •

#### Initial Condition(s):

- RHR A was previously in service for Shutdown Cooling but was secured. •
- RHR B has been flushed, warmed up and is ready to be placed in Shutdown Cooling.
- SSW B is in operation.
- ADHR is not in operation.

#### Initiating Cue(s):

• You have been directed to place RHR B in Shutdown Cooling through E12-F053B, starting at Step 4.2.2c(12) of SOI 04-1-01-E12-2. Establish RHR flow with E12-F003B full open and E12-F048B full closed to maximize RPV cooldown rate.



JOB PERFORMANCE MEASURE

# **<u>E12 Task 1</u>**: Startup Shutdown Cooling B

#### **Notes**

- 1. All controls will be from panels P601 and P680 in the Main Control Room.
- 2. Unless otherwise indicated, all valves are in the "E12" system.

## Task Overview:

This task places the RHR system in service for Shutdown Cooling using the normal (E12-F053B) flowpath. This is a Tech Spec Decay Heat Removal method. Throttling of RHR Shutdown Cooling flow caused damage to RHR Instrumentation piping during RF12.



JOB PERFORMANCE MEASURE

# **<u>E12 Task 1</u>**: Startup Shutdown Cooling B

Tasks: critical tasks are underlined, italicized and denoted by (\*)

Note: Sequence is critical for critical tasks unless otherwise noted.

- € Place the RHR B MOV TEST switch in TEST <u>Standard</u>: Turns the RHR B MOV TEST switch clockwise until it snaps in the TEST position <u>Cue</u>: As Indicated <u>Notes</u>: Indication is on P601-17B. Will receive MOVS IN TEST Status Light and RHR B OOSVC annunciator.
- $\in$  Open or check open the following values:
  - € E12-F010 INLET TO SHUTDOWN COOLING
  - € <u>\* E12-F008 RHR SHUTDN CLG OTBD SUCT VLV</u>
  - € <u>\* E12-F009 RHR SHUTDN CLG INBD SUCT VLV</u>
  - € <u>\* E12-F006B RHR B PMP SUCT FM SHUTDN CLG</u>
  - € E12-F047B RHR HX INL VLV
  - € E12-F048B RHR HX BYP VLV
  - Standard: Checks open E12-F010; F047B on P601 by observing their red light on and their green light off. E12-F048B has a valve position indication meter on P601-17B to indicate 100%. OPENS E12-F008; F009 and F006B by turning their handswitches on P601 clockwise in the OPEN direction and observing its red light is on and its green light is off.

Cue: As Indicated

Notes: Valves are controlled from P601-17C



€ \* Close E12-F003B RHR <u>HX B OUTL VLV-</u>

Closes E12-F003B by turning its handswitch on P601 counter -Standard: clockwise in the CLOSE direction and holding while observing position indication meter on P601-17B lower to indicate 0%. As Indicated Cue:

Notes: Valve is controlled from P601-17C

€ \*Close or check closed B21-F065B FW INL SHUTOFF VLV Checks closed B21-F065B on P680 by observing its green light on and Standard: its red light off.

Cue: As Indicated Notes: Valve indication is located on P680-2C

#### NOTE: The Candidate should identify OPTION 1 is the method to be used per NOTE at step 4.2.2c(14).

NOTE: The following two steps have to be performed within 8 seconds to prevent causing E12-F064B from opening for minimum flow which would drain the RPV to the Suppression Pool.

€ \*Start RHR PMP B

> Starts RHR pump B by turning its handswitch on P601 clockwise in Standard: the START direction and observing its red light is on and its green light is off.

#### **As Indicated** Cue:

Notes: Pump handswitch is on P601-17C



ENTERGY NUCLEAR Number: GJPM-OPS-E1201 **Revision: 1** Page: 69 of 272

**JOB PERFORMANCE MEASURE** 

€ \* Open E12-F053B RHR B SHUTDN CLNGRTN TO FW Standard: Opens E12-F053B by turning its handswitch on P601 clockwise in the OPEN direction and holding it until its red light is on and its green light is off Cue: As Indicated Notes:

€ \* Slowly opens E12-F003B RHR HX B OUTL VLV

Slowly opens E12-F003B by turning its handswitch on P601 clockwise Standard: to jog the valve in the OPEN direction and while observing the valve position indication on P601-17B rise to indicate 100%.

Cue: As Indicated Notes: Candidate should observe RHR Flow on E12-R603B and temperatures on E12-R601.

NOTE: Due to current RPV temperature 100 degree F / Hr cooldown rate cannot be exceeded.

€ \* Slowly throttle E12-F048B RHR HX BYP VLV closed Throttles E12-F048B closed by turning its handswitch on P601 counter Standard: - clockwise in the CLOSE direction.

Cue: As indicated Notes: Indication on E12-R603B panel P601-17B



Number: GJPM-OPS-E1201 Revision: 1 Page: 70 of 272

JOB PERFORMANCE MEASURE

Task Standard(s):

Shutdown Cooling B is started IAW SOI 04-1-01-E12-1, with E12-F003B full open and E12-F048B full closed.

Name:	Time Start:	Time Stop:



JOB PERFORMANCE MEASURE

# **<u>E12 Task 1</u>**: Startup Shutdown Cooling B

Follow-Up Questions & Answers:

Comments:



# **Startup Shutdown Cooling B**

## Give this page to the student

Initial Condition(s):

- RHR A was previously in service for Shutdown Cooling but was secured.
- RHR B has been flushed, warmed up and is ready to be placed in Shutdown Cooling.
- SSW B is in operation.
- ADHR is not in operation.

#### Initiating Cue(s):

You have been directed to place RHR B in Shutdown Cooling through E12-F053B, • starting at Step 4.2.2c(12) of SOI 04-1-01-E12-2. Establish RHR flow with E12-F003B full open and E12-F048B full closed to maximize RPV cooldown rate.


ENTERGY NUCLEAR Number: GJPM-OPS-E2215 **Revision: 0** Page: 73 of 272

**JOB PERFORMANCE MEASURE** 

#### **TRAINING PROGRAM:**

### **OPERATOR TRAINING**

TITLE:

<b>Raise Suppression Pool Level using RCIC/HPCS</b>				
New Material	Minor Revision	Major Revision	Cancellation	
REASON FOR RE	VISION: New JPM <u>CREPLACES</u> : N/A			
<b>REVIEW / APPRO</b>	OVAL (Print Name): 🗌 Th	EAR Approval (TEAR #	)	
Prepared By:	**Preparer		Date	
Ops Review <sup>++:</sup>	Technical Reviewer (e.g., SME	line management)	Date	
Validated By:		· · · · · · · · · · · · · · · · · · ·		
4 J.D.	Training Represent	tative	Date	
Approved By:	<sup>+</sup> Discipline Training S	upervisor	Date	
Approval Date:*_				
* Indexing Information ** The requirements of the The	raining Material Checklist have been met.			

Indicates that the LP has been reviewed by the Training Supervisor for inclusion of Management Expectations and items referenced on TQJA-201- DD06, Training Material Checklist.

<sup>++</sup> Indicates that Operations has reviewed and approved this material for exam use.

#### FLEET/REGIONAL PROGRAM CONCURRENCE:

Fleet	ENS ENN	X Not Applicable		
DATE TRANSMITTED TO RM	INITIAL RECEIPT BY RM (DATE/INITIAL)	RETURNED FOR CORRECTIONS (DATE/INITIAL)	RETURN RECEIPT (DATE/INITIAL)	FINAL ACCEPTANCE BY RM (DATE/INITIALS)



# **Generic Instructions**

- 1. Standards and cues for valve operation:
  - a. MOVs:
    - "Turn the valve's handswitch on (panel #)(section#, as applicable) in the (clockwise or counter-clockwise) direction and observe that the valve's red light is (energized or de-energized) and its green light is (energized or de-energized)".
  - b. Manual valves
    - 1) "Turn the valve's handwheel (or other manual operating device) in the (clockwise or counter-clockwise) direction until resistance is felt."
- 2. The Evaluator should indicate simulated analog gauge readings by pointing a pen or equivalent to the intended place on the gauge.
- 3. Other methods of simulating control, operation and data collection is at the discretion of the Evaluator.
- 4. It is expected that the candidate shall locate controlled copies of any required procedures and describe how copies of these procedures would be prepared for use in the field. Only at this time should the evaluator give the candidate previously prepared copies of the procedure(s). This entire procedure need only be performed or simulated once during the entire exam. <u>These activities are not required for JPMs conducted in the Simulator</u>.
- 5. Consideration of electrical safety must be made during the performance of certain tasks involving electrical circuits and circuit breakers. The performer should be aware that working on or near energized equipment requires, at a minimum, wearing 100% cotton clothing and low voltage (Class 0) gloves while removing or securing shock hazards such as chains, jewelry, watches and metal-framed eyeglasses. Operating or racking circuit breakers may require additional PPE. Details can be found in Att. 2 of the Electrical Safety Rulebook and General Operating procedure 04-S-04-2 (Operation of Electrical Circuit Breakers)
- 6. Obtain Shift Management's permission before opening any control panel or compartment. Avoid placing any tools, flashlights, pointing devices or any part of your body inside the panel or compartment in a manner that could disturb the operation of any component within or potentially result in an electric shock).
- 7. Use of lasers as a pointing tool requires Engineering's prior approval of the specific tool for safe use in the Control area. (specifically, the laser's emissions must be verified as not interfering with any component's intended operation or function).
- 8. During activities within the CAA, consideration must be given to area dose rates. When in a posted Radiation Area, check your EAD for dose rates and minimize time spent in the area. Entry into High Radiation Areas or Contamination Areas is prohibited.

### Under no circumstances is any candidate allowed to operate any equipment outside the simulator without the permission of the Evaluator and Shift Management.



ENTERGY NUCLEAR Number: GJPM-OPS-E2215 **Revision: 0** Page: 75 of 272

**JOB PERFORMANCE MEASURE** 

#### **Raise Suppression Pool Level using** E22 Task 15: **RCIC/HPCS**

Setting:	Simulator
<u>Type</u> :	RO
Task:	CRO-E22-011; CRO-E51-016
<u>K&amp;A</u> :	223001 A2.11: 3.6/3.8; K1.13: 3.4/3.5; K1.14: 3.3/3.6
	209002 A1.05: 3.3/3.4; K1.01: 3.4/3.4; K1.02: 3.5/3.5;
	A4.01: 3.7/3.7; A4.02: 3.6/3.6; A4.14: 3.0/3.0
	217000 A4.03: 3.4/3.3
	295030 EA1.02: 3.4/3.5; EA1.03: 3.4/3.4
Safety Function:	5
Time Required:	10 minutes
Time Critical:	No
Faulted:	YES
Performance:	Actual
Reference(s):	04-1-01-E51-1; 04-1-01-E22-1; 05-1-01-EP-3
Handout(s):	04-1-01-E51-1; 04-1-01-E22-1
<u># Manipulations:</u>	8 or 9
# Critical Steps:	7 or 8
Group:	1/2

#### Simulator

Simulator Setups:

- ANY IC
- Lower Suppression Pool Water Level to 18.13 feet.
- Defeat Suppression Pool Makeup A & B
- Insert Malfuction e51187g on RCIC Minimum Flow Valve Closed (loss of power on stroke)

Safety Concerns:

None •



#### E22 Task 15: **Raise Suppression Pool Level using RCIC/HPCS**

Initial Condition(s):

- The plant is operating at 100% power. •
- Suppression Pool Water Level is low due to a leak in RHR C Pump Room. •
- Standby Service Water A is operating.
- Emergency Operating Procedure 3 has been entered.
- Suppression Pool Makeup is out of service. •

### Initiating Cue(s):

You have been directed to perform a controlled startup of RCIC and raise • Suppression Pool water level to the normal band using RCIC.

### Notes

1. All controls will be from panels P601 and P870 in the Main Control Room.

### **Task Overview:**

This task raises Suppression Pool Water Level using methods allowed per 05-1-01-EOP-3 using RCIC / HPCS.



#### **Raise Suppression Pool Level using** E22 Task 15: **RCIC/HPCS**

### Tasks: critical tasks are underlined, italicized and denoted by (\*)

Note : The sequence for the following steps is critical.

€ Start RCIC RM FAN COIL UNIT. Standard: Starts RCIC RM Fan Coil Unit by placing RCIC RM FAN COIL UNIT handswitch to the clockwise direction on P870 and observes red light on green light off. **Cue: As Indicated** Notes: Indication is on P870-1C.

€ Close E51-F268 PRESS LOCK ISOL FOR F013 Standard: Contacts Aux Bldg Operator to close E51-F268 PRESS LOCK ISOL FOR F013. Cue: E51-F268 is closed. Notes: Field operation.

€ \* Shift RCIC FLO CONT to MANUAL. Standard: Shifts RCIC FLO CONT to MANUAL by placing slide switch on controller to left for controller on P601. **Cue: As Indicated** Notes: Indication is on P601-21B.

€ \* Reduce RCIC FLO CONT output to minimum. Reduces RCIC FLO CONT to output to minimum by depressing left Standard: pushbutton on controller until horizontal meter reads zero on P601. **Cue: As Indicated** Notes: Indication is on P601-21B.



Number: GJPM-OPS-E2215 Revision: 0 Page: 78 of 272

JOB PERFORMANCE MEASURE

€ \* <u>Open E51-F046 RCIC WTR TO TURB LUBE OIL CLR</u>
 <u>Standard</u>: Opens E51-F046 by turning its handswitch on P601 clockwise in the OPEN direction and holding while observing red light on and green light off.
 <u>Cue</u>: As Indicated
 Notes: Valve is controlled from P601-21C

€ <u>\* Start Turbine Gland Seal Compressor using RCIC GL SEAL COMPR handswitch.</u> <u>Standard</u>: Starts RCIC Glans Seal Compressor by turning handswitch clockwise on P601 and observing red light on green light off.

<u>Cue</u>: As Indicated <u>Notes</u>: Indication is on P601-21C.

€ \* <u>Open E51-F095 RCIC STM SPLY BYP VLV</u>

<u>Standard</u>: Opens E51-F095 by turning its handswitch on P601 clockwise in the OPEN direction and holding while observing red light on and green light off.

Cue: As Indicated

Notes: Valve is controlled from P601-21C

NOTE: As soon as the candidate recognizes the failure of the Minimum Flow Valve, the candidate may proceed to secure the RCIC Turbine. If this is the case the following three steps will be N/A.

€ After 6 seconds open E51-F045 RCIC STM SPLY TO RCIC TURB <u>Standard</u>: After approximately 6 seconds E51-F045 by turning its handswitch on P601 clockwise in the OPEN direction and holding while observing red light on and green light off.

<u>Cue:</u> As Indicated Notes: Valve is controlled from P601-21C

NOTE: May not be performed is RCIC is tripped.



€ Raise RCIC Turbine speed to greater than 2000 rpm by opening on RCIC FLO CONT output. Standard: Raises RCIC Turbine speed to > 2000 rpm using RCIC FLO CONT by depressing the OPEN pushbutton and observing E51-R605 on section 21B of P601. **Cue: As Indicated** Notes: Indication is on P601-21B.

NOTE: May not be performed if RCIC is tripped. NOTE: The following steps may be performed in any order.

€ Open or check open E51-F019 RCIC MIN FLO to SUPP POOL Opens E51-F019 by turning its handswitch on P601 clockwise in the Standard: OPEN direction and holding while observing red light on and green light off. Cue: As Indicated Notes: Candidate should observe the valve loses power and fails to open. Valve is controlled from P601-21C

CUE: If asked by the candidate to check the valve circuit breaker, report as the Roving Operator circuit breaker 72-11A56 is in the TRIP FREE condition and there is a strange odor in the area.

Candidate should inform the Control Room Supervisor (CRS) of the problem. IF ASKED, <u>CUE</u> the candidate to secure the RCIC Turbine and raise Suppression Pool Level via the HPCS gravity flow. Once the RCIC Turbine is tripped another operator will complete the RCIC shutdown.

€ Close or check closed E51-F022 RCIC INBD TEST RTN TO CST Standard: Observes indication for E51-F022 as green light on red light off on P601.

As Indicated Cue: Notes: Valve is controlled from P601-21C NOTE: May not be performed.

€ Close or check closed E51-F059 RCIC OUTBD TEST RTN TO CST Observes indication for E51-F059 as green light on red light off on Standard: P601.

As Indicated Cue: Notes: Valve is controlled from P601-21C NOTE: May not be performed.



### Secure RCIC

- € Observe RCIC INIT RESET pushbutton white light is out. Observes RCIC INIT RESET pushbutton white light is out. Standard: **Cue: As Indicated.** Notes: Indication is on P601 section 21B. NOTE: May not be performed. This is acceptable.
- € Reduce RCIC flow to <100 gpm using RCIC FLO CONT. Standard: Reduces RCIC flow using RCIC FLO CONT. **Cue: As Indicated** Notes: Candidate may not perform, this step since there is no RCIC flow. This is acceptable.
- € Close E51-F013 RCIC INJ SHUTOFF VLV. Observes indication for E51-F013 closed as green light on red light off Standard: on P601. **Cue: As Indicated** Notes: Candidate may not perform, the valve was never opened. This is

# **RCIC** may be secured by option 1 or 2 either is acceptable. **Option 1 to secure RCIC**

€ \* <u>TRIP RCIC Turbine</u>

acceptable.

Trips the RCIC Turbine using the RCIC TURBINE TRIP pushbutton Standard: on P601 and observes green light on and red light off for the RCIC Trip Throttle valve.

#### As Indicated Cue:

Notes: Controlled from P601-21C



ENTERGY NUCLEAR Number: GJPM-OPS-E2215 **Revision: 0** Page: 81 of 272

**JOB PERFORMANCE MEASURE** 

### **Option 2 to secure RCIC**

- € \* <u>Close E51-F095 RCIC STM SPLY BYP VLV</u>
  - Standard: Closes E51-F095 by turning its handswitch on P601 counter-clockwise in the CLOSE direction and holding while observing green light on and red light off.

#### **As Indicated** Cue:

Notes: Valve is controlled from P601-21C

### € \* <u>Close E51-F045 RCIC STM SPLY TO RCIC TURB</u>

Closes E51-F045 by turning its handswitch on P601 counter-clockwise <u>Standar</u>d: in the CLOSE direction and holding while observing green light on and red light off.

#### As Indicated Cue:

Notes: Valve is controlled from P601-21C

ANOTHER OPERATOR WILL PICKUP THE RCIC OPERATIONS FROM HERE.

May need to cue the candidate to another operator securing RCIC and as Control Room Supervisor direct candidate to raise Suppression Pool Level via **HPCS gravity flow.** 



ENTERGY NUCLEAR Number: GJPM-OPS-E2215 **Revision: 0** Page: 82 of 272

**JOB PERFORMANCE MEASURE** 

### **HPCS Gravity Flow**

€ \* <u>Throttle open E22-F023HPCS TEST RTN TO SUPP POOL</u> Standard: Opens E22-F023 by turning its handswitch on P601 clockwise in the OPEN direction and holding while observing red light on and green light off. Cue: **As Indicated** Notes: Valve is controlled from P601-16C

€ Observes CST Level lowering and Suppression Pool Level rising on P870 Checks CST Level and Suppression Pool Level on P870. Standard:

### **Cue:** As Indicated

Notes: The candidate may use any of the following indications:

E30-LR-R600A	P870 4B Suppression Pool Level
E30-LR-R600B	P870 10B Suppression Pool Level
P11-LI-R601	P870 5B CST Level
SPDS for Suppress	ion Pool Level

### When Suppression Pool Level has been raised to the satisfaction of the Evaluator, the Evaluator may terminate the JPM.

Task Standard(s):

Suppression Pool level is rising using HPCS gravity flow.

Name:	Time Start:	Time Stop:	
		I	



Number: GJPM-OPS-E2215 Revision: 0 Page: 83 of 272

JOB PERFORMANCE MEASURE

# **<u>E22 Task 15</u>**: Raise Suppression Pool Level using RCIC/HPCS

Follow-Up Questions & Answers:

Comments:



### **Raise Suppression Pool Level using RCIC**

### Give this page to the student

Initial Condition(s):

- The plant is operating at 100% power.
- Suppression Pool Water Level is low due to a leak in RHR C Pump Room.
- Standby Service Water A is operating.
- Emergency Operating Procedure 3 has been entered.
- Suppression Pool Makeup is out of service.

<u>Initiating Cue(s)</u>:

• You have been directed to perform a controlled startup of RCIC and raise Suppression Pool water level to the normal band using RCIC.



#### **TRAINING PROGRAM:**

### **OPERATOR TRAINING**

TITLE:

### Align RWCU for Vessel Level Control

New Material	Minor Revision	Major Revision	Cancellation
REASON FOR RE' THIS DOCUMENT	VISION: NEW JP <u>CREPLACES</u> : N/A	M; Modified from GJPM-	RO-G3301.
REVIEW / APPRO	OVAL (Print Name):	TEAR Approval (TEAR #	)
Prepared By:	**Droporo	r	Data
Ops Review <sup>++:</sup>	Tachnical Paviawar (a.g. SM	I	Date
Validated By:	Training Panress		Date
Approved By:	Training Repress		Date
Approval Date:*	<sup>+</sup> Discipline Training	Supervisor	Date
* Indexing Information ** The requirements of the Th	raining Material Checklist have been m	et.	

Indicates that the LP has been reviewed by the Training Supervisor for inclusion of Management Expectations and items referenced on TQJA-201- DD06, Training Material Checklist.

<sup>++</sup> Indicates that Operations has reviewed and approved this material for exam use.

#### FLEET/REGIONAL PROGRAM CONCURRENCE:

Fleet	ENS ENN	Not Applicable		
DATE TRANSMITTED TO RM	INITIAL RECEIPT BY RM (DATE/INITIAL)	RETURNED FOR CORRECTIONS (DATE/INITIAL)	RETURN RECEIPT (DATE/INITIAL)	FINAL ACCEPTANCE BY RM (DATE/INITIALS)



# **Generic Instructions**

- 1. Standards and cues for valve operation:
  - a. MOVs:
    - "Turn the valve's handswitch on (panel #)(section#, as applicable) in the (clockwise or counter-clockwise) direction and observe that the valve's red light is (energized or de-energized) and its green light is (energized or de-energized)".
  - b. Manual valves
    - 1) "Turn the valve's handwheel (or other manual operating device) in the (clockwise or counter-clockwise) direction until resistance is felt."
- 2. The Evaluator should indicate simulated analog gauge readings by pointing a pen or equivalent to the intended place on the gauge.
- 3. Other methods of simulating control, operation and data collection is at the discretion of the Evaluator.
- 4. It is expected that the candidate shall locate controlled copies of any required procedures and describe how copies of these procedures would be prepared for use in the field. Only at this time should the evaluator give the candidate previously prepared copies of the procedure(s). This entire procedure need only be performed or simulated once during the entire exam. <u>These activities are not required for JPMs conducted in the Simulator</u>.
- 5. Consideration of electrical safety must be made during the performance of certain tasks involving electrical circuits and circuit breakers. The performer should be aware that working on or near energized equipment requires, at a minimum, wearing 100% cotton clothing and low voltage (Class 0) gloves while removing or securing shock hazards such as chains, jewelry, watches and metal-framed eyeglasses. Operating or racking circuit breakers may require additional PPE. Details can be found in Att. 2 of the Electrical Safety Rulebook and General Operating procedure 04-S-04-2 (Operation of Electrical Circuit Breakers)
- 6. Obtain Shift Management's permission before opening any control panel or compartment. Avoid placing any tools, flashlights, pointing devices or any part of your body inside the panel or compartment in a manner that could disturb the operation of any component within or potentially result in an electric shock).
- 7. Use of lasers as a pointing tool requires Engineering's prior approval of the specific tool for safe use in the Control area. (specifically, the laser's emissions must be verified as not interfering with any component's intended operation or function).
- 8. During activities within the CAA, consideration must be given to area dose rates. When in a posted Radiation Area, check your EAD for dose rates and minimize time spent in the area. Entry into High Radiation Areas or Contamination Areas is prohibited.

### Under no circumstances is any candidate allowed to operate any equipment outside the simulator without the permission of the Evaluator and Shift Management.



Number: GJPM-OPS-G3311 Revision: 00 Page: 87 of 272

JOB PERFORMANCE MEASURE

### **<u>G33 Task 11</u>**: Align RWCU for Vessel Level Control

Simulator
RO
CRO-G33/36-009
204000 A1.01 - 3.1/3.2; A1.04 - 2.8/2.8; A4.02 - 2.9/2.9
A4.06- 3.0/2.9
295008 AA1.02 - 3.3/3.3; AA2.03 - 2.9/3.0
2
15 minutes
No
YES
Actual
04-1-01-G33-1
04-1-01-G33-1
11
7
2

Simulator / Low Power

Simulator Setups:

- IC
- Ensure RWCU is operating in Pre-Pump mode.
- Ensure G33-F033 contrtoller G33-R606 is set at 0%.
- Insert malfunction
  - o di\_1G33-M612 P680/11C G33-F046 CLOSE
  - o di\_1G33-M625 P680/11C G33-F041 CLOSE

Safety Concerns:

• None



JOB PERFORMANCE MEASURE

### **<u>G33 Task 11</u>**: Align RWCU for Vessel Level Control

Initial Condition(s):

- The plant is in mode 2 with coolant temperature approximately \_140\_ degrees F.
- Plant startup is in progress.
- Component Cooling Water is in operation.
- RWCU is in Pre-Pump mode of operation with two pumps and two filters in service.
- Radiation Protection has been notified.

Initiating Cue(s):

- You have been directed to align RWCU for blowdown to the Main Condenser at 60 gpm.
- Other operators will control other plant parameters.



JOB PERFORMANCE MEASURE

### **<u>G33 Task 11</u>**: Align RWCU for Vessel Level Control

### **Notes**

1. All controls will be from panels P680 and P870 in the Main Control Room.

### **Task Overview:**

This task aligns Reactor Water Cleanup for reactor vessel level control using blowdown to the Main Condenser/Radwaste. This action is performed during reactor startup/heatup to control reactor water level.



JOB PERFORMANCE MEASURE

### **<u>G33 Task 11</u>**: Align RWCU for Vessel Level Control

**<u>Tasks</u>**: critical tasks are underlined, italicized and denoted by (\*)

Note: Sequence is critical for critical tasks unless otherwise noted.

Adjust G33-F033, RWCU SYS BLWDN F/D CONT VLV to 10 % open.
 Standard: Adjusts G33-F033 to 10% open on controller G33-R606 by placing the controller in MANUAL and opening to indicated 10% on the horizontal meter.
 Cue: As Indicated
 Notes: Indications are on P680 section 11D.

€ Place NSSSS INBD MOV TEST switch to TEST.
Standard: On P601 section 18B places the keylock switch for NSSSS INBD MOV TEST to TEST clockwise and observes annunciator "Rx Div 2 Isol Sys OOSVC" is received P601-19A-G3.
Cue: As Indicated Notes:

€\* <u>Open or check open G33-F028, RWCU BLWDN CTMT INBD ISOL.</u>
 <u>Standard</u>: Opens G33-F028, RWCU BLWDN CTMT INBD ISOL by rotating the key lock switch clockwise on P680 and observing red light on green light off.
 <u>Cue</u>: As Indicated
 <u>Notes</u>: Pushbutton is located on P680 section 11C.



Number: GJPM-OPS-G331 Revision: 00 Page: 91 of 272

JOB PERFORMANCE MEASURE

€ Place NSSSS OUTBD MOV TEST switch to TEST.
Standard: On P601 section 19B places the keylock switch for NSSSS OUTBD MOV TEST to TEST clockwise and observes annunciator "Rx Div 1 Isol Sys OOSVC" is received P601-19A-H3.
Cue: As Indicated Notes:

€\* Open or check open G33-F034, RWCU BLWDN CTMT OUTBD ISOL.
Standard: Opens G33-F034, RWCU BLWDN CTMT OUTBD ISOL by rotating the key lock switch clockwise on P680 and observing red light on green light off.
Cue: As Indicated
Notes: Pushbutton is located on P680 section 11C.

€\* Open or check open G33-F046, RWCU BLWDN TO MN CNDSR.
 Standard: Opens G33-F046, RWCU BLWDN TO MN CNDSR by depressing the OPEN pushbutton on P680 and observing red light on green light off.
 <u>Cue</u>: As Indicated Notes: Pushbutton is located on P680 section 11C.

G33-F046 will not change position when the pushbutton is depressed.

Candidate should inform the Control Room Supervisor of this malfunction. AS CRS, CUE candidate to attempt to use the BYPASS Valve G33-F041.



€\* Ope<u>n or check open G33-F041, RWCU BLWDN TO MN CNDSR BYP.</u> Opens G33-F041, RWCU BLWDN TO MN CNDSR BYP by Standard: depressing the OPEN pushbutton on P680 and observing red light on green light off. Cue: As Indicated Notes: Pushbutton is located on P680 section 11C.

G33-F041 will not change position when the pushbutton is depressed.

Candidate should inform the Control Room Supervisor of this malfunction. AS CRS, CUE candidate to change the flowpath to blowdown to Radwaste. Maintenance will be contacted to investigate the problems with G33-F041 and F046.

€\* Open G33-F035, RWCU BLWDN TO RADWST. Standard: Opens G33-F035, RWCU BLWDN TO RADWST by depressing the OPEN pushbutton on P680 and observing red light on green light off. Cue: **As Indicated** Notes: Pushbutton is located on P680 section 11C.

€\* Adjust G33-F033, RWCU SYS BLWDN F/D CONT VLV to attain 60 gpm flow as indicated on G33-FI-R602. Opening G33-F031, RWCU BLWDN ORF BYP VLV to obtain additional flow as necessary.

Standard: Adjusts G33-F033, RWCU SYS BLWDN F/D CONT VLV to attain 60 gpm flow as indicated on G33-FI-R602. Opening G33-F031, RWCU BLWDN ORF BYP VLV to obtain additional flow as necessary

#### **Cue: As Indicated**

Notes: Indications are on P680 section 11D.

Candidate may request permission to throttle G33-F042 closed to obtain desired flow. If so, CUE candidate to throttle G33-F042. Candidate may elect to open G33-F031 to obtain additional flow. Either of these methods are acceptable.



ENTERGY NUCLEAR Number: GJPM-OPS-G3311 **Revision: 00** Page: 93 of 272

**JOB PERFORMANCE MEASURE** 

€ Place NSSSS OUTBD MOV TEST switch to NORM. Standard: On P601 section 19B places the keylock switch for NSSSS OUTBD MOV TEST to NORM counter-clockwise and observes annunciator "Rx Div 1 Isol Sys OOSVC" clears P601-19A-H3. Cue: As Indicated Notes:

NOTE: Order between INBD and OUTBD is not essential.

€ Place NSSSS INBD MOV TEST switch to NORM. On P601 section 19B places the keylock switch for NSSSS INBD Standard: MOV TEST to NORM counter-clockwise and observes annunciator "Rx Div 2 Isol Sys OOSVC" clears P601-19A-G3. Cue: As Indicated Notes:

NOTE: Order between INBD and OUTBD is not essential.

Candidate may elect to leave MOV Test Switches in TEST. This is acceptable.

Task Standard(s):

RWCU is aligned to blow down the reactor to Radwaste at 60 gpm as indicated on G33-R602.

Name: \_\_\_\_\_\_Time Start: \_\_\_\_\_Time Stop: \_\_\_\_\_



JOB PERFORMANCE H MEASURE

# **<u>G33 Task 11</u>**: Align RWCU for Vessel Level Control

Follow-Up Questions & Answers:

Comments:



### **Align RWCU for Vessel Level Control**

### Give this page to the student

Initial Condition(s):

- The plant is in mode 2 with coolant temperature approximately \_140\_ degrees F.
- Plant startup is in progress.
- Component Cooling Water is in operation.
- RWCU is in Pre-Pump mode of operation with two pumps and two filters in service.
- Radiation Protection has been notified.

Initiating Cue(s):

- You have been directed to align RWCU for blowdown to the Main Condenser at 60 • gpm.
- Other operators will control other plant parameters.



#### **TRAINING PROGRAM:**

### **OPERATOR TRAINING**

TITLE:

Distribute Loads between ST-11 and ST-21				
New Material	Minor Revision	Major Revision	Cancellation	
REASON FOR REVISION:New JPMTHIS DOCUMENT REPLACES:N/A				
REVIEW / APPRO	OVAL (Print Name): 🗌 TH	EAR Approval (TEAR #	)	
Prepared By:	**Preparer		Date	
Ops Review <sup>++:</sup>	-			
Validated Rv•	Technical Reviewer (e.g., SME,	line management)	Date	
· unduced Dy · _	Training Represent	ative	Date	
Approved By:	<sup>+</sup> Discipline Training Su	ipervisor	Date	
Approval Date:*_	Discipline Training St		Suit	
* Indexing Information ** The requirements of the Tr	aining Material Checklist have been met.			

Indicates that the LP has been reviewed by the Training Supervisor for inclusion of Management Expectations and items referenced on TQJA-201- DD06, Training Material Checklist.

<sup>++</sup> Indicates that Operations has reviewed and approved this material for exam use.

#### FLEET/REGIONAL PROGRAM CONCURRENCE:

Fleet	ENS ENN	X Not Applicable		
DATE TRANSMITTED TO RM	INITIAL RECEIPT BY RM (DATE/INITIAL)	RETURNED FOR CORRECTIONS (DATE/INITIAL)	RETURN RECEIPT (DATE/INITIAL)	FINAL ACCEPTANCE BY RM (DATE/INITIALS)



# **Generic Instructions**

- 1. Standards and cues for valve operation:
  - a. MOVs:
    - "Turn the valve's handswitch on (panel #)(section#, as applicable) in the (clockwise or counter-clockwise) direction and observe that the valve's red light is (energized or de-energized) and its green light is (energized or de-energized)".
  - b. Manual valves
    - 1) "Turn the valve's handwheel (or other manual operating device) in the (clockwise or counter-clockwise) direction until resistance is felt."
- 2. The Evaluator should indicate simulated analog gauge readings by pointing a pen or equivalent to the intended place on the gauge.
- 3. Other methods of simulating control, operation and data collection is at the discretion of the Evaluator.
- 4. It is expected that the candidate shall locate controlled copies of any required procedures and describe how copies of these procedures would be prepared for use in the field. Only at this time should the evaluator give the candidate previously prepared copies of the procedure(s). This entire procedure need only be performed or simulated once during the entire exam. <u>These activities are not required for JPMs conducted in the Simulator</u>.
- 5. Consideration of electrical safety must be made during the performance of certain tasks involving electrical circuits and circuit breakers. The performer should be aware that working on or near energized equipment requires, at a minimum, wearing 100% cotton clothing and low voltage (Class 0) gloves while removing or securing shock hazards such as chains, jewelry, watches and metal-framed eyeglasses. Operating or racking circuit breakers may require additional PPE. Details can be found in Att. 2 of the Electrical Safety Rulebook and General Operating procedure 04-S-04-2 (Operation of Electrical Circuit Breakers)
- 6. Obtain Shift Management's permission before opening any control panel or compartment. Avoid placing any tools, flashlights, pointing devices or any part of your body inside the panel or compartment in a manner that could disturb the operation of any component within or potentially result in an electric shock).
- 7. Use of lasers as a pointing tool requires Engineering's prior approval of the specific tool for safe use in the Control area. (specifically, the laser's emissions must be verified as not interfering with any component's intended operation or function).
- 8. During activities within the CAA, consideration must be given to area dose rates. When in a posted Radiation Area, check your EAD for dose rates and minimize time spent in the area. Entry into High Radiation Areas or Contamination Areas is prohibited.

### Under no circumstances is any candidate allowed to operate any equipment outside the simulator without the permission of the Evaluator and Shift Management.



Number: GJPM-OPS-R2732 Revision: 0 Page: 98 of 272

JOB PERFORMANCE MEASURE

### **<u>R27 Task 32</u>**: Distribute Loads between ST-11 and ST-21

Setting:	Simulator
Type:	RO
<u>Task</u> :	CRO-R20/27-003; CRO-R20/27-008
<u>K&amp;A</u> :	262001 A4.01 – 3.4/3.7; A4.02 – 3.4/3.4; A4.04 – 3.6/3.7;
	A4.05 – 3.3/3.3; 2.1.30 – 3.9/3.4; 2.1.31 – 4.2/3.9
	295003 AA1.01 – 3.7/3.8; AA1.02 – 4.2/4.3; AA2.05 – 3.9/4.2
Safety Function:	6
Time Required:	30 minutes
Time Critical:	No
Faulted:	YES
Performance:	Actual
Reference(s):	04-1-01-R21-11; 04-1-01-R21-12; 04-1-01-R21-13;
	04-1-01-R21-14; 04-1-01-R21-15; 04-1-01-R21-16; 05-1-02-1-I-4
Handout(s):	04-1-01-R21-12; 04-1-01-R21-13; 04-1-01-R21-15
<u># Manipulations</u> :	14
<u># Critical Steps:</u>	13
Group:	1

Simulator

Simulator Setups:

- ANY IC
- Transfer 12HE; 13AD; and 15AA to ST-21
- In the computer cross tie 18AG and 28AG with 28AG supplying 18AG
- Insert Malfunction r21133b for Service Transformer 21 Lockout on Trigger 2
- Insert Malfunction n41140b for Diesel Generator 12 fail to start on Trigger 2

Safety Concerns:

• None



JOB PERFORMANCE MEASURE

### **<u>R27 Task 32</u>**: Distribute Loads between ST-11 and ST-21

Initial Condition(s):

- All electrical buses are being supplied from Service Transformer 21.
- Preventive maintenance on Service Transformer 11 is complete and Entergy Mississippi has released the transformer.
- GGNS 34.5 KV switchyard has been restored to a normal configuration with ESF and BOP Transformers energized.
- All Red Tags are cleared.
- All circuit breakers are racked in.

### Initiating Cue(s):

- You have been directed to align BOP buses 12HE, 13AD and 15AA in their normal configuration.
- Another operator will transfer bus 18AG.

### **Notes**

1. All controls will be from panels P864 and P807 in the Main Control Room.

### Task Overview:

This task transfers buses from all being supplied by a single Service Transformer to a preferred alignment. Following the transfer the on-coming Service Transformer will experience a lockout. Additionally the ESF bus will not be automatically energized by the Diesel Generator requiring operator action to align to an offsite power source.

This task implements SOER 2002-3 Large Power Transformer Reliability.



**MEASURE** 

### **Distribute Loads between ST-11 and ST-21 R27 Task 32:**

Tasks: critical tasks are underlined, italicized and denoted by (\*)

NOTE: The order in which buses are transferred/restored is NOT critical.

### **BUS 12HE**

- € Ensure XFMR 11B energized up to Bus Feeder Breaker 252-1201 by checking the following:
  - € Check closed disconnect J5234 FDR to XFMR ST-11 Standard: Observes disconnect indication on P807 for J5234 red light on green light off. **<u>Cue</u>:** As Indicated Notes: Indication is on P807-3B.
  - € Check closed circuit breaker 552-1105 XFMR ST-11 FDR to bus 11R Standard: Observes circuit breaker indication on P807 for 552-1105 red light on green light off. **Cue: As Indicated**

Notes: Indication is on P807-2C.

€ Check indicator R25-R603 34.5 bus voltage Standard: Observes indicator R25-R603 on P807 section 1B indicates approximately 34.5KV. **Cue: As Indicated** Notes: Indication is on P807-1B.

 $\in$  Check closed circuit breaker 552-1101 11R FDR to bus 12R Standard: Observes circuit breaker indication on P807 for 552-1101 red light on green light off. **Cue: As Indicated** Notes: Indication is on P807-1C.



Number: GJPM-OPS-R2732 Revision: 0 Page: 101 of 272

JOB PERFORMANCE MEASURE

 € Check closed disconnect 589-1101D BOP XFMR 11B disconnect <u>Standard</u>: Observes disconnect indication on P807 for 589-1101D red light on green light off.
 <u>Cue</u>: As Indicated Notes: Indication is on P807-1C.

€ Check ENERGIZED status light is on <u>Standard</u>: Observes ENERGIZED status light (purple light) is on for 252-1201 on P807.

<u>Cue</u>: As Indicated <u>Notes</u>: Indication is on P807-2C.

### € \* <u>Close 252-1201 XFMR 11B FDR to bus 12HE</u>

Standard: Closes circuit breaker 252-1201 by turning its handswitch on P807 clockwise in the CLOSE direction and holding while observing Red light on and green light off.

**<u>Cue</u>:** As Indicated <u>Notes</u>: Circuit Breaker is controlled from P807-2C

€ Observes circuit breaker 252-1208 opens

Standard: Checks circuit breaker 252-1208 opens on P807 by observing its green light on and its red light off.

Cue: As Indicated

Notes: Circuit breaker indication is located on P807-2C



Number: GJPM-OPS-R2732 Revision: 0 Page: 102 of 272

### JOB PERFORMANCE MEASURE

### **BUS 13AD**

- € Ensure XFMR 11A energized up to Bus Feeder Breaker 152-1315 by checking the following:
  - € Check closed disconnect J5234 FDR to XFMR ST-11 <u>Standard</u>: Observes disconnect indication on P807 for J5234 red light on green light off. Cue: As Indicated

### Cue: As Indicated

Notes: Indication is on P807-3B.

€ Check closed circuit breaker 552-1105 XFMR ST-11 FDR to bus 11R <u>Standard</u>: Observes circuit breaker indication on P807 for 552-1105 red light on green light off.

### Cue: As Indicated

Notes: Indication is on P807-2C.

 € Check indicator R25-R603 34.5 bus voltage <u>Standard</u>: Observes indicator R25-R603 on P807 section 1B indicates approximately 34.5KV.

 <u>Cue</u>: As Indicated Notes: Indication is on P807-1B.

€ Check closed circuit breaker 552-1101 11R FDR to bus 12R
 <u>Standard</u>: Observes circuit breaker indication on P807 for 552-1101 red light on green light off.
 <u>Cue</u>: As Indicated
 <u>Notes</u>: Indication is on P807-1C.



Number: GJPM-OPS-R2732 Revision: 0 Page: 103 of 272

JOB PERFORMANCE MEASURE

 € Check closed disconnect 589-1101C BOP XFMR 11A disconnect <u>Standard</u>: Observes disconnect indication on P807 for 589-1101C red light on green light off.
 <u>Cue</u>: As Indicated Notes: Indication is on P807-1C.

€ Check ENERGIZED status light is on <u>Standard</u>: Observes ENERGIZED status light (purple light) is on for 152-1315 on P807.

<u>Cue</u>: As Indicated <u>Notes</u>: Indication is on P807-1C.

### € \* <u>Close 152-1315 XFMR 11A FDR to bus 13AD</u>

Standard: Closes circuit breaker 152-1315 by turning its handswitch on P807 clockwise in the CLOSE direction and holding while observing Red light on and green light off.

<u>Cue:</u> As Indicated <u>Notes</u>: Circuit Breaker is controlled from P807-1C

€ Observes circuit breaker 152-1302 opens

Standard: Checks circuit breaker 152-1302 opens on P807 by observing its green light on and its red light off.

Cue: As Indicated

Notes: Circuit breaker indication is located on P807-1C



Number: GJPM-OPS-R2732 Revision: 0 Page: 104 of 272

### JOB PERFORMANCE MEASURE

### **BUS 15AA**

- € Ensure XFMR ESF 11 energized up to Bus Feeder Breaker 152-1514 by checking the following:
  - € Check closed disconnect J5234 FDR to XFMR ST-11
    <u>Standard</u>: Observes disconnect indication on P807 for J5234 red light on green light off.
    <u>Cue: As Indicated</u>

Notes: Indication is on P807-3B.

€ Check closed circuit breaker 552-1105 XFMR ST-11 FDR to bus 11R <u>Standard</u>: Observes circuit breaker indication on P807 for 552-1105 red light on green light off.

<u>Cue</u>: As Indicated Notes: Indication is on P807-2C.

 € Check indicator R25-R603 34.5 bus voltage <u>Standard</u>: Observes indicator R25-R603 on P807 section 1B indicates approximately 34.5KV.

 <u>Cue</u>: As Indicated Notes: Indication is on P807-1B.

€ Check closed circuit breaker 552-1104 11R FDR to XFMR ESF11
 <u>Standard</u>: Observes circuit breaker indication on P807 for 552-1104 red light on green light off.
 <u>Cue</u>: As Indicated
 <u>Notes</u>: Indication is on P807-1C.



Number: GJPM-OPS-R2732 Revision: 0 Page: 105 of 272

JOB PERFORMANCE MEASURE

€ Check closed circuit breaker 152-1901 FDR FRM XFMR ESF 11
 <u>Standard</u>: Observes circuit breaker indication on P807 for 152-1901 red light on green light off.
 <u>Cue</u>: As Indicated
 Notes: Indication is on P807-1C.

 € Check ENERGIZED status light is on <u>Standard</u>: Observes ENERGIZED status light (purple light) is on for 152-1514 on P864.
 <u>Cue</u>: As Indicated Notes: Indication is on P864-1C.

€ \* <u>Turn on the Sync switch for breaker 152-1514 BUS 15AA FDR FRM XFMR ESF 11</u> <u>Standard</u>: Turns on Sync Switch for 152-1514 by turning its handswitch on P864 clockwise in the ON direction.

Cue:As IndicatedNotes:Sync Switch is controlled from P864-1C

€ Check sync scope comes to 12 o'clock ± 10°. <u>Standard</u>: Observes sync scope comes to 12 o'clock ± 10° on for 152-1514 on P864.

<u>Cue</u>: As Indicated <u>Notes</u>: Indication is on P864-1B.



€ \* <u>Close 152-1514 BUS 15AA FDR FRM XFMR ESF 11</u>

Standard: Closes circuit breaker 152-1514 by turning its handswitch on P864 clockwise in the CLOSE direction and holding while observing Red light on and green light off.

#### As Indicated Cue:

Notes: Circuit Breaker is controlled from P864-1C

- € Observes circuit breaker 152-1511 opens Checks circuit breaker 152-1511 opens on P864 by observing its green Standard: light on and its red light off. **<u>Cue</u>:** As Indicated Notes: Circuit breaker indication is located on P864-1C
- € Turn off the Sync switch for breaker 152-1514 BUS 15AA FDR FRM XFMR ESF 11 Turns off Sync Switch for 152-1514 by turning its handswitch on P864 Standard: counter-clockwise in the OFF direction.

As Indicated Cue:

Notes: Sync Switch is controlled from P864-1C



### ONCE the third bus is transferred (12HE, 13AD and 15AA), INSERT malfunctions on Trigger 1. r21133b – Lockout Service Transformer 21 n41140b – Failure of Diesel Generator 12 (Division 2 DG)

This results in a loss of power to buses 11HD, 14AE, 16AB, and 17AC.

Bus 17AC will automatically re-energize from DG-13.

Per the Loss of AC Power ONEP (05-1-02-I-4) re-energize buses from available offsite feeders and/or DG.

The order of bus re-energization is NOT Critical.



Number: GJPM-OPS-R2732 Revision: 0 Page: 108 of 272

### JOB PERFORMANCE MEASURE

### **BUS 11HD**

- € Ensure XFMR 11B energized up to Bus Feeder Breaker 252-1101 by checking the following:
  - € Check closed disconnect J5234 FDR to XFMR ST-11 <u>Standard</u>: Observes disconnect indication on P807 for J5234 red light on green light off.

### Cue: As Indicated

Notes: Indication is on P807-3B.

€ Check closed circuit breaker 552-1105 XFMR ST-11 FDR to bus 11R <u>Standard</u>: Observes circuit breaker indication on P807 for 552-1105 red light on green light off.

### Cue: As Indicated

Notes: Indication is on P807-2C.

 € Check indicator R25-R603 34.5 bus voltage <u>Standard</u>: Observes indicator R25-R603 on P807 section 1B indicates approximately 34.5KV.

 <u>Cue</u>: As Indicated Notes: Indication is on P807-1B.

€ Check closed circuit breaker 552-1101 11R FDR to bus 12R
 <u>Standard</u>: Observes circuit breaker indication on P807 for 552-1101 red light on green light off.
 <u>Cue</u>: As Indicated
 <u>Notes</u>: Indication is on P807-1C.


## ENTERGY NUCLEAR Number: GJPM-OPS-R2732

Number: GJPM-OPS-R2732 Revision: 0 Page: 109 of 272

JOB PERFORMANCE MEASURE

 € Check closed disconnect 589-1101D BOP XFMR 11B disconnect <u>Standard</u>: Observes disconnect indication on P807 for 589-1101D red light on green light off.
 <u>Cue</u>: As Indicated Notes: Indication is on P807-1C.

€ Check ENERGIZED status light is on
 <u>Standard</u>: Observes ENERGIZED status light (purple light) is on for 252-1101 on P807.
 Cue: As Indicated

<u>Notes</u>: Indication is on P807-1C.

NOTE: Candidate may go directly to breaker 252-1101 handswitch and energize the bus.

# € \* <u>Close 252-1101 XFMR 11B FDR to bus 11HD</u>

Standard: Closes circuit breaker 252-1101 by turning its handswitch on P807 clockwise in the CLOSE direction and holding while observing Red light on and green light off.

### Cue: As Indicated

Notes: Circuit Breaker is controlled from P807-1C

€ Observes circuit breaker 252-1108 opens

Standard: Checks circuit breaker 252-1108 opens on P807 by observing its green light on and its red light off.

### Cue: As Indicated

Notes: Circuit breaker indication is located on P807-1C



### ENTERGY NUCLEAR

JOB PERFORMANCE MEASURE

€ \* <u>Close supply circuit breakers for the following Load Control Centers (LCC):</u>

- <u> \*LCC 11BD7\_breaker 52-11701</u>
- <u>+LCC 11BD4\_breaker 52-11401</u>
- \*<u>LCC 11BD3\_breaker 52-11301</u>
- <u> \*LCC 11BD2\_breaker 52-11201</u>
- \*<u>LCC 21BD4 breaker 52-21401</u>
- \_\_\_\_\_\*<u>LCC 21BD3\_breaker 52-21301</u>
- Standard: Closes the above circuit breakers on H13-P807 by placing the handswitch clockwise in the CLOSE direction and holding while observing red light on and green light off.

### Cue: As Indicated

Notes: Circuit Breakers are controlled from P807



### ENTERGY NUCLEAR Number: GJPM-OPS-R2732

Number: GJPM-OPS-R2732 Revision: 0 Page: 111 of 272

## JOB PERFORMANCE MEASURE

# **BUS 14AE**

- € Ensure XFMR 11A energized up to Bus Feeder Breaker 152-1415 by checking the following:
  - € Check closed disconnect J5234 FDR to XFMR ST-11
    <u>Standard</u>: Observes disconnect indication on P807 for J5234 red light on green light off.
    <u>Cue: As Indicated</u>

# Notes: Indication is on P807-3B.

€ Check closed circuit breaker 552-1105 XFMR ST-11 FDR to bus 11R <u>Standard</u>: Observes circuit breaker indication on P807 for 552-1105 red light on green light off.

# <u>Cue</u>: As Indicated

Notes: Indication is on P807-2C.

 € Check indicator R25-R603 34.5 bus voltage <u>Standard</u>: Observes indicator R25-R603 on P807 section 1B indicates approximately 34.5KV.

 <u>Cue</u>: As Indicated Notes: Indication is on P807-1B.

€ Check closed circuit breaker 552-1101 11R FDR to bus 12R
 <u>Standard</u>: Observes circuit breaker indication on P807 for 552-1101 red light on green light off.
 <u>Cue</u>: As Indicated
 <u>Notes</u>: Indication is on P807-1C.



# ENTERGY NUCLEAR Number: GJPM-OPS-R2732

Number: GJPM-OPS-R2732 Revision: 0 Page: 112 of 272

JOB PERFORMANCE MEASURE

 € Check closed disconnect 589-1101C BOP XFMR 11A disconnect <u>Standard</u>: Observes disconnect indication on P807 for 589-1101C red light on green light off.
 <u>Cue</u>: As Indicated Notes: Indication is on P807-1C.

 € Check ENERGIZED status light is on <u>Standard</u>: Observes ENERGIZED status light (purple light) is on for 152-1415 on P807.
 Cue: As Indicated

<u>Notes</u>: Indication is on P807-2C.

NOTE: Candidate may go directly to breaker 252-1101 handswitch and energize the bus.

# € \* <u>Close 152-1415 XFMR 11A FDR to bus 14AE</u>

Standard: Closes circuit breaker 152-1415 by turning its handswitch on P807 clockwise in the CLOSE direction and holding while observing Red light on and green light off.

### Cue: As Indicated

Notes: Circuit Breaker is controlled from P807-2C

€ Observes circuit breaker 152-1402 opens

Standard: Checks circuit breaker 152-1402 opens on P807 by observing its green light on and its red light off.

### Cue: As Indicated

Notes: Circuit breaker indication is located on P807-2C



**JOB PERFORMANCE MEASURE** 

# **BUS 16AB**

# There are two options for the candidate. Either Option is acceptable.

# **Option 1 ESF Transformer 11**

€ Ensure XFMR ESF 11 energized up to Bus Feeder Breaker 152-1601 by checking the following:

€ Check closed disconnect J5234 FDR to XFMR ST-11 Standard: Observes disconnect indication on P807 for J5234 red light on green light off.

### **<u>Cue</u>: As Indicated**

Notes: Indication is on P807-3B.

 $\in$  Check closed circuit breaker 552-1105 XFMR ST-11 FDR to bus 11R Standard: Observes circuit breaker indication on P807 for 552-1105 red light on green light off.

### **Cue: As Indicated**

Notes: Indication is on P807-2C.

€ Check indicator R25-R603 34.5 bus voltage Standard: Observes indicator R25-R603 on P807 section 1B indicates approximately 34.5KV.

# **Cue: As Indicated**

Notes: Indication is on P807-1B.

 $\in$  Check closed circuit breaker 552-1104 11R FDR to XFMR ESF11 Standard: Observes circuit breaker indication on P807 for 552-1104 red light on green light off.

### **Cue: As Indicated**

Notes: Indication is on P807-1C.



ENTERGY NUCLEAR Number: GJPM-OPS-R2732 **Revision: 0** Page: 114 of 272

**JOB PERFORMANCE MEASURE** 

€ Check closed circuit breaker 152-1901 FDR FRM XFMR ESF 11 Standard: Observes circuit breaker indication on P807 for 152-1901 red light on green light off. **<u>Cue</u>:** As Indicated Notes: Indication is on P807-1C.

€ Check ENERGIZED status light is on Standard: Observes ENERGIZED status light (purple light) is on for 152-1601 on P864. Cue: As Indicated Notes: Indication is on P864-2C.

€ \* <u>Close 152-1601 BUS 16AB FDR FRM XFMR ESF 11</u>

Standard: Closes circuit breaker 152-1601 by turning its handswitch on P864 clockwise in the CLOSE direction and holding while observing Red light on and green light off.

As Indicated Cue:

Notes: Circuit Breaker is controlled from P864-2C



ENTERGY NUCLEAR Number: GJPM-OPS-R2732 **Revision: 0** Page: 115 of 272

**JOB PERFORMANCE MEASURE** 

# **Option 2 ESF Transformer 12**

- € Ensure XFMR ESF 12 energized up to Bus Feeder Breaker 152-1611 by checking the following:
  - € Check closed disconnect J3885 FDR to XFMR ESF 12 Standard: Observes disconnect indication on P807 for J3885 red light on green light off.

# Cue: As Indicated

Notes: Indication is on P807-1C.

€ Check closed circuit breaker 152-1903 FDR FRM XFMR ESF 12 Standard: Observes circuit breaker indication on P807 for 152-1903 red light on green light off. Cue: As Indicated

Notes: Indication is on P807-1C.

€ Check ENERGIZED status light is on Standard: Observes ENERGIZED status light (purple light) is on for 152-1611 on P864. Cue: As Indicated

Notes: Indication is on P864-2C.

# € \* <u>Close 152-1611 BUS 16AB FDR FRM XFMR ESF 12</u>

Standard: Closes circuit breaker 152-1611 by turning its handswitch on P864 clockwise in the CLOSE direction and holding while observing Red light on and green light off.

#### <u>Cu</u>e: **As Indicated**

Notes: Circuit Breaker is controlled from P864-2C



**JOB PERFORMANCE MEASURE** 

€ Orders Turbine Building Operator to reset Bus Undervoltage Lockouts for BOP Buses 11HD and 14AE Standard: Contacts Turbine Building Operator to reset Bus Undervoltage Lockouts for buses 11HD and 14AE Cue: **Turbine Building Operator is dispatched.** Notes: This action may be performed any time after the buses have been reenergized.

Task Standard(s):

BOP Buses 11HD & LCCs, 12HE, 13AD and 14AE are energized from Service Transformer 11 ESF Bus 15AA is energized from ESF Transformer 11. ESF Bus 16AB is energized from either ESF Transformer 11 or 12. ESF Bus 17AC is energized from Diesel Generator 13.

Name: \_\_\_\_\_\_Time Start: \_\_\_\_\_Time Stop: \_\_\_\_\_



**JOB PERFORMANCE MEASURE** 

#### **R27 Task 32: Distribute Loads between ST-11 and ST-21**

Follow-Up Questions & Answers:

Comments:



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-ADM-11

 Revision: 00

 Page: 118 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_\_

# **Distribute Loads between ST-11 and ST-21**

# Give this page to the student

Initial Condition(s):

- All electrical buses are being supplied from Service Transformer 21.
- Preventive maintenance on Service Transformer 11 is complete and Entergy Mississippi has released the transformer.
- GGNS 34.5 KV switchyard has been restored to a normal configuration with ESF and BOP Transformers energized.
- All Red Tags are cleared.
- Allcircuit breakers are racked in.

<u>Initiating Cue(s)</u>:

- You have been directed to align BOP buses 12HE, 13AD and 15AA in their normal configuration.
- Another operator will transfer bus 18AG.



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-ADM-11

 Revision: 00

 Page: 119 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

**TRAINING PROGRAM:** 

# **OPERATIONS TRAINING**

\*LESSON PLAN TITLE:

Determine Shift Staffing to Meet Shift Requirements						
APPROXIMATE TIME	REQUIRED: 15 Minut	es				
PREREQUISITES: NO	NE					
SUPPORTING LESSO	NS: NONE					
	🛛 New Material	Minor Revision	Major Revision			
REASON FOR REVISION: New JPM						
REVIEW / APPROVAL (Print Name):  Electronic Approval (TEAR #)						
Prepared By:						
		Preparer	Date			
<b>Reviewed By:</b>						
Instructional Adequacy Determined Bv:	Technical Reviewer (	e.g., SME, line management)	Date			
	ITPL (Rev 0); Qualified	d Instructor (All other revisions)	Date			
Approved By:						
,	++Discipline	Training Supervisor	Date			
Effective Date:		*Date	_			

<sup>†</sup>Indicates that the LP has been reviewed by the Training Supervisor for inclusion of Management Expectations and items referenced on the Training Development Review Worksheet

# FLEET/REGIONAL PROGRAM CONCURRENCE:

ANO	PNPS	
CNPS	RBS	
ECH	VY	
GGNS	WF3	
IPEC	WPO	
JAF		

\* Indexing Information



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-ADM-11

 Revision: 00

 Page: 120 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

# **Generic Instructions**

- 1. Standard cues for valve operation:
  - a. MOVs:
    - 1) "Full open" = "red light on, green light off"
    - 2) "Full closed" = "red light off, green light on"
  - b. Manual valves
    - 1) "Full open" = "you feel resistance in the counter-clockwise direction"
    - 2) "Full closed" = "you feel resistance in the clockwise direction"

2. The Evaluator should indicate simulated analog gauge readings by pointing a pen or equivalent to the intended place on the gauge.

3. Other methods of simulating control, operation and data collection is at the discretion of the Evaluator.

4. Obtain Shift Management's permission before opening any control panel door or instrument cover.

5 It is expected that the candidate shall locate controlled copies of any required procedures and describe how copies of these procedures would be prepared for use in the field. Only at this time should the evaluator give the candidate previously prepared copies of the procedure(s). This entire procedure need only be performed or simulated once during the entire exam. <u>These activities are not required for JPMs</u> <u>conducted in the Simulator</u>.

6. Consideration of electrical safety must be made during the performance of certain tasks involving electrical circuits and circuit breakers. The performer should be aware that working on or near energized equipment requires, at a minimum, wearing 100% cotton clothing and low voltage (Class 0) gloves while removing or securing shock hazards such as chains, jewelry, watches and metal-framed eyeglasses. Operating or racking circuit breakers may require additional PPE. Details can be found in Att. 2 of the Electrical Safety Rulebook and General Operating procedure 04-S-04-2 (Operation of Electrical Circuit Breakers)

# Under no circumstances is any candidate allowed to operate any equipment outside the simulator without the permission of the Evaluator and Shift Management.



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-ADM-11

 Revision: 00

 Page: 121 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

# ADMIN Task 11: Determine Shift Staffing to Meet Shift Requirements

Setting:	Classroom
Type:	SRO
Task:	SRO-NO-032
<u>K&amp;A</u> :	Generic 2.1.4: 3.4
Safety Function:	N/A
Time Required:	15 minutes
Time Critical:	No
Faulted:	No
Performance:	Perform
Reference(s):	Nuclear Management Manual EN-OP-115 Conduct of Operations.
	OPG-35 Operator Qualification Verification
Handout(s):	None
<u># Manipulations</u> :	N/A
# Critical Steps:	Option 1 – 20 Option 2 - 18
<u>Group #</u> :	N/A

### **ADMINISTRATIVE JPM / SRO LEVEL**

Simulator Setup/Required Plant Conditions: None.

Safety Concerns: None.

Equipment Needed: Computer with Entergy Internet Access



JOB PERFORMANCE MEASURE Number: GJPM-SRO-ADM-11 Revision: 00 Page: 122 of 272 Rtype: \_\_\_\_\_ QA Record Number of pages \_\_\_\_\_ Date \_\_\_\_\_ Initials \_\_\_\_\_

# ADMIN Task 11: Determine Shift Staffing to Meet Shift Requirements

### Initial Condition(s):

- The Plant is operating at 100% power.
- An operator has called in sick.
- Your shift is below minimum Fire Brigade staffing.

#### Initiating Cue(s):

- You are the Control Room Supervisor.
- Determine whether the following operator to be called in meets the requirements to be your replacement Fire Brigade Member USING ON-TRACK ONLINE.

#### Gary W. Carter

• You already have a Fire Brigade Leader and three other members.



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-ADM-11

 Revision: 00

 Page: 123 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

# ADMIN Task 11: Determine Shift Staffing to Meet Shift Requirements

# <u>Notes</u>

1. This is an Administrative JPM.

**Task Overview:** This task is to determine the staffing qualifications of an oncoming operator for fire brigade status per Nuclear Management Manual EN-OP-115 Conduct of Operations. It is the responsibility of the Control Room Supervisor to ensure he has sufficient qualified personnel for plant operations.

<u>**Task Justification:**</u> This task is performed at least weekly by Control Room Supervisors. This is an Administrative JPM.

# Tasks: Critical tasks are underlined, italicized, and denoted by (\*).

For logging into ON-TRACK ONLINE there are two options either is acceptable.

# **OPTION 1**

- Log into the Entergy network.
   Standard: Logs onto the Entergy Network from any network computer.
   Cue: None.
   Notes:
- □\* <u>Select the GGNS Home Page.</u>
   <u>Standard:</u> Selects the GGNS Home Page.
   Cue: None.
   Notes:



 Number: GJPM-SRO-ADM-11

 Revision: 00

 Page: 124 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

JOB PERFORMANCE MEASURE

- □\* <u>Select DEPARTMENTS.</u> <u>Standard:</u> Select DEPARTMENTS. Cue: None. Notes: Left side of the screen
- □\* <u>Select TRAINING.</u> <u>Standard:</u> Selects TRAINING. Cue: None. Notes: Left side of the screen

# **OPTION 2**

- □\* <u>Select START.</u> <u>Standard:</u> Selects START. Cue: None. Notes: Bottom left of the screen
- □\* <u>Select NUCLEAR CORPORATE APPS.</u>
   <u>Standard:</u> Selects NUCLEAR CORPORATE APPS.
   Cue: None.
   Notes: Drop down menu



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-ADM-11

 Revision: 00

 Page: 125 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_\_

# **COMMON**

- □\* Select ON-TRACK ONLINE.
   Standard: Selects ON-TRACK ONLINE.
   Cue: None.
   Notes: Quick link highlighted in blue or listed under Nuclear Corporate Apps
- □\* <u>Select SUPERVISOR FUNCTIONS.</u> <u>Standard:</u> Selects SUPVERVISOR FUNCTIONS. Cue: None. Notes: top bar.
- □\* Login with Network ID and password is SSN
   Standard: Logsin with Network ID and password is SSN.
   Cue: None.
   Notes: Candidate may need prompting of this. This is acceptable.
- □\* <u>Select FIND STAFF.</u> <u>Standard:</u> Selects FIND STAFF. Cue: None. Notes: folders on left
- □\* <u>Select BY DEVELOPMENT PLAN.</u>
   <u>Standard:</u> Selects BY DEVELOPMENT PLAN.
   Cue: None.
   Notes: folder under FIND STAFF.



Number: GJPM-SRO-ADM-11 Revision: 00 Page: 126 of 272 Rtype: \_\_\_\_\_ QA Record Number of pages \_\_\_\_\_ Date Initials

JOB PERFORMANCE MEASURE

□\* <u>Select SELECT DEVELOPMENT PROGRAM AREA.</u>
 <u>Standard:</u> Selects SELECT DEVELOPMENT PROGRAM AREA.
 Cue: None.
 Notes: Tab in main screen.

- □\* <u>Select FIRE PROTECTION.</u>
   <u>Standard:</u> Selects FIRE PROTECTION.
   Cue: None.
   Notes: Drop down menu under SELECT DEVELOPMENT PROGRAM AREA.
- □\* <u>Select GRAND GULF.</u>
   <u>Standard:</u> Selects GRAND GULF.
   Cue: None.
   Notes: Drop down menu under FIRE PROTECTION.
- □\* <u>Select G-FIRE-FB-FIRE BRIGADE.</u>
   <u>Standard:</u> Selects G-FIRE-FB-FIRE BRIGADE.
   Cue: None.
   Notes: Drop down menu under SELECT DEVELOPMENT PROGRAM AREA.
- □\* <u>Select CARTER, GARY W.</u>
   <u>Standard:</u> Selects CARTER, GARY W.
   Cue: None.
   Notes: Drop down menu under SELECT DEVELOPMENT PROGRAM AREA.

### The following steps are NOT sequence critical.

□\* <u>Select UNIT – Fire Brigade Classroom Training and checks Complete Next Dates.</u>
 <u>Standard:</u> Selects UNIT – Fire Brigade Classroom Training and checks Complete Next Dates.
 Cue: None.
 Notes: dates on the screen should be acceptable.



# JOB PERFORMANCE MEASURE

 Number: GJPM-SRO-ADM-11

 Revision: 00

 Page: 127 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

- Select UNIT Respiratory Protection Training and checks Complete Next Dates.
   Standard: Selects UNIT Respiratory Protection Training and checks Complete Next Dates.
   Cue: None.
   Notes: dates on the screen should be acceptable.
- □\* <u>Select UNIT Fire Brigade Physical and checks Complete Next Dates.</u>
   <u>Standard:</u> Selects UNIT Fire Brigade Physical and checks Complete Next Dates.
   Cue: None.
   Notes: dates on the screen should be acceptable.
- Select UNIT Quarterly Meetings and checks Complete Next Dates.
   Standard: Selects UNIT Quarterly Meetings and checks Complete Next Dates.
   Cue: None.
   Notes: dates on the screen should be acceptable.
- □\* <u>Select UNIT Fire Drills and checks Complete Next Dates.</u>
   <u>Standard:</u> Selects UNIT Fire Drills and checks Complete Next Dates.
   Cue: None.
   Notes: dates on the screen should be acceptable.
- □\* <u>Select UNIT Fire Brigade Practice Session and checks Complete Next Dates.</u>
   <u>Standard:</u> Selects UNIT Fire Brigade Practice Session and checks Complete Next Dates.
   Cue: None.
   Notes: dates on the screen should be acceptable.

#### Task Standard(s):

Determines Gary W. Carter is Fire Brigade Qualified.

Name:	Time Start:	Time Stop:
-------	-------------	------------



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-ADM-11

 Revision: 00

 Page: 128 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

# ADMIN Task 11: Determine Shift Staffing to Meet Shift Requirements

Follow-Up Questions & Answers:

Comments:



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-ADM-12

 Revision: 00

 Page: 129 of 8

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_\_

# **Determine Shift Staffing to Meet Shift Requirements**

# Give this page to the student

Initial Condition(s):

- The Plant is operating at 100% power.
- An operator has called in sick.
- Your shift is below minimum Fire Brigade staffing.

#### Initiating Cue(s):

- You are the Control Room Supervisor.
- Determine whether the following operator to be called in meets the requirements to be your replacement Fire Brigade Member USING ON-TRACK ONLINE.
- •

#### Gary W. Carter

• You already have a Fire Brigade Leader and three other members.



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-ADM-12

 Revision: 00

 Page: 130 of 8

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

**TRAINING PROGRAM:** 

# **OPERATIONS TRAINING**

\*LESSON PLAN TITLE:

# DETERMINE THE PLANT EOOS FACTOR

#### APPROXIMATE TIME REQUIRED: 10 Minutes

PREREQUISITES: NONE

SUPPORTING LESSONS: NONE

New Material

Minor Revision

Major Revision

#### **REASON FOR REVISION:**

New JPM; Modified from GJPM-SRO-ADM04

REVIEW / APPROVAL (Print Name): 
Electronic Approval (TEAR #

Prepared By:		
· · · · · ·	Preparer	Date
Reviewed By:		
Instructional Adequacy Determined By:	Technical Reviewer (e.g., SME, line management)	Date
Approved Bv:	ITPL (Rev 0); Qualified Instructor (All other revisions)	Date
	**Discipline Training Supervisor	Date
Effective Date:	*Date	

Indicates that the LP has been reviewed by the Training Supervisor for inclusion of Management Expectations and items referenced on the Training Development Review Worksheet

#### 

		able	
ANO		PNPS	
CNPS		RBS	
ECH		VY	
GGNS		WF3	
IPEC		WPO	
JAF			

\* Indexing Information



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-ADM-12

 Revision: 00

 Page: 131 of 8

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_\_

# **Generic Instructions**

- 1. Standard cues for valve operation:
  - a. MOVs:
    - 1) "Full open" = "red light on, green light off"
    - 2) "Full closed" = "red light off, green light on"
  - b. Manual valves
    - 1) "Full open" = "you feel resistance in the counter-clockwise direction"
    - 2) "Full closed" = "you feel resistance in the clockwise direction"

2. The Evaluator should indicate simulated analog gauge readings by pointing a pen or equivalent to the intended place on the gauge.

3. Other methods of simulating control, operation and data collection is at the discretion of the Evaluator.

4. Obtain Shift Management's permission before opening any control panel door or instrument cover.

5 It is expected that the candidate shall locate controlled copies of any required procedures and describe how copies of these procedures would be prepared for use in the field. Only at this time should the evaluator give the candidate previously prepared copies of the procedure(s). This entire procedure need only be performed or simulated once during the entire exam. <u>These activities are not required for JPMs</u> conducted in the Simulator.

6. Consideration of electrical safety must be made during the performance of certain tasks involving electrical circuits and circuit breakers. The performer should be aware that working on or near energized equipment requires, at a minimum, wearing 100% cotton clothing and low voltage (Class 0) gloves while removing or securing shock hazards such as chains, jewelry, watches and metal-framed eyeglasses. Operating or racking circuit breakers may require additional PPE. Details can be found in Att. 2 of the Electrical Safety Rulebook and General Operating procedure 04-S-04-2 (Operation of Electrical Circuit Breakers)

# Under no circumstances is any candidate allowed to operate any equipment outside the simulator without the permission of the Evaluator and Shift Management.



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-ADM-12

 Revision: 00

 Page: 132 of 8

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_

 Date \_\_\_\_\_\_

 Initials \_\_\_\_\_

# **<u>ADMIN Task 12</u>**: Determine the plant EOOS Factor

Setting:	Classroom
Type:	SRO
<u>Task</u> :	SRO-ADMIN-015
<u>K&amp;A</u> :	Generic 2.1.19: 3.0
Safety Function:	N/A
Time Required:	10 minutes
Time Critical:	No
Faulted:	No
Performance:	Perform
Reference(s):	EDP-045 GGNS EOOS Risk Monitor User's Guide
Handout(s):	EDP-045 GGNS EOOS Risk Monitor User's Guide
<u># Manipulations</u> :	N/A
# Critical Steps:	4
<u>Group #</u> :	N/A

## **ADMINISTRATIVE JPM / SRO LEVEL**

Simulator Setup/Required Plant Conditions: None.

Safety Concerns: None.

Equipment Needed: Shift Manager's Computer in the simulator with the EOOS Program.



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-ADM-12

 Revision: 00

 Page: 133 of 8

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_\_

# **<u>ADMIN Task 12</u>**: Determine the plant EOOS Factor

### <u>Initial Condition(s)</u>:

• The Plant is 100% power.

#### <u>Initiating Cue(s)</u>:

- You are the Shift Supervisor.
- Service Transformer 21 is out of service.
- Diesel Driven Fire Pump B is out of service.
- Component Cooling Water Pump B is out of service.
- Determine the EOOS Risk Factor and Plant Safety Index.

Give the candidate a copy of EDP-045 GGNS EOOS Risk Monitor User's Guide

USE the Shift Manager's Computer in the Simulator for the Training Program.

DO NOT USE A COMPUTER CONNECTED TO THE PLANT.



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-ADM-12

 Revision: 00

 Page: 134 of 8

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_\_

# **<u>ADMIN Task 12</u>**: Determine the plant EOOS Factor

# <u>Notes</u>

1. This is an Administrative JPM.

**Task Overview:** This task is to use the EOOS Computer to assess the Plant Safety Index and Risk Factor for out of service equipment and plant work.

<u>**Task Justification:**</u> This task is performed any time equipment is removed from service. This is an Administrative JPM.

# Tasks: Critical tasks are underlined, italicized, and denoted by (\*).

Selection of components and calculation are NOT sequence Critical.

Log onto a computer with the EOOS Computer Program.
 <u>Standard:</u> Candidate logs onto a computer with the EOOS Computer Program.
 Cue: None
 Notes:

At the Shift Manager's Desk the LOGON ID is op and the PASSWORD is left blank.

Select Service Transformer (ST-21) as Out of Service.
 Standard: Candidate Select Service Transformer (ST-21) as Out of Service.
 Cue: None.
 Notes: This can be done by selecting ST-21 as Out of Service or the Take a Component Out/Return to Service button.



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-ADM-12

 Revision: 00

 Page: 135 of 8

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_\_

□\* Select Component Cooling Water Pump B (CCW B) as Out of Service.
 Standard: Candidate Select Component Cooling Water Pump B (CCW B) as Out of Service.
 Cue: None.
 Notes: This can be done by selecting CCW B as Out of Service or the Take a Component Out/Return to Service button.

Select Diesel Driven Fire Pump B (C3B) as Out of Service.
 Standard: Candidate Select Diesel Driven Fire Pump B (C3B) as Out of Service.
 Cue: None.
 Notes: This can be done by selecting Fire Pump C3 B as Out of Service or the Take a Component Out/Return to Service button.

Select Recalculate Plant Risk Measure button.
 Standard: Candidate selects Recalculate Plant Risk Measure button.
 Cue: None.
 Notes: The EOOS computer will perform the calculations and display the Plant Safety Index and risk color 9.0 YELLOW.

Task Standard(s):

Plant Safety Index is determined to be 9.0 YELLOW.

Name: \_\_\_\_\_

Time Start: \_\_\_\_\_

Time Stop: \_\_\_\_\_



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-ADM-12

 Revision: 00

 Page: 136 of 8

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_\_

# <u>ADMIN Task 4</u>: Determine the plant EOOS Factor

Follow-Up Questions & Answers:

Comments:



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-ADM-13

 Revision: 00

 Page: 137 of 8

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_\_

# **Determine the plant EOOS Factor**

# Give this page to the student

Initial Condition(s):

• The Plant is 100% power.

### Initiating Cue(s):

- You are the Shift Supervisor.
- Service Transformer 21 is out of service.
- Diesel Driven Fire Pump B is out of service.
- Component Cooling Water Pump B is out of service.
- Determine the EOOS Risk Factor and Plant Safety Index.

Give the candidate a copy of EDP-045 GGNS EOOS Risk Monitor User's Guide

USE the Shift Manager's Computer in the Simulator for the Training Program.

DO NOT USE A COMPUTER CONNECTED TO THE PLANT.



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-ADM-13

 Revision: 00

 Page: 138 of 8

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

**TRAINING PROGRAM:** 

# OPERATIONS TRAINING

#### \*LESSON PLAN TITLE:

# PERFORM OPERATIONS SUPERVISOR REVIEW OF TAGOUT

#### APPROXIMATE TIME REQUIRED: 10 Minutes

#### PREREQUISITES: NONE

#### SUPPORTING LESSONS: NONE

🛛 New Material

Minor Revision

Major Revision

#### **REASON FOR REVISION:**

New JPM; Modified from GJPM-SRO-ADM3

#### REVIEW / APPROVAL (Print Name): Electronic Approval (TEAR #\_\_\_\_\_

Prepared By:		
. , _	Preparer	Date
Reviewed By:		
	Technical Reviewer (e.g., SME, line management)	Date
Instructional		
Adequacy Determined		
By:		
-	ITPL (Rev 0); Qualified Instructor (All other revisions)	Date
Approved By:		
	**Discipline Training Supervisor	Date
Effective Date:		
	*Doto	

Indicates that the LP has been reviewed by the Training Supervisor for inclusion of Management Expectations and items referenced on the Training Development Review Worksheet

#### FLEET/REGIONAL PROGRAM CONCURRENCE:

∐ Fleet	L ENS	L ENN	🛛 Not Applic	able	
ANO				PNPS	
CNPS				RBS	
ECH				VY	
GGNS				WF3	
IPEC				WPO	
JAF					

\* Indexing Information



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-ADM-13

 Revision: 00

 Page: 139 of 8

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_\_

# **Generic Instructions**

- 1. Standard cues for valve operation:
  - a. MOVs:
    - 1) "Full open" = "red light on, green light off"
    - 2) "Full closed" = "red light off, green light on"
  - b. Manual valves
    - 1) "Full open" = "you feel resistance in the counter-clockwise direction"
    - 2) "Full closed" = "you feel resistance in the clockwise direction"

2. The Evaluator should indicate simulated analog gauge readings by pointing a pen or equivalent to the intended place on the gauge.

3. Other methods of simulating control, operation and data collection is at the discretion of the Evaluator.

4. Obtain Shift Management's permission before opening any control panel door or instrument cover.

5 It is expected that the candidate shall locate controlled copies of any required procedures and describe how copies of these procedures would be prepared for use in the field. Only at this time should the evaluator give the candidate previously prepared copies of the procedure(s). This entire procedure need only be performed or simulated once during the entire exam. <u>These activities are not required for JPMs</u> conducted in the Simulator.

6. Consideration of electrical safety must be made during the performance of certain tasks involving electrical circuits and circuit breakers. The performer should be aware that working on or near energized equipment requires, at a minimum, wearing 100% cotton clothing and low voltage (Class 0) gloves while removing or securing shock hazards such as chains, jewelry, watches and metal-framed eyeglasses. Operating or racking circuit breakers may require additional PPE. Details can be found in Att. 2 of the Electrical Safety Rulebook and General Operating procedure 04-S-04-2 (Operation of Electrical Circuit Breakers)

# Under no circumstances is any candidate allowed to operate any equipment outside the simulator without the permission of the Evaluator and Shift Management.



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-ADM-13

 Revision: 00

 Page: 140 of 8

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_\_

# ADMIN Task 13: Perform Operations Supervisor Review of Tagout

Setting:	Classroom
<u>Type</u> :	SRO
<u>Task</u> :	SRO-ADMIN-048
<u>K&amp;A</u> :	Generic 2.2.13: 3.8; 2.2.17: 3.5
Safety Function:	N/A
Time Required:	15 minutes
Time Critical:	No
Faulted:	No
Performance:	Perform
Reference(s):	NMM EN-OP-102 Protective and Caution Tagging
Handout(s):	NMM EN-OP-102 Protective and Caution Tagging
	Candidate copy of Manual Tagout
	SOI 04-1-01-P11-1 Condensater Storage and Transfer System
	E-1221
	M-1065
<u># Manipulations:</u>	N/A
# Critical Steps:	1
<u>Group #</u> :	N/A

### **ADMINISTRATIVE JPM / SRO LEVEL**

Simulator Setup/Required Plant Conditions: None.

Safety Concerns: None.

Equipment Needed: None



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-ADM-13

 Revision: 00

 Page: 141 of 8

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_\_

# ADMIN Task 13: Perform Operations Supervisor Review of Tagout

### <u>Initial Condition(s)</u>:

- The Plant is 100% power.
- Condensate Transfer Pump A (P11-C001A) motor has burned up.
- Condensate Transfer Pump B is in service.

#### <u>Initiating Cue(s)</u>:

- You are the Shift Supervisor.
- A Work Order has been issued to replace the Pump Motor for P11-C001A.
- There will be NO breach of the fluid system portion of the pump.
- The eSOMS Clearance System computer is out of service and the pump must repaired and returned to service ASAP.
- Review the attached Protective clearance as Operations Supervisor for adequacy to hang.



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-ADM-13

 Revision: 00

 Page: 142 of 8

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_\_

# <u>ADMIN Task 13</u>: Perform Operations Supervisor Review of Tagout

# <u>Notes</u>

1. This is an Administrative JPM.

<u>**Task Overview:**</u> This task is to perform the Operations Supervisor review of a tagout for protective tagging.

<u>**Task Justification:**</u> This task is performed any time equipment is removed from service. Operations SROs are responsible for releasing ALL plant equipment for maintenance and protective tagging. This is an Administrative JPM.

Tasks: Critical tasks are underlined, italicized, and denoted by (\*).

Selection of components and calculation are NOT sequence Critical.

*Identifies the tagout is missing the P11-C001A Space Heater Breaker 52-1P42214 from the tagout.* <u>Standard:</u> Reviews the tagout and determines the P11-C001A Space Heater Breaker 52-1P42214 is not on the tagout and should be to allow motor work.
 Cue: None Notes:



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-ADM-13

 Revision: 00

 Page: 143 of 8

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_\_

□ The following components are present on the tagout as required for P11-C001A Motor Replacement:

P11-H	IS-M604A Handsv	witch for CNDS	XFER PMP A	A P11-C001A	H13-P870-5C
ST	ΌΡ				
P11-F	024A CNDS XFE	R PMP A DISC	H valve (Opti	onal) CLOSE	ED

- P11-F026A CNDS XFER PMP A SUCT valve (Optional) CLOSED
- 52-142223 CNDS XFER PMP A circuit breaker OPEN

\_\_\_\_\_ P11-F050A CNDS XFER PMP A CSG VENT valve OPEN

P11-F139A CNDS XFER PMP A CSG DR valve OPEN

**Standard:** The above components are on the tagout and are acceptable. The Suction and Discharge Valves are there only to keep the pump shaft from potentially turning. The vent and drain valve are to prevent water inside the pump from expanding causing damage to the pump. **Cue:** None.

Notes:



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-ADM-13

 Revision: 00

 Page: 144 of 8

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_

 Date \_\_\_\_\_\_

 Initials \_\_\_\_\_

Task Standard(s):

Taggout is determined to be inadequate for the work to be done due to P11-C001A Condensate Transfer Pump A Space heater circuit breaker not being opened and tagged.

\_\_\_\_\_

Time Start: \_\_\_\_\_

Time Stop: \_\_\_\_\_


JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-ADM-13

 Revision: 00

 Page: 145 of 8

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_\_

# ADMIN Task 13: Perform Operations Supervisor Review of Tagout

Follow-Up Questions & Answers:

Comments:



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-ADM-14

 Revision: 00

 Page: 146 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_\_

# Perform Operations Supervisor Review of Tagout

# Give this page to the student

<u>Initial Condition(s)</u>:

- The Plant is 100% power.
- Condensate Transfer Pump A (P11-C001A) motor has burned up.
- Condensate Transfer Pump B is in service.

### Initiating Cue(s):

- You are the Shift Supervisor.
- A Work Order has been issued to replace the Pump Motor for P11-C001A.
- There will be NO breach of the fluid system portion of the pump.
- The eSOMS Clearance System computer is out of service and the pump must repaired and returned to service ASAP.
- Review the attached Protective clearance as Operations Supervisor for adequacy to hang.



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-ADM-14

 Revision: 00

 Page: 147 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

**TRAINING PROGRAM:** 

# **OPERATIONS TRAINING**

\*LESSON PLAN TITLE:

	•		
Revie	w Radioactive	Waste Dischar	ge Permit
APPROXIMATE TIME	REQUIRED: 10 Minutes	3	
PREREQUISITES: NON	NE		
SUPPORTING LESSO	NS: NONE		
	New Material	Minor Revision	Major Revision
REASON FOR REVISION New JPM; Modified from	<b>DN:</b> m GG-1-JPM-SRO-AD	M37	
<b>REVIEW / APPROVAL</b>	(Print Name): 🗌 Electi	ronic Approval (TEAR # _	)
Prepared By:			
	Pr	eparer	Date
Reviewed By:			
Instructional Adequacy Determined Bv:	Technical Reviewer (e.	g., SME, line management)	Date
_,	ITPL (Rev 0); Qualified In	nstructor (All other revisions)	Date
Approved Bv:			
	**Discipline Tr	aining Supervisor	Date
Effective Date:			_
	*	Date	

Indicates that the LP has been reviewed by the Training Supervisor for inclusion of Management Expectations and items referenced on the Training Development Review Worksheet

# 

ANO	PNPS	
CNPS	RBS	
ECH	VY	
GGNS	WF3	
IPEC	WPO	
JAF		

\* Indexing Information



JOB PERFORMANCE MEASURE Number: GJPM-SRO-ADM-14 Revision: 00 Page: 148 of 272 Rtype: \_\_\_\_\_ QA Record Number of pages \_\_\_\_\_ Date Initials

# **Generic Instructions**

- 1. Standard cues for valve operation:
  - a. MOVs:
    - 1) "Full open" = "red light on, green light off"
    - 2) "Full closed" = "red light off, green light on"
  - b. Manual valves
    - 1) "Full open" = "you feel resistance in the counter-clockwise direction"
    - 2) "Full closed" = "you feel resistance in the clockwise direction"

2. The Evaluator should indicate simulated analog gauge readings by pointing a pen or equivalent to the intended place on the gauge.

3. Other methods of simulating control, operation and data collection is at the discretion of the Evaluator.

4. Obtain Shift Management's permission before opening any control panel door or instrument cover.

5 It is expected that the candidate shall locate controlled copies of any required procedures and describe how copies of these procedures would be prepared for use in the field. Only at this time should the evaluator give the candidate previously prepared copies of the procedure(s). This entire procedure need only be performed or simulated once during the entire exam. <u>These activities are not required for JPMs</u> <u>conducted in the Simulator</u>.

6. Consideration of electrical safety must be made during the performance of certain tasks involving electrical circuits and circuit breakers. The performer should be aware that working on or near energized equipment requires, at a minimum, wearing 100% cotton clothing and low voltage (Class 0) gloves while removing or securing shock hazards such as chains, jewelry, watches and metal-framed eyeglasses. Operating or racking circuit breakers may require additional PPE. Details can be found in Att. 2 of the Electrical Safety Rulebook and General Operating procedure 04-S-04-2 (Operation of Electrical Circuit Breakers)

## Under no circumstances is any candidate allowed to operate any equipment outside the simulator without the permission of the Evaluator and Shift Management.



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-ADM-14

 Revision: 00

 Page: 149 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages

 Date \_\_\_\_\_\_

 Initials \_\_\_\_\_\_

# **ADMIN Task 14:** Review Radioactive Waste Discharge Permit

Setting:	Classroom
Type:	SRO
<u>Task</u> :	SRO-NO-010
<u>K&amp;A</u> :	Generic 2.3.11: 3.2
Safety Function:	N/A
Time Required:	10 minutes
Time Critical:	No
Faulted:	No
Performance:	Perform
Reference(s):	Administrative Procedure 01-S-08-11 Radioactive Discharge Controls
Handout(s):	Administrative Procedure 01-S-08-11 Radioactive Discharge Controls
	Candidate Copy of Attachment I Batch Liquid Radwaste Discharge Permit
<u># Manipulations</u> :	N/A
# Critical Steps:	4
<u>Group #</u> :	N/A

### **ADMINISTRATIVE JPM / SRO LEVEL**

#### Simulator Setup/Required Plant Conditions: None.

Safety Concerns: None.

Equipment Needed: None.

#### Initial Condition(s):

• The Radwaste Specialist / Operator has brought a Batch Liquid Radwaste Discharge Permit to the Control Room for approval.

#### Initiating Cue(s):

- You are the Shift Manager.
- Review the Batch Liquid Radwaste Discharge Permit..

There are 5 critical deficiencies on the Discharge Permit. Typos and spelling errors do NOT count.



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-ADM-14

 Revision: 00

 Page: 150 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages

 Date \_\_\_\_\_\_

 Initials \_\_\_\_\_\_

# **<u>ADMIN Task 14</u>**: Review Radioactive Waste Discharge Permit

## <u>Notes</u>

1. This is an Administrative JPM.

**Task Overview:** This task is to review a Radioactive Waster Discharge permit per Administrative Procedure 01-S-08-11. This is the responsibility of the Shift Manager to review and approve all radioactive discharges from GGNS.

**Task Justification:** This task is performed any time Radwaster discharges a tank of liquid to the environment. This is an Administrative JPM.

# Tasks: Critical tasks are underlined, italicized, and denoted by (\*).

□\* <u>Review the Batch Liquid Radwaste Discharge Permit for readiness for use.</u>
 <u>Standard:</u> SEE Attached Evaluator Copy of permit for marked critical errors on the permit.

Errors are circled and marked with \*.

The candidate must find 4 or 5 errors for satisfactory completion of JPM. Cue: None. Notes:

Task Standard(s):

Four of five Errors are noted from Batch Liquid Radwaste Discharge Permit.

Name:	Time Start:	Time Stop:
-------	-------------	------------



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-ADM-14

 Revision: 00

 Page: 151 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_\_

# **<u>ADMIN Task 14</u>:** Review Radioactive Waste Discharge Permit

Follow-Up Questions & Answers:

Comments:



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 152 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

# **Review Radioactive Waste Discharge Permit**

## Give this page to the student

<u>Initial Condition(s)</u>:

• The Radwaste Specialist / Operator has brought a Batch Liquid Radwaste Discharge Permit to the Control Room for approval.

### <u>Initiating Cue(s)</u>:

- You are the Shift Manager.
- Review the Batch Liquid Radwaste Discharge Permit..

There are 5 critical deficiencies on the Discharge Permit. Typos and spelling errors do NOT count.



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 153 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

**TRAINING PROGRAM:** 

## OPERATIONS TRAINING

#### \*LESSON PLAN TITLE:

# DETERMINE ENTRY INTO SITE EMERGENCY PLAN AND COMPLETE INITIAL NOTIFICATION FORMS

#### APPROXIMATE TIME REQUIRED: 15 Minutes

#### PREREQUISITES: NONE

#### SUPPORTING LESSONS: NONE

🛛 New Material

Minor Revision

Major Revision

#### **REASON FOR REVISION:**

New JPM; Modified JPM

<b>REVIEW / APPROVAL (F</b>	Print Name):   Electronic Approval (TEAR #	)
Prepared By:		
	Preparer	Date
Reviewed By:		
	Technical Reviewer (e.g., SME, line management)	Date
Instructional Adequacy Determined		
Ву:	ITDL (Dov 0), Qualified Instructor (All other revisions)	Data
	TTPL (Rev 0), Qualified instructor (All other revisions)	Dale
Approved By:		
	**Discipline Training Supervisor	Date
Effective Date:		
	*Date	

Indicates that the LP has been reviewed by the Training Supervisor for inclusion of Management Expectations and items referenced on the Training Development Review Worksheet

# FLEET/REGIONAL PROGRAM CONCURRENCE:

∐ Fleet	L ENS	Not Applic	able	
ANO			PNPS	
CNPS			RBS	
ECH			VY	
GGNS			WF3	
IPEC			WPO	
JAF				

\* Indexing Information



JOB PERFORMANCE MEASURE Number: GJPM-SRO-A&E-43 Revision: 00 Page: 154 of 272 Rtype: \_\_\_\_\_\_ QA Record Number of pages \_\_\_\_\_\_ Date Initials

# **Generic Instructions**

- 1. Standard cues for valve operation:
  - a. MOVs:
    - 1) "Full open" = "red light on, green light off"
    - 2) "Full closed" = "red light off, green light on"
  - b. Manual valves
    - 1) "Full open" = "you feel resistance in the counter-clockwise direction"
    - 2) "Full closed" = "you feel resistance in the clockwise direction"

2. The Evaluator should indicate simulated analog gauge readings by pointing a pen or equivalent to the intended place on the gauge.

3. Other methods of simulating control, operation and data collection is at the discretion of the Evaluator.

4. Obtain Shift Management's permission before opening any control panel door or instrument cover.

5 It is expected that the candidate shall locate controlled copies of any required procedures and describe how copies of these procedures would be prepared for use in the field. Only at this time should the evaluator give the candidate previously prepared copies of the procedure(s). This entire procedure need only be performed or simulated once during the entire exam. <u>These activities are not required for JPMs</u> <u>conducted in the Simulator</u>.

6. Consideration of electrical safety must be made during the performance of certain tasks involving electrical circuits and circuit breakers. The performer should be aware that working on or near energized equipment requires, at a minimum, wearing 100% cotton clothing and low voltage (Class 0) gloves while removing or securing shock hazards such as chains, jewelry, watches and metal-framed eyeglasses. Operating or racking circuit breakers may require additional PPE. Details can be found in Att. 2 of the Electrical Safety Rulebook and General Operating procedure 04-S-04-2 (Operation of Electrical Circuit Breakers)

## Under no circumstances is any candidate allowed to operate any equipment outside the simulator without the permission of the Evaluator and Shift Management.



**JOB PERFORMANCE** 

MEASURE

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 155 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

# <u>A&E Task 43</u> Determine Entry into Site Emergency Plan and Complete Initial Notification Forms as applicable

Classroom
SRO
SRO-A&E-015 SRO-A&E-003
Generic 2.4.41: 4.1; 2.4.38: 4.0; 2.4.40: 4.0
N/A
15 minutes
YES
No
Perform
10-S-01-1
10-S-01-1; EAL Flow Chart
N/A
3
N/A

### ADMINISTRATIVE JPM

#### Simulator Setup/Required Plant Conditions: None.

Safety Concerns: None.

Equipment Needed: None.



Revision: 00 Page: 156 of 272 Rtype: \_ **JOB PERFORMANCE QA Record** MEASURE Number of pages Date \_\_\_\_\_ Initials \_\_\_\_

Number: GJPM-SRO-A&E-43

#### **Determine Entry into Site Emergency Plan and** A&E Task 43 **Complete Initial Notification Forms as applicable**

<u>Initial Condition(s)</u>:

The Plant is 100% power. •

### Initiating Cue(s):

- You are the Shift Manager.
- A Dry Fuel Storage Cask is being moved from Unit I to the ISFSI Storage Facility.
- The ISFSI Crawler (Transporter) engine caught on fire at 1010 just as the crawler was going around the Combination Shop on the south side of the building.
- The Site Fire Brigade has responded with the Site Fire Truck and has reported the fire is extinguished at 1035 and a reflash watch has been established.
- There is visible damage to the outside of the Dry Fuel Storage Cask.
- The Radiation Protection Technician monitoring the Fire Brigade and Dry Fuel Storage Cask has stated the Radiation Levels adjacent to the cask are two times pre-fire levels.
- Classify this event and complete any initial notification forms that are required. ٠



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 157 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

# <u>A&E Task 43</u> Determine Entry into Site Emergency Plan and Complete Initial Notification Forms as applicable

## <u>Notes</u>

1. This is an Administrative JPM.

2. This is an activity performed by an SRO as Emergency Director per the GGNS Emergency Plan Procedures.

**Task Overview:** This task is to use the Emergency Plan Procedure and Off Normal Event Procedures for classification of plant conditions per the Emergency Action Levels and complete the Initial Notification forms for contact of State and Local Agencies. This is a <u>TIME CRITICAL</u> JPM based on the requirements of 10 CFR50 Appendix E IV.D.3.

# Tasks: Critical tasks are underlined, italicized, and denoted by (\*).

This is a <u>TIME CRITICAL</u> JPM.

Identify the CONFINEMENT BOUNDARY of a loaded cask has been damaged.
 Standard: Candidate uses 10-S-01-1 Section 5.7 to identify the Confinement Boundary has been damaged due to radiation levels being TWO times the pre-event levels in the area of the cask.
 Cue: None
 Notes: This E-HU1 Unusual Event.

Identify the fire location was within the boundaries of the PROTECTED AREA and lasted for greater than 15 minutes (25 minutes), however, the fire was NOT contiguous to any VITAL AREAS as identified in Table H3
 Standard: Candidate uses 10-S-01-1 section 5.42 to identify the Protected Area and determine the fire lasted greater than 15 minutes (25 minutes) but was not contiguous to VITAL AREAS as defined in Table H3, also the fire did not affect structures containing functions or systems required for Safe Shutdown.
 Cue: None Notes:



 NOCLEAR STATION
 Page: 158 of

 Rtype:
 \_\_\_\_\_\_

 JOB PERFORMANCE
 QA Record

 MEASURE
 Number of page

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 158 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

Classify the event as an UNUSUAL EVENT.
 Standard: Candidate uses 10-S-01-1 Attachments I and II Initiating Conditions E-HU1 to classify the event as an UNUSUAL EVENT.
 Cue: None
 Notes:

□\* <u>Complete the Initial Notification form for contact of State and Local Agencies. (SEE Attached form for critical information.)</u>
 Standard: Candidate completes Initial Notification form.
 Cue: None
 Notes:

Task Standard(s):

UNUSUAL EVENT is declared per EAL E-HU1 and Initial Notification Form is completed.

Name:	Time Start:	Time Stop:
		1 mic 5top.



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 159 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

# <u>A&E Task 43</u> Determine Entry into Site Emergency Plan and Complete Initial Notification Forms as applicable

Follow-Up Questions & Answers:

Comments:



JOB PERFORMANCE MEASURE

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 160 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

# Determine Entry into Site Emergency Plan and Complete Initial Notification Forms as applicable

# Give this page to the student

## Initial Condition(s):

• The Plant is 100% power.

## Initiating Cue(s):

- You are the Shift Manager.
- A Dry Fuel Storage Cask is being moved from Unit I to the ISFSI Storage Facility.
- The ISFSI Crawler (Transporter) engine caught on fire at 1010 just as the crawler was going around the Combination Shop on the south side of the building.
- The Site Fire Brigade has responded with the Site Fire Truck and has reported the fire is extinguished at 1035 and a reflash watch has been established.
- There is visible damage to the outside of the Dry Fuel Storage Cask.
- The Radiation Protection Technician monitoring the Fire Brigade and Dry Fuel Storage Cask has stated the Radiation Levels adjacent to the cask are two times pre-fire levels.
- Classify this event and complete any initial notification forms that are required.

**REVISION 0 1/11/2007** 

SCENARIO 1 PAGE 160 of 272



**JOB PERFORMANCE** 

MEASURE

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 161 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

Appendi	хD		Scenario Outline	Form ES-D-1
Facility: Examine	GRAND GUL ers:	F NUCLEA	AR STATION Scenario No.: 1 Op-Test No.: Day 1Operators:	-
Objectiv evolu 1. Ir 2. F 3. R 4. D 5. T ( 6. R 7. R	ves: To evaluations: asert control ro Respond to a f espond to trip ownshift Rea ake actions to LOCA is NOT espond to mu	ate the car ods to lowe failure of R o of SBGT ctor Recirc mitigate a severe en iltiple contr steam leak	didates' ability to operate the facility in response to the er reactor power per control rod movement plan. PS MG 'B' per Loss of One or Both RPS Busses ONEF 'A'. Pumps to Slow Speed. I large break failure of Feedwater piping in the Drywell ough to result in depressurization of RPV.) ol rods stuck withdrawn. on RCIC when initiated.	following P. per EOPs.
<u>Initial C</u> outage. Master L	onditions: Ro Reactor Recin .evel Control;	eactor Pow culation pu one Heate	ver is at 53 %. Plant shutdown is in progress in prepara umps in Fast Speed; a single Reactor Feed Pump in Th r Drain Pump is pumping forward.	ation for an aree element
INOP SR IRM AP HF ES RF SB Appropr	<b>ERABLE</b> M 'F' are INO As 'A' & 'H' ar RM 'H' is INC CS Pump is t F 12 Transfor S 'A' is on Alt GT 'A' is operate clearance	Equipm P and bypa e INOP an P due to a agged out rmer is tag ternate Pow rating for s es and LCC	nent assed. d bypassed. failed FCTR card. of service for failure of the Jockey Pump. ged out of service for maintenance. wer due to EPA circuit breaker failure. urveillance. Os are written.	
<u>Turnove</u> Tensas	e <u>r:</u> Continue Parish area.	plant shutd	own per IOI-2. There are scattered thunder showers re	eported in the
Event No.	Malf. No.	Event Type*	Event Description	

REVISION 0 1/11/2007

SCENARIO 1 PAGE 161 of 272



**JOB PERFORMANCE** 

MEASURE

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 162 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

1		R (RO)	Lower Reactor power using control rods to 60 – 75% rod line. (Control Rod Movement Sequence)
2	1	C (RO) TS (SS)	Respond to RPS Motor Generator 'B' trip. (ONEP 05-1-02-III-2). Complete <b>Technical Specification/FSAR</b> determination.
3	2	C (BOP) TS (SS)	Respond to trip of SBGT 'A' trip. (ARI 04-1-02-1H13-P870 2A-A2) Complete <b>Technical Specification</b> determination.

REVISION 0 1/11/2007

SCENARIO 1 PAGE 162 of 272



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 163 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

Appendix D Scenario Outline Form ES-D-1

Scenario **1** Day **1** (Continued)

Event No.	Malf. No.	Event Type*	Event Description
4	2	N (RO)	Transfer Reactor Recirc Pumps to Slow Speed (SOI 04-1-01-B33-1)
5	3	M (ALL)	Respond to indications of large break LOCA on Feedwater Line 'A' per EOPs. (B21-F065A will close if attempted.)
	4	C (RO)	Respond to a failure of 3 control rods to fully insert on Reactor Scram signal.
	5	C (BOP)	RCIC steam leak will isolate by manual means.

(N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor

# Critical Tasks

- When allowed by Level/Power Control leg of EP-2A, restores injection from Condensate/Feedwater.
- Inserts rods by manual scrams and normal rod insertion using Attachments 18, 19, and 20.



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 164 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

Scenario 1 Day 1 (Continued)

### Crew Turnover:

Rx power is at 53% CTP.

The plant is lowering power in preparation for an outage.

Reactor Recirculation Pumps are operating in Fast Speed.

The 'A' Reactor Feed Pump is operating in Three Element Master Level Control.

One Heater Drain Pump is pumping forward.

Circ Water is in Single Pump Dual Train 'A' Pump in service.

SRMs 'F' is INOP and bypassed.

IRMs 'A' & 'H' are INOP and bypassed.

APRM 'H' is failed due to a failed FCTR card and bypassed.

ESF 12 Transformer is tagged out of service for maintenance.

RPS 'A' is on Alternate Power due to an EPA circuit breaker failure.

SBGT 'A' is operating for surveillance 06-OP-1T48-M-0001 holding at step 5.2.11 allowing the System Engineer to obtain data.

Hpcs Pump and Jockey Pump are out of service due to the Jockey Pump motor burned up.

Appropriate clearances and LCOs are written.

Continue plant shutdown to less than 75% Rod Line to Downshift Reactor Recirc Pumps.

At step 8.3/8.4 of IOI-2 Attachment IV.

REVISION 0 1/11/2007

SCENARIO 1 PAGE 164 of 272



JOB PERFORMANCE MEASURE

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 165 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

BOC Shutdown Sequence Sheet Step 5.

Plant EOOS is 7.3 YELLOW.

Hydrogen Water Chemistry and Alternate Cooling Tower are secured.

There are scattered thunderstorms reported in the Tensas Parish area.

REVISION 0 1/11/2007

SCENARIO 1 PAGE 165 of 272



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 166 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_

 Date \_\_\_\_\_ Initials \_\_\_\_\_

Simulator Setup: (Scenarios may be setup and shot into encrypted ICs and Password protected.)

Start the process from a new simulator load. Reset to IC-13. Verify or perform the following: IC: 13 OOS: APRM H (Place in Bypass w/ Caution tag) IRMs A & H (Place in Bypass w/ Caution tag) SRMs F (Place in Bypass w/ Caution tag) RPS A (Transfer to Alternate Power and reset RPS A w/ Caution tag) Manually Initiate SBGT A HPCS and HPCS Jockey Pump OOS (Place HPCS OOSVC to OOSVC and place tags on HPCS Pump and Jockey Pump HS) ESF XFMER 12 (Place tag on J3885, 152-1903, 152-1904, 152-1905, 152-1511, 152-1611, 152-1704 HS) Active malfunctions: c51002f SRM F incorporated into present simulator load c51005a IRM A incorporated into present simulator load c51005h IRM H incorporated into present simulator load c71077a RPS A MG failure (Normal EPA OOS) z022022 60 21 Control rod 60-21 stuck out z022022 60 25 Control rod 60-25 stuck out **z022022** 60-29 Control rod 60-29 stuck out Active Remote Functions: c51262 APRM H Function Switch to STDBY p81218 J3885 115KV Disconnect OPEN e22644 HPCS Pump BKR OUT e22646 HPCS JKY pump breaker OPEN 152-1511 lo\_1r21m601a\_g Bus 15AA FDR FM ESF XFMR 12 OFF di 1r21m601ap864/01c Bus 15AA FDR FM ESF XFMR 12 TRIP 152-1611 lo\_1r21m601b\_g Bus 16AB FDR FM ESF XFMR 12 OFF di 1r21m601bp864/02c Bus 16AB FDR FM ESF XFMR 12 TRIP 152-1704 lo 1e22m709 g 17AC FDR FM ESF 12 OFF di\_1e22m709p601/16c 17AC FDR FM ESF 12 OFF 152-1903 lo\_1r21m623\_g Bus 15AA/16AB/27AC FDR FM ESF XFMR 12 OFF di\_1r21m623p807/01c Bus 15AA/16AB/27AC FDR FM ESF XFMR 12 **REVISION 0 1/11/2007 SCENARIO** 1 NUREG 1021 REVISION 9 PAGE 166 of 272



**JOB PERFORMANCE** 

**MEASURE** 

Number: GJPM-SRO-A&E-43 **Revision: 00** Page: 167 of 272 Rtype: \_ QA Record Number of pages \_\_\_\_\_ Date \_\_\_\_\_ Initials \_\_\_\_\_

## TRIP 152-1904 lo\_1r21m624\_g Bus 17AC/25AA/26AB FDR FM ESF XFMR 12 OFF di\_1r21m624p807/01c Bus 17AC/25AA/26AB FDR FM ESF XFMR 12 TRIP 152-1905 lo\_1r21m637\_g SWYD XFMR T3 FDR FM ESF XFMR 12 OFF di\_1r21m637p807/01c SWYD XFMR T3 FDR FM ESF XFMR 12 TRIP

Active Case File:	cae sg	tsai.cae SBGT A operating for surveillance
Active overrides:	None	
Pending overrides:		remote function <b>e51319</b> Failure to isolate RCIC remote function <b>e51320</b> Failure to isolate RCIC
Pending malfunctions	:	c71077b RPS MG failure (TRG 2) t48d001a_a SBGT A Filter Train Fan trip (TRG 3) fw171a@100% Feedwater Line 'A' break in Drywell (TRG 5) rr063a@4.6% Recirc line 'A' leakage to simulate Feedwater Check Valve leakage ramp 1% to 4.6% over 2 minutes (TRG 5) e51050@50% RCIC Steam line rupture five minutes after Feedwater failure (TRG 5) RCIC will fail to automatically isolate.

Pending component malfunctions: None

Trigger files: Trigger 2 RPS B MG Failure

Trigger 3 SBGT A Trip Trigger 5

Feedwater Line 'A' rupture in Drywell w/ RCIC Steam leak

COMPONENT	PANEL	INDICATION or	SIMULATOR	STATUS	DONE
		CONTROL	CODE	511105	DONE
APRM H			c51262	STDBY	
HPCS PUMP	P601-16C		e22644_OUT	OUT	
HPCS Jockey Pump	P601-16C		e22646_OPEN	OPEN	
RPS A on Alternate	P610	Handswitch	c71077a	ALT	
152-1511	P864-1C	Green light	lo_1r21m601a_g	OFF	
	P864-1C	Handswitch	di_1r21m601a	STOP	
152-1611	P864-2C	Green light	lo_1r21m601b_g	OFF	
	P864-2C	Handswitch	di_1r21m601b	STOP	
DEVISION 0 1/11/2007	S	CENADIO 1	NUPEC	1021 DEVIS	ION 0

**REVISION 0 1/11/2007** 



## JOB PERFORMANCE MEASURE

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 168 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

152-1704	P601-16C	Green light	lo_1e22m709_g	OFF
	P601-16C	Handswitch	di_1e22m709	STOP
152-1903	P807-1C	Green light	lo_1r21m623_g	OFF
	P807-1C	Handswitch	di_1r21m623	STOP
152-1904	P807-1C	Green light	lo_1r21m624_g	OFF
	P807-1C	Handswitch	di_1r21m624	STOP
152-1905	P807-1C	Green light	lo_1r21m637_g	OFF
	P807-1C	Handswitch	di_1r21m637	STOP
J3885 115 KV Disconnect	P807-1C	Green Light	p81218	OPEN

Bypass Division 2 APRM Bypass Joystick to APRM H position.

IRMs A and H, SRMs F are bypassed in the IC setup for Cycle 15.

Verify or perform the following:

Verify Reactor Power is above the 75% rod line.

Open Circuit Breakers 152-1903, 1904, 1905, 1511, 1611, and 1704

Place HPCS OOSVC handswitch to OOSVC.

Place RPS A on Alternate Power and RESET RPS A logic on P680.

Verify SBGT A is operating.

Startup all PDS / SPDS screens. Clear any graphs and trends off of SPDS.

Setup the presently used cyclops display and verify it is functional.

Ensure the correct startup sequence is available at the P680 for the present IC.

Install turnover guide, red tag, and LCO paperwork as applicable.

Advance all chart recorders and ensure all pens are inking properly. (APRM chart recorders must be turned on and settings for scales on pens 0 - 125 scale)

Place tags on ALL circuit breakers associated with the ESF 12 Transformer outage.

Place tags on APRM H, IRM A & H and SRMS F Joysticks.

REVISION 0 1/11/2007

SCENARIO 1 PAGE 168 of 272



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 169 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

Place tags on HPCS Pump and Jockey Pump handswitches.

Place a Caution tag on RPS B Power Handswitch on P610.

REVISION 0 1/11/2007

SCENARIO 1 PAGE 169 of 272



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 170 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

## SIMULATOR OPERATION SCENARIO 1

Once simulator is reinitialized and setup complete take the simulator out of Freeze.

Once the Crew has taken control note the simulator time.

#### Lower Reactor Power using Control Rods

This step will lower Reactor Power to below the 75% Rod Line per IOI-2 Step 8.4.

Set FCBB less than 1.0 using Remote Function cy\_fcbb after crew inserts the first gang of control rods.

Crew will review procedures for lowering power using control rods.

Cues:

If asked, report as Reactor Engineer – follow the instructions in the front of the Control Rod Movement Sequence.

Adjust APRM gains using remote function c51299 as requested.

### Place FCTR cards in SETUP using remote function c51310 as requested.

### **RPS Motor Generator B trip**

Once power is below the 75% rod line and the Lead Examiner concurs, activate TRIGGER 2.

Respond to RPS B Motor Generator trip per ONEP 05-1-02-III-2, Loss of One or Both RPS Buses.

Cue:

When asked, report as Control Building Operator RPS MG B tripped and is extremely hot to the touch.

**RPS B CANNOT** be transferred to the Alternate Power Source per the SOI Precautions and Limitations (04-1-01-C71-1 section 3.5) due to FSAR 8.3.1.1.5.4 commitment. The FSAR is an appendix of the GGNS Operating License. Tech spec 3.3.8.2 is not applicable.

REVISION 0 1/11/2007

SCENARIO 1 PAGE 170 of 272



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 171 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_

 Date \_\_\_\_\_ Initials \_\_\_\_\_

Cue:

When asked, as Duty Manager continue plant shutdown with the half scram signal, I'll discuss with Plant Licensing the options concerning RPS.

Crew will have to live with a half scram signal the SS should brief the crew accordingly on contingencies.

REVISION 0 1/11/2007

SCENARIO 1 PAGE 171 of 272



JOB PERFORMANCE MEASURE

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 172 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

## <u>SBGT A Fan trip</u>

Two minutes after the Tech Specs/FSAR briefing have been identified, activate TRIGGER 3.

Standby Gas Treatment Exhaust Fan A will trip.

The BOP operator will have to realign Auxiliary Building Ventilation.

Cues:

If asked, respond as the Auxiliary Building Operator to investigate the SBGT A Exhaust Fan Trip.

Report as the Auxiliary Building Operator that the fan motor is hot to the touch and breaker 52-151117 for T48-D001A SBGT A Exhaust Fan is in the Trip Free condition on bus MCC 15B11.

The SS should direct restoration of Auxiliary Building Ventilation per the SOI 04-1-01-T48-1 section 5.3.

The SS should review Tech Spec 3.6.4.3.

Cues:

As asked, assist in the restoration of systems.

Cue: If contacted, as Assistant Operations Manager –Shift or Duty Manager instruct the shift to continue plant shutdown.

### **Recirc Pump Downshift to Slow Speed**

Once power is below the 75% rod line, the crew is ready per the IOI step 8.4 to downshift Reactor Recirc Pumps to Slow Speed per SOI 04-1-01-B33-1 section 4.3.

REVISION 0 1/11/2007

SCENARIO 1 PAGE 172 of 272



JOB PERFORMANCE MEASURE

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 173 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

### Feedwater rupture in the Drywell

Once the Reactor Recirc Pumps are in slow speed and the Lead Evaluator concurs, <u>activate</u> <u>TRIGGER 5.</u>

The reactor will scram on Drywell pressure and will continue to rise from the Feedwater Line Break.

There will be 3 control rods stuck at position 48.

B21-F065A Feedwater Isolation Valve will close when the operator gives it the signal to close.

RCIC can be used to inject to the reactor via Feedwater line B.

Recirc loop leakage simulating check valve leakage will ramp rr063b to 4.6% over 2 minutes.

MSIVs will close due to loss of both RPS buses.

Five minutes after the Feedwater rupture, RCIC will have a steam leak due to packing problems in the RCIC Room. RCIC will fail to automatically isolate on high temperatures, but the operator can manually isolate the system from H13-P601.

Crew will implement actions of EP-2A and EP-3, EP-4 when RCIC Steam Leak occurs.

After the LOCA is detected, perform the following attachments when requested.

Attachment 12 Defeat SDC interlocks4 minutes to DONEAttachment 12 for RHR 'B' can be of use.4

EP Attachments which may be requested:

Attachment 19Defeat RPS	4 minutes to DONE
Attachment 20Defeat RCIS	5 minutes to DONE
Attachment 8 Defeat MSIV isolations	9 minutes to DONE
If Attachment 8 is requested early by itself	- 3 minutes to DONE
Attachment 18Defeat ATWS ARI	3 minutes to DONE

**REVISION 0 1/11/2007** 

SCENARIO 1 PAGE 173 of 272



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 174 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

RCIC will be initially available until the time of the steam leak.

RHR 'A' Shutdown Cooling line are not available due to the 'B' Feedwater Line break.

Once B21-F065A is closed Condensate and Feedwater can be restored through the 'B' Feedwater injection line and level restored. To inject Reactor Pressure will have to be lowered to use Condensate Booster Pumps.

RPS buses will have to be shifted to Alternate and EPA breakers reset to allow insertion of control rods.

Once attachments are installed for control rod insertion **remove stuck control rod malfunction** for control rods as selected to insert the rods with elevated drive pressure.

Inserts Control Rods using elevated drive pressure and RCIS.

Attachments 25 (Condensate Transfer) and 26 (Fire Water) can not be installed by any remote functions just acknowledge the request.

## TERMINATION

Once Reactor level is being restored with Condensate/Feedwater or Low Pressure ECCS and at least the first control rods has been fully inserted and the Lead Evaluator concurs the scenario may be terminated.

### Critical Tasks

- When allowed by Level/Power Control leg of EP-2A, restores injection from Condensate/Feedwater.
- Insert rods by manual scrams and normal rod insertion using attachments 18, 19, 20.

### **Emergency Plan Procedure – Emergency Action Level Classification**

<u>Alert</u> based on 10-S-01-1 Attachment I FA1 RCS loss or SA3 more than one control rod past position 02 and power <4% on APRMs.

REVISION 0 1/11/2007

SCENARIO 1 PAGE 174 of 272



**JOB PERFORMANCE** 

**MEASURE** 

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 175 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

Form ES-D-2 Appendix D Operator Actions Op-Test No.: \_\_\_\_\_ Scenario No.: \_\_1\_\_\_ Event No.: \_\_\_1\_\_ Event Description: Lower Reactor Power using control rods to below 75% rod line. (Control Rod Movement Sequence Sheet) Time Position Applicant's Actions or Behavior SS Conduct reactivity manipulation brief. RO Inserts control rods in individual or gang per control rod movement sequence sheet to lower power to below the 75% rod line. BOP Assists RO in Control Rod selection verification, monitors Pressure, Level, Power, and Turbine Loading.

REVISION 0 1/11/2007

SCENARIO 2 PAGE 175 of 272



**JOB PERFORMANCE** 

**MEASURE** 

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 176 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

Appendix	( D	Operator Actions	Form ES-D-2		
Op-Test Event De	Op-Test No.: Scenario No.:1 Event No.:2 Event Description: Respond to RPS Motor Generator B trip.				
	(ONE)	P 05-1-02-III-2 and SOI 04-1-01-C71-1)			
Time	Position	Applicant's Actions or Behavior			
	RO	Responds to Reactor Scram and HCU Trouble annunciator (ARI 04-1-02-1H13-P680)	rs.		
	RO	Identifies the control rod HCUs 12-13, 12-53, 20-05, 20-61 alarms and are associated with RPS B power.	have trouble		
	вор	Responds to H13-P610 to determine the loss of RPS B nor supply and the Alternate Power for RPS B is available	rmal power		
	BOP	Verifies RPS A is on its Alternate Power Source.			
	SS	Reviews Precautions and Limitations of SOI 04-1-01-C71-1 05-1-02-III-2 and determines RPS B must remain de-energ (FSAR 8.3.1.1.5.4) Tech Spec 3.3.8.2 is not applicable.	I and ONEP jized.		
	SS	Consult with Duty Manager concerning operating with half sloss of RPS bus.	scram due to		

REVISION 0 1/11/2007

SCENARIO 2 PAGE 176 of 272



**JOB PERFORMANCE** 

**MEASURE** 

Number: GJPM-SRO-A&E-43Revision: 00Page: 177 of 272Rtype: \_\_\_\_\_QA RecordNumber of pages \_\_\_\_\_Date \_\_\_\_\_ Initials \_\_\_\_\_

SS	Briefs Crew on contingencies and situation of operating with a half scram.

REVISION 0 1/11/2007

SCENARIO 2 PAGE 177 of 272



**JOB PERFORMANCE** 

**MEASURE** 

Number: GJPM-SRO-A&E-43 Revision: 00 Page: 178 of 272 Rtype: \_\_\_\_\_ QA Record Number of pages \_\_\_\_\_ Date \_\_\_\_ Initials \_\_\_\_

Appendix	D	Operator Actions	Form ES-D-2	
Op-Test No.: Scenario No.:1 Event No.:3 Event Description: Respond to Standby Gas Treatment A Exhaust Fan Trip (ARI 04-1-02-1H13-P870; SOI 04-1-01-T48-1)				
Time	Position	Applicant's Actions or Behavior		
	BOP	Responds to SGTS FLTR TR A FAN PROT TRIP alarm. (ARI 04-S-02-1H13-P870 2A-A2)		
	SS	Dispatches an operator to SBGT Train A to investigate prol	olem.	
	SS/BOP	Determine the circuit breaker number for T48-D001A 52-15 Operator will report the circuit breaker is TRIP FREE.	51117. The	
	SS	Direct restoration of Auxiliary Building Ventilation to normal		
	BOP	Restores Auxiliary Building Ventilation to normal using Surv 06-OP-1T48-M-0001 or SOI 04-1-01-T48-1	veillance	
	SS	Determines Tech Spec actions for failed SBGT Train. (Tech Condition A restore within 7 days)	n Spec 3.6.4.3	

REVISION 0 1/11/2007

SCENARIO 2 PAGE 178 of 272



**JOB PERFORMANCE** 

**MEASURE** 

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 179 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

Appendix	D	Operator Actions	Form ES-D-2	
Op-Test No.: Scenario No.:1 Event No.:4 Event Description: Downshift Reactor Recirc pumps to slow speed. (SOI 04-1-01-B33-1)				
Time	Position	Applicant's Actions or Behavior		
	SS	Performs Reactivity Briefing.		
	RO	Downshifts Reactor Recirc Pumps to Slow Speed. Closes Recirc FCV A and B to MIN ED position. Verifies parameters for downshift. Depresses both Trans to LFMG pushbuttons and Pump Circuit Breaker operation. Opens Recirc FCV A and B to maximum position. Adjusts tap settings on BOP Transformers 11B ar	verifies Recirc nd 12B.	

REVISION 0 1/11/2007

SCENARIO 2 PAGE 179 of 272



JOB PERFORMANCE MEASURE Number: GJPM-SRO-A&E-43Revision: 00Page: 180 of 272Rtype: \_\_\_\_\_QA RecordNumber of pages \_\_\_\_\_Date \_\_\_\_\_ Initials \_\_\_\_\_

Appendi	x D	Operator Actions	Form ES-D-2	
[ <del></del>				
Op-Test No.: Scenario No.:1_ Event No.:5				
Event D	escription: Feed	lwater Rupture in the Drywell with leakage past o	check valves	
	from the Re	actor / Multiple Control Rods not fully inserted F	RCIC Steam leak.	
(EOP 0	<u>5-S-01-EP-2A; (</u>	05-1-01-EP-3 and 05-1-01-EP-4)		
Time	Position	Applicant's Actions or Behavior		
	RO	Recognizes scram on High Drywell Pressure/Low level and performs the immediate actions for Rea Reports all rods NOT fully inserted and places the Switch to SHUTDOWN. Performs Scram Report. Part of Scram Report should include APRM powe Reports MSIVs are closed.	Reactor Water ctor Scram. Reactor Mode r is less than 4%.	
	RO	Determines 3 control rods not fully inserted. 60-21 60-25 60-29		
	RO	Recognizes loss of ability to feed the reactor with Feedwater. Communicates the loss to the SS. D conditions, RO may recognize which feed line has Indications on H13-P680 section 2B indicators: A FW FLO C34-R604A upscale B FW FLO C34-R604B downscale A FW FLO C34-FR-R616 Blue Pen upscale B FW FLO C34-FR-R616 Blue Pen upscale B FW FLO C34-FR-R616 Red Pen downscale	Condensate and epending on s rupture.	

REVISION 0 1/11/2007

SCENARIO 2 PAGE 180 of 272


Number: GJPM-SRO-A&E-43 Revision: 00 Page: 181 of 272 Rtype: \_\_\_\_\_ QA Record Number of pages \_\_\_\_\_ Date \_\_\_\_\_ Initials \_\_\_\_\_

JOB PERFORMA	ANCE
MEASURE	

RO	Secures the Condensate and Feedwater Systems by tripping all operating pumps and attempt to isolate the affected Feedwater line by closing B21-F065A Feedwater Inlet Shutoff Valve on H13-P680 section 2C.
SS	Enters EP-2A and EP-3, orders the BOP Operator to initiate RCIC and inhibit ADS (HPCS is tagged out).
BOP or RO	Verifies/initiates RCIC (If RO/SS determine which Feedwater Line is ruptured allows injection of RCIC due to it injects via the unaffected Feedwater line.) Level band should be +30 to -30 inches.

REVISION 0 1/11/2007

SCENARIO 2 PAGE 181 of 272



**JOB PERFORMANCE** 

**MEASURE** 

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 182 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_\_

Appendi	x D	Operator Actions Form ES-D-2		
Op-Test Event D	Op-Test No.: Scenario No.:1 Event No.:5 (Cont.) Event Description: Feedwater Rupture in the Drywell with leakage past check valves from the Reactor / Multiple Control Rods not fully inserted RCIC Steam leak.			
(EOP 05	5-S-01-EP-2A; 0	95-1-01-EP-3 and 05-1-01-EP-4)		
Time	Position	Applicant's Actions or Behavior		
	SS	Orders CRD maximized and possible initiation of SLC. (Optional) SLC injection may not be necessary due to Reactor power being less than 4%.		
	RO/BOP	Maximizes CRD for FLOW per operator aid.		
	SS	May order manual initiation and overriding of Low Pressure ECCS.		
	BOP/RO	If ordered, manually initiates and overrides Low Pressure ECCS.		
	SS	Dispatches EP Attachments to be installed Attachment 12 RHR through Shutdown Cooling (May note not to perform for RHR 'A') Attachment 25 Condensate Transfer injection Attachment 26 Fire Water injection		
	RO/BOP	Reports the isolation of B21-F065A allowing the restoration of Condensate and Feedwater for injection to the reactor vessel.		

REVISION 0 1/11/2007

SCENARIO 2 PAGE 182 of 272



JOB PERFORMANCE MEASURE Number: GJPM-SRO-A&E-43 Revision: 00 Page: 183 of 272 Rtype: \_\_\_\_\_\_ QA Record Number of pages \_\_\_\_\_ Date \_\_\_\_\_ Initials \_\_\_\_\_

SS **	Orders restoration of Condensate and Feedwater for RPV level control using the Startup Level Control Valve through the 'B' Feedwater Line with a Normal RPV Level Band (+11.4 to 53.5 inches). If +30 inches to -30 inches band was already ordered may remain with this band.
RO **	Aligns Condensate and Feedwater for injection to the RPV through 'B' Feedwater Line using one or two Condensate and Condensate Booster Pumps through the Startup Level Control Valve.

\*\* Critical Task

REVISION 0 1/11/2007

SCENARIO 2 PAGE 183 of 272



JOB PERFORMANCE MEASURE Number: GJPM-SRO-A&E-43Revision: 00Page: 184 of 272Rtype: \_\_\_\_\_QA RecordNumber of pages \_\_\_\_\_Date \_\_\_\_\_Initials \_\_\_\_\_

Appendi	x D	Operator Actions	Form ES-D-2		
Op-Test	Op-Test No.: Scenario No.:1 Event No.:5 (Cont.)				
Event D	escription: Feed	water Rupture in the Drywell with leakage past ch	eck valves		
	from the Rea	actor / Multiple Control Rods not fully inserted RC	IC Steam leak.		
(EOP 05	5-S-01-EP-2A; 0	5-1-01-EP-3 and 05-1-01-EP-4)			
Time	Position	Position Applicant's Actions or Behavior			
	SS	Orders reduced Pressure Band 400-600 psig to allo using Condensate and Condensate Booster Pumps	w injection		
	BOP/RO         Lowers Reactor pressure to a band of 400 – 600 psig to allow           Condensate and Condensate Booster Pumps to inject to the RI		ig to allow act to the RPV.		
IF the c	closure of B21-	F065A is not noted or accomplished, the following taken to restore RPV Level.	ı steps will be		
	SS **	Orders alignment of Low Pressure ECCS for injection Reactor.	on to the		
	BOP or RO	Align Low Pressure ECCS for injection.			
	SS **	If Reactor Level drops below – 160 inches, orders E Depressurization with 8 SRVs (at least 5 SRVs shou	mergency ıld be open)		

REVISION 0 1/11/2007

SCENARIO 2 PAGE 184 of 272



**JOB PERFORMANCE** 

**MEASURE** 

Number: GJPM-SRO-A&E-43 Revision: 00 Page: 185 of 272 Rtype: \_\_\_\_\_\_ QA Record Number of pages \_\_\_\_\_ Date \_\_\_\_\_ Initials \_\_\_\_\_

BOP or RO **	On orders, opens 8 SRVs using handswitches (initiation pushbuttons may be used initially, however should be followed with handswitches.)	
SS **	If conditions require RPV Flooding, orders injection to attain RPV pressure 57 psig above Containment pressure	
BOP or RO	Verifies injection to the RPV with Low Pressure ECCS.	
RO	Restores level using LP ECCS with band of +30 inches to -30 inches Wide Range.	

\*\* Critical task

REVISION 0 1/11/2007

SCENARIO 2 PAGE 185 of 272



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 186 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

Appendix D Operator Actions Form ES-D			Form ES-D-2
Op-Test	t No.: So	enario No.: <b>1</b> Event No.: <b>5</b> (Cont.)	
Event D	escription: Feed	lwater Rupture in the Drywell with leakage past ch	neck valves
	from the Re	actor / Multiple Control Rods not fully inserted R	CIC Steam leak.
(EOP 0	5-S-01-EP-2A; (	05-1-01-EP-3 and 05-1-01-EP-4)	
Time	Position	Applicant's Actions or Behavior	
	When RCIC	Steam Leak occurs, the following actions will be t	taken.
	BOP	Reports RCIC Room Temperatures above isolation setpoint and failure of RCIC to isolate and isolates E51-F063 and F064.	
	SS	Enters EP-4 to verify actions taken for breach of Pr Containment.	imary
		Actions to be taken to insert Control Rods	
	SS	Dispatches EP Attachments to be installed for rod i Attachment 18 Defeat ATWS ARI Attachment 19 Defeat RPS Attachment 20 Defeat RCIS	insertion:
	SS	Orders RPS Bus(es) EPA Breakers reset and close Feeders.	ed on Alternate
	BOP/RO	Verifies/transfers RPS buses to Alternate Power So	ource.
REVISIO	N 0 1/11/2007	SCENARIO 2 NUREG 1021 RE PAGE 186 of 272	EVISION 9



## GRAND GULF NUCLEAR STATION

Number: GJPM-SRO-A&E-43 Revision: 00 Page: 187 of 272 Rtype: \_\_\_\_\_ QA Record Number of pages \_\_\_\_\_ Date \_\_\_\_\_ Initials \_\_\_\_\_

<b>JOB PERFORMANCE</b>	
MEASURE	

SS	Orders restoration of Auxiliary Building, Containment and Drywell isolation valves.
BOP	When ordered by SS, restores Auxiliary Building, Containment, and Drywell isolation (Instrument Air, Plant Service Water, and Drywell Chilled Water). (Attachment 7 of EP-1)

REVISION 0 1/11/2007

SCENARIO 2 PAGE 187 of 272



**JOB PERFORMANCE** 

**MEASURE** 

Number: GJPM-SRO-A&E-43 Revision: 00 Page: 188 of 272 Rtype: \_\_\_\_\_ QA Record Number of pages \_\_\_\_\_ Date \_\_\_\_ Initials \_\_\_\_

Append	ix D	Operator Actions	Form ES-D-2
Op-Tes	t No.: S	cenario No.:1_ Event No.:5 (Cont	.)
Event D	Description: Fee	dwater Rupture in the Drywell with leakage	past check valves
	-		-
	from the Re	eactor / Multiple Control Rods not fully inse	rted RCIC Steam leak.
(EOP 0	5-S-01-EP-2A;	05-1-01-EP-3 and 05-1-01-EP-4)	
Time	Position	Applicant's Actions or Bel	navior
	RO/BOP	Adjusts CRD Drive Pressure for Control Ro	d insertion.
	RO/BOP **	Insert Control Rods by scramming rods and CRD/RCIS. CRD Drive Pressure, Instrume and Auxiliary Building, and RPS reset. Con using RCIS with elevated CRD Drive Pressu	inserting rods using nt Air to Containment trol Rods will insert ure.

\*\* Critical task

REVISION 0 1/11/2007

SCENARIO 2 PAGE 188 of 272



**JOB PERFORMANCE** 

**MEASURE** 

Number: GJPM-SRO-A&E-43 **Revision: 00** Page: 189 of 272 **Rtype: QA Record** Number of pages Date \_\_\_\_\_ Initials \_\_\_\_\_

)-1

Appendix D	Scenario Outline	Form ES-L
Facility: GRAND GULF	NUCLEAR STATION Scenario No.: 2	Op-Test No.: Day 2
Examiners:	Operators:	
<ul> <li><u>Objectives:</u> To evaluate evolutions:</li> <li>1. Startup 2<sup>nd</sup> RFPT</li> <li>2. Raise Reactor P ONEP 05-1-02-I</li> <li>3. Respond to APR</li> <li>4. Respond to Pres</li> <li>5. Take actions per ATWS.</li> <li>6. Respond to failur</li> </ul>	e the candidates' ability to operate the fac and place on Master Controller. ower by withdrawing control rods. Respo V-1. M D failure upscale. sure Controller fault Reactor Pressure risi the EOPs in response to an ATWS and r	ility in response to the following nd to single control rod stuck per ing. nitigate the consequences of the unction.
Initial Conditions: Rea Reactor Recirculation pr Level Control; both Hea	ictor Power is at 50 %. Plant startup is in umps in Fast Speed; a single Reactor Fee ter Drain Pumps are pumping forward.	progress following an outage. ed Pump in Three element Master
INOPEKABLE E SRM 'F' are INOP IRMs 'A' & 'H' are APRM 'H' is INOP	and bypassed. INOP and bypassed. due to failed downscale and is bypassed	

HPCS Pump is tagged out of service for failure of the Jockey Pump.

ESF 12 Transformer is tagged out of service for maintenance.

RPS 'A' is on Alternate Power due to EPA circuit breaker failure.

SBGT 'A' is operating for surveillance.

Appropriate clearances and LCOs are written.

Turnover: Continue plant startup per IOI-2. Ready for startup of RFPT 'B'. There are scattered thunder showers reported in the Tensas Parish area.

REVISION 0 1/11/2007

SCENARIO 2 PAGE 189 of 272



**JOB PERFORMANCE** 

**MEASURE** 

Number: GJPM-SRO-A&E-43 Revision: 00 Page: 190 of 272 Rtype: \_\_\_\_\_ QA Record Number of pages \_\_\_\_\_ Date \_\_\_\_\_ Initials \_\_\_\_\_

Event No.	Malf. No.	Event Type*	Event Description
1		N (RO)	Place RFPT B in service on the Master Level Controller. (SOI 04-1-01-N21-1)
2		R (RO)	Raise Reactor power using control rods to 52%. (Control Rod Pull Sheet)

REVISION 0 1/11/2007

SCENARIO 2 PAGE 190 of 272



**JOB PERFORMANCE** 

**MEASURE** 

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 191 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_

 Date \_\_\_\_\_ Initials \_\_\_\_\_

Appendix D

Scenario Outline

Form ES-D-1

Scenario 2 Day 2 (Continued)

Event No.	Malf. No.	Event Type*	Event Description
3	1	C (RO/ BOP) TS (SS)	Respond to single control rod immovable taking actions to move the control rod. (ONEP 05-1-02-IV-1) Disarm Control Rod. Complete <b>Technical Specification</b> determination.
4	2	C (RO) TS (SS)	Respond to failure of APRM D upscale. Complete <b>Technical Specification</b> determination. (ARI 04-1-02-1H13-P680 7A-B11)
5	3	C(RO)	Respond to a failure of the Reactor Pressure Control System with pressure rising. (ARI 04-1-02-1H13-P680 9A- D2)
6	4	C (RO)	Recognize a failure to scram using RPS and manually scram the reactor using ATWS ARI.
7	5	M (ALL)	Respond to ATWS with partial Main Steam Bypass Valve availability. (EOP 05-1-01-EP-2A)
	6	C (BOP)	Respond to a failure of Standby Liquid Control to initiate. (SOI 04-1-01-C41-1 and EOP 05-1-01-EP-2A)

\* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor

# Critical Tasks

- Inserts rods by manual scrams and normal rod insertion using Attachments 18, 19, and 20.
- When allowed by Level / Power Control leg of EP-2A, restores injection from Condensate / Feedwater.
- Terminates and prevents all injection except boron, CRD and RCIC when required by steps L-7 or 8 of EP-2A.

REVISION 0 1/11/2007	SCENARIO 2	NUREG 1021 REVISION 9	
	PAGE 191 of 272		

	GRAND GULF NUCLEAR STATION	Number: GJPM-SRO-A&E-43 Revision: 00 Page: 192 of 272
Entergy	JOB PERFORMANCE MEASURE	Rtype:      QA Record      Number of pages      Date      Initials

- For ATWS above 4% power, injects SLC A/B before Suppression Pool temperature reaches 115 degrees F.

REVISION 0 1/11/2007

SCENARIO 2 PAGE 192 of 272



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 193 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

Scenario 2 Day 2 (Continued)

#### Crew Turnover:

Rx is at 50% CTP.

SRMs 'F' is bypassed.

IRMs 'A' & 'H' are INOP and bypassed.

APRM 'H' is INOP and bypassed due to failed downscale.

HPCS Pump is tagged out of service for failure of the Jockey Pump.

ESF Transformer 12 is tagged out of service for Entergy –Mississippi maintenance.

RPS 'A' is on Alternate Power due to EPA circuit breaker failure.

SBGT 'A' is operating for surveillance 06-OP-1T48-M-0001 section 5.2.11 allowing the System Engineer to obtain data.

Hydrogen Water Chemistry and Alternate Cooling Tower are out of service.

Both Circ Water Pumps are in service.

Appropriate clearances and LCOs are written.

Continue plant startup per IOI-2.

Ready for startup of RFPT 'B'.

REVISION 0 1/11/2007

SCENARIO 2 PAGE 193 of 272

	GRAND GULF NUCLEAR STATION	Number: GJPM-SRO-A&E-43 Revision: 00 Page: 194 of 272
Entergy	JOB PERFORMANCE MEASURE	Rtype:      QA Record      Number of pages      Date      Initials

Control Rod movement is at step 120b for the Startup Sequence.

Plant EOOS factor is 7.3 YELLOW.

There are scattered thunderstorms reported in the Tensas Parish area.

REVISION 0 1/11/2007

SCENARIO 2 PAGE 194 of 272



**Simulator Setup:** (Scenarios may be setup and shot into encrypted ICs and Password protected.)

Start the process from a new simulator load. Reset to IC-13.

Verify or perform the following:

IC:	13					
OOS:	APRM H (Place in Bypass w/ Caution tag)					
	IRMs A & H (Place in Bypass w/ Caution tag)					
SRMs F (Place in Bypass w/ Caution tag)						
	RPS A (Transfer to Alternate Power and reset RPS A w/ Caution tag)					
	Manually Initiate SBGT A					
	HPCS and HPCS Jockey Pump OOS (Place HPCS OOSVC to OOSVC					
	and place tags on HPCS Pump and Jockey Pump HS)					
	ESF XFMER 12 (Place tag on J3885, 152-1903, 152-1904, 152-1905,					
	152-1511, 152-1611, 152-1704 HS)					
Active malfur	nctions: <b>c51002f</b> SRM F incorporated into present simulator load					
	c51005a IRM A incorporated into present simulator load					
	c51005h IRM H incorporated into present simulator load					
	c51010h APRM H downscale					
c71077a RPS A MG failure (Normal EPA OOS)						
z022022_36_37 Control rod 36-37 stuck						
c11164@20% CRD Hydraulic Block						
c41f004a_d SLC Squib fail to fire						
	c41f004b_d SLC Squib fail to fire					
Active Remo	te Functions: <b>p81218</b> J3885 115KV Disconnect <b>OPEN</b>					
	e22644 HPCS Pump BKR OUT					
	e22646 HPCS JKY pump breaker OPEN					
152-1	511 lo_1r21m601a_g Bus 15AA FDR FM ESF XFMR 12 OFF					
	di_1r21m601ap864/01c Bus 15AA FDR FM ESF XFMR 12 TRIP					
152-1	611 lo_1r21m601b_g Bus 16AB FDR FM ESF XFMR 12 OFF					
<b>REVISION</b> 0	1/11/2007 SCENARIO 2 NUREG 1021 REVISION 9					
	PAGE 195 of 272					

	GRAND GULF NUCLEAR STATION	Number: GJPM-SRO-A&E-43 Revision: 00 Page: 196 of 272
Entergy	JOB PERFORMANCE MEASURE	Rtype:      QA Record      Number of pages      Date      Initials

di_1r21m601bp864/02c Bus 16AB FDR FM ESF XFMR 12 TRIP						
152-1704 lo_1e22m709_g 17AC FDR FM ESF 12 OFF						
	di_1e22m709p601/16c 17AC FDR FM ESF 12 OFF					
152-1903 lo_1r21m	623_g Bus 15AA/16AB/27AC FDR FM ESF XFMR 12 OFF					
	di_1r21m623p807/01c Bus 15AA/16AB/27AC FDR FM ESF XFMR 12					
	TRIP					
152-1904 lo_1r21m	624_g Bus 17AC/25AA/26AB FDR FM ESF XFMR 12 OFF					
	di_1r21m624p807/01c Bus 17AC/25AA/26AB FDR FM ESF XFMR 12					
	TRIP					
152-1905 lo 1r21m	637 g SWYD XFMR T3 FDR FM ESF XFMR 12 OFF					
—	di 1r21m637p807/01c SWYD XFMR T3 FDR FM ESF XFMR 12					
	TRIP					
Active Case File: cae sgt	tsai.cae SBGT A operating for surveillance					
Active overrides: None						
Pending overrides:	None					
Pending malfunctions:	c51009d APRM D failed upscale (TRG 4)					
	c71162 Failure to Scram Manual and Automatic (ATWS ARI Available)					
	(TRG 5)					
	tc079 3 second time delay ramp to 0% over 15 seconds Pressure Control					
Failure pressure rising (TRG 5)						
tc082a Main Steam Bypass valve 'A' failed closed after 3 minute TD						
	(TRG 20)					
	tc082b Main Steam Bypass valve 'C' failed closed after 3 minute TD					
	(TRG 20)					

Pending component malfunctions: None

Trigger files:	Trigger 4 APRM D Failed upscale				
	Trigger 5 Pressure Controller Failure - Pressure rising				
	Trigger 20 Bypass Valves failed closed				

REVISION 0 1/11/2007	SCENARIO 2	NUREG 1021 REVISION 9
	PAGE 196 of 272	



**JOB PERFORMANCE** 

**MEASURE** 

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 197 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

COMPONENT	PANEL	INDICATION or	SIMULATOR	STATUS	DONE
		CONTROL	CODE		
APRM H			c51010h	downscale	
HPCS PUMP	P601-16C		e22644_OUT	OUT	
HPCS Jockey Pump	P601-16C		e22646_OPEN	OPEN	
RPS A on Alternate	P610	Handswitch	c71077a	ALT	
152-1511	P864-1C	Green light	lo_1r21m601a_g	OFF	
	P864-1C	Handswitch	di_1r21m601a	STOP	
152-1611	P864-2C	Green light	lo_1r21m601b_g	OFF	
	P864-2C	Handswitch	di_1r21m601b	STOP	
152-1704	P601-16C	Green light	lo_1e22m709_g	OFF	
	P601-16C	Handswitch	di_1e22m709	STOP	
152-1903	P807-1C	Green light	lo_1r21m623_g	OFF	
	P807-1C	Handswitch	di_1r21m623	STOP	
152-1904	P807-1C	Green light	lo_1r21m624_g	OFF	
	P807-1C	Handswitch	di_1r21m624	STOP	
152-1905	P807-1C	Green light	lo_1r21m637_g	OFF	
	P807-1C	Handswitch	di_1r21m637	STOP	
J3885 115 KV Disconnect	P807-1C	Green Light	p81218	OPEN	

Bypass Division 2 APRM Bypass Joystick to APRM H position.

IRMs A and H, SRM F are bypassed in the IC setup for Cycle 15.

Verify or perform the following:

Verify Reactor Power is above the 75% rod line.

Open Circuit Breakers 152-1903, 1904, 1905, 1511, 1611, and 1704

Place HPCS OOSVC handswitch to OOSVC.

Place RPS A on Alternate Power and RESET RPS A logic on P680.

Verify SBGT A is operating.

REVISION 0 1/11/2007

SCENARIO 2 PAGE 197 of 272



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 198 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

Startup all PDS / SPDS screens. Clear any graphs and trends off of SPDS.

Setup the presently used cyclops display and verify it is functional.

Ensure the correct startup sequence is available at the P680 for the present IC.

Install turnover guide, red tag, and LCO paperwork as applicable.

Advance all chart recorders and ensure all pens are inking properly. (APRM chart recorders must be turned on and settings for scales on pens 0 - 125 scale)

Place tags on ALL circuit breakers associated with the ESF 12 Transformer outage.

Place tags on APRM H, IRM A & H and SRMS F Joysticks.

Place tags on HPCS Pump and Jockey Pump handswitches.

REVISION 0 1/11/2007

SCENARIO 2 PAGE 198 of 272



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 199 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

### **SIMULATOR OPERATION SCENARIO 2**

Once simulator is reinitialized and setup complete take the simulator out of Freeze.

Once the Crew has taken control note the simulator time.

### Place RFPT B on Master Level controller

Start RFPT B per SOI 04-1-01-N21-1 section 4.5.5 and 4.6.5. Cues:

If asked, as Turbine Building Operator close RFPT Steam line drains on P175.

If asked, biasing on the Reactor Feed Pumps should be balanced.

Cue: The CRS to raise reactor power to 55% for Reactor Engineering data.

### Raise Reactor Power using control rods

The RO will raise reactor power by withdrawing control rod per the Control Rod Movement Sequence. Cues:

If asked, as Reactor Engineer withdraw control rods per the movement sequence beginning at step 102b.

### **Immovable Control Rod**

When the RO gets to control rod 36-37 the control rod will NOT move. This will prompt entry into ONEP 05-1-02-IV-1 Control Rod/Drive Malfunctions section 3.5.

Cues:

If asked, as Reactor Engineering raising CRD Drive Pressure is acceptable.

If asked, as Auxiliary Building Operator report CRD Drive Filter DP 17 psid, Suction Filter DP is 2.1 psid, Backwash Filter DP is 2.0 psid and the CRD Flow Control Station is functioning properly.

REVISION 0 1/11/2007	<b>SCENARIO 2</b>	NUREG 1021 REVISION 9
	PAGE 199 of 272	



If asked, as Reactor Engineering about individually scramming the control rod inform the CRS that analysis on the effects needs to be performed hold reactor power at this point. Until further analysis individually scramming the control rod is NOT acceptable.

If asked, report as Auxiliary Building Operator Local Drive Water Pressure gages are tagged out for a work order to replace the gages.

SS should consult Tech Specs for TS 3.1.3 and declare the control rod INOP. SS may consider a Potential LCO for TS 3.1.4 Scram Times

REVISION 0 1/11/2007

SCENARIO 2 PAGE 200 of 272



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 201 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

### **APRM D failure Upscale**

One minute after Reactor Engineering cue, activate TRIGGER 4.

Cues:

# If asked, report as I&C the APRM is hard failed upscale with no apparent cause and it will require further investigation.

SS should direct un-bypassing APRM H and bypassing APRM D to clear the scram signal and take the Control Rod Withdrawal Block. Then direct resetting RPS B.

SS will consult Tech Specs for 3.3.1.1 Reactor Protection System Instrumentation is NOT met for RPS B and 3.3.2.1 Control Rod Block Instrumentation is met but a Potential LCO is appropriate.

### **Reactor Pressure Control System Failure - RPV Pressure Rising**

One minute after the Tech Spec call, activate TRIGGER 5.

This will cause a pressure controller failure raising reactor pressure and initiating a Reactor Scram signal (Automatic RPS actuation will fail however the RO can insert a manual reactor scram signal to RPS and subsequent ATWS due to a CRD Scram Discharge Volume Hydraulic Block.

The Main Steam Bypass valves will be available for pressure control for 3 minutes after the Manual Bypass Jack is energized at which time Bypass Valves A and B will fail closed. Bypass Valve C is available.

This is an ATWS with limited Main Steam Bypass Valves available for Reactor Pressure Control.

EP Attachments which may be requested:

Attachment 12 Defeat R	HR Shutdown Cooling	interlocks	6 minutes to DONE
Attachment 19 Defeat R	PS	4 minutes to DO	NE
Attachment 20 Defeat RCIS		5 minutes to DONE	
Attachment 8 Defeat M	ISIV isolations	9 minutes to l	DONE
REVISION 0 1/11/2007	SCENARIO 2 PAGE 201 of 272	NUREG 10	21 REVISION 9

	GRAND GULF NUCLEAR STATION	Number: GJPM-SRO-A&E-43 Revision: 00 Page: 202 of 272
Entergy	JOB PERFORMANCE MEASURE	Rtype:      QA Record      Number of pages      Date

If Attachment 8 is requested early by itself - 3 minutes to DONE Attachment 18 Defeat ATWS ARI 3

3 minutes to DONE

REVISION 0 1/11/2007

SCENARIO 2 PAGE 202 of 272



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 203 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

# TERMINATION

Once Control Rods are being inserted and the Lead Evaluator concurs, the scenario may be terminated.

## Critical Tasks

- Inserts rods by manual scrams and normal rod insertion using Attachments 18, 19, and 20.
- When allowed by Level / Power Control leg of EP-2A, restores injection from Condensate / Feedwater.
- Terminates and prevents all injection except boron, CRD and RCIC when required by steps L-7 or L-8 of EP-2A.
  - For ATWS above 4% power, injects SLC A/B before Suppression Pool temperature reaches 115 degrees F.

### **Emergency Plan Procedure – Emergency Action Level Classification**

Site Area Emergency based on 10-S-01-1 Attachment I EAL SS3

REVISION 0 1/11/2007

SCENARIO 2 PAGE 203 of 272



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 204 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_

 Date \_\_\_\_\_ Initials \_\_\_\_\_

Appendi	x D	Operator Actions	Form ES-D-2		
h					
Op-Test	Op-Test No.: Scenario No.:2 Event No.:1				
LVCIILD			-01-INZ 1-1)		
Time	Position	Applicant's Actions or Behavior			
	RO	Starts up RFPT B and places control of the feed pur Master Level Controller SOI 04-1-01-N21-1.	mp on the		
	вор	Monitors Reactor Power, Level and Pressure.			

Op-Test No.: Scenario No.:2 Event No.:2 Event Description: Raise Reactor power by withdrawing control rods. (Control Rod Movement Sequence)			
Time	Position	Applicant's Actions or Behavior	
	SS	Conducts Reactivity Brief on expectations for Control Rod movement.	
	RO	Withdraws control rods in accordance with Control Rod Movement Sequence to raise reactor power.	
	BOP	Peer Check Control Rod selection and movement and assist in monitoring Reactor Level, Pressure and Power.	

REVISION 0 1/11/2007



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 205 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

Appendi	x D	Operator Actions Form ES-D-2	
Op-Test No.: Scenario No.:2_ Event No.:3_ Event Description: Control rod 36-37 immovable (ONEP 05-1-02-IV-1; Tech Specs 3.1.3 and 3.1.4)			
Time	Position	Applicant's Actions or Behavior	
	RO	Recognizes control rod 36-37 will not move when given a withdraw signal.	
	SS	Enter ONEP 05-1-02-IV-1 and contact Auxiliary Building Operator to verify CRD system parameters.	
	SS	Directs raising CRD Drive Water Pressure in 25 psid increments to attempt to move the control rod.	
	BOP	Throttles C11-F003 CRD Pressure Control Valve to adjust CRD Drive Water Pressure.	
	RO	Attempts to move control rod 36-37 and determines control rod is stuck.	
	BOP	Verify Seal Steam Pressure Extraction Steam pressure Low due to down power.	
	SS	Contacts Reactor Engineering for determination to individually scram the control rod.	

REVISION 0 1/11/2007



# JOB PERFORMANCE MEASURE

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 206 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

SS	Refers to Tech Spec 3.1.3 and criteria for TS 3.1.4.

REVISION 0 1/11/2007

SCENARIO 3 PAGE 206 of 272



JOB PERFORMANCE MEASURE

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 207 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_

 Date \_\_\_\_\_ Initials \_\_\_\_\_

Appendi	x D	Operator Actions Form ES-D-2
Op-Tes Event D	t No.: S Description: AP (AF 3.3	Scenario No.:2_ Event No.:4_ PRM D fails upscale RI 04-1-02-1H13-P680 7A-B11; SOI-04-1-01-C51-1; Tech Specs .1.1; 3.3.2.1 and TRM 3.3.1.1)
Time	Position	Applicant's Actions or Behavior
	RO	Responds to and reports the annunciators for APRM D failing upscale and half scram for RPS B. May remind SS that APRM H is bypassed in the Division 2.
	вор	Investigates APRM D and reports failed hard upscale.
	SS	Contacts I&C to investigate APRM D.
	SS	Reviews Tech Specs 3.3.1.1 and 3.3.2.1 and TRM 3.3.1.1. Determination that TS3.3.1.1 is not met due to APRM H and D being INOP in Division 2. (3 of 4 must be operable). TS 3.3.2.1 is met by having 6 of 8 APRMs operable.
	SS	(Optional) May decide to un-bypass APRM H and bypass APRM D to take a Control Rod Withdrawal Block but be able to reset the Division 2 Half Scram signal until I&C can repair either APRM H or D.



 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 208 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

# JOB PERFORMANCE MEASURE

RO	When directed, un-bypasses APRM H and bypasses APRM D.
RO	Resets Division 2 RPS.

REVISION 0 1/11/2007



**JOB PERFORMANCE** 

MEASURE

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 209 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

Appendi	x D	Operator Actions Form E	S-D-2
Op-Test No.: Scenario No.:2_ Event No.:5 / 6_ Event Description: Pressure Controller Failure – Reactor Pressure Rising			
Time	Position	Applicant's Actions or Behavior	
	RO	Responds to Reactor Pressure and Power rising due to failure Pressure Control System closing Turbine Control Valves. Reac Pressure will reach RPS Scram setpoint however RPS will fail t actuate.	of ctor :0
	RO	Manually initiate or verify actuation of ATWS ARI to insert contr rods and inform SS of failure of RPS actuation.	rol
	RO	Observes and reports failure of all control rods to fully insert on ATWS ARI actuation. (CRD Scram Discharge Volume Hydrauli Block)	С
	RO	Observes and reports Reactor Recirc Pumps Tripped to OFF.	
	RO	Provides SS with Scram Report of status of Feedwater, Control Rods, Recirc, and Pressure control.	I

REVISION 0 1/11/2007



**JOB PERFORMANCE** 

MEASURE

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 210 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

Appendi	x D	Operator Actions Form ES-D-2		
Op-Test Event D	Op-Test No.: Scenario No.:2_ Event No.:7 Event Description: ATWS with Partial Main Steam Bypass Valves (05-1-01-EP-2; 2A; and 3			
Time	Position	Applicant's Actions or Behavior		
	SS	Enters EP-2A.		
	BOP	On orders inhibits ADS.		
		HPCS Override is not necessary due to Out of service, may elect to close E22-F004 HPCS Injection valve.		
	RO	Realigns Condensate and Feedwater on Startup Level Control and maintains reactor level within level band specified by the SS. Initially may operate in a normal lineup then transition to Startup Level Control.		
	BOP	Maintains RPV pressure based on SS orders using Turbine Bypass valves or SRVs as appropriate. (optional) Pressure band 800 – 1060 psig. Should attempt to open Main Steam Bypass Valves using the Manual Bypass Jack. This is manually positioning the Bypass valves to maintain pressure. These are acceptable.		
	SS	May order opening of long and short string Main Steam Drains to supplement pressure control.		
	SS	Order manual initiation and overriding of Low Pressure ECCS.		
	BOP	On orders manually initiates and overrides Low Pressure ECCS.		

REVISION 0 1/11/2007



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 211 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_

 Date \_\_\_\_\_ Initials \_\_\_\_\_

BOP/RO	When ordered by SS, restores Auxiliary Building, Containment, and Drywell isolation (Instrument Air, Plant Service Water, and Drywell Chilled Water). (Attachment 7 of EP-1)
--------	--



**JOB PERFORMANCE** 

MEASURE

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 212 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

Appendi	x D	Operator Actions Form ES-D-2		
Op-Test Event D	Op-Test No.: Scenario No.:2_ Event No.:7 Event Description: ATWS with Main Steam Bypass Valves (Cont.)			
Time	Position	Applicant's Actions or Behavior		
	SS **	Orders installation of Attachments 18, 19, and 20 of EP-1. (may not order Attachment 18 since RPS is still energized.)		
	SS	Orders installation of Attachments 8 and 12 of EP-1.		
	BOP	Notifies SS of MSL RAD HI (If Alarmed)		
	SS	Enters EP-4 on MSL RAD HI (If Alarmed)		
	SS **	Based on conditions orders Terminate and Prevent step to lower RPV level to reduce reactor power.		
	BOP/RO **	Terminates and prevents systems ordered by SS RHR A RHR B RHR C LPCS		
	RO **	On orders of SS, initiates flow to the RPV from Condensate / Feedwater.		
	BOP/RO **	Insert Control Rods by inserting rods using CRD/RCIS. CRD Drive Pressure, Instrument Air to Containment and Auxiliary Building, and RPS reset. (Scramming rods is not an option) If low pressure ECCS has been initiated, RPS A has no power because the EPA breakers are tripped due powered from alternate.		

REVISION 0 1/11/2007



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 213 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

\*\* Critical Task

REVISION 0 1/11/2007

SCENARIO 3 PAGE 213 of 272



**JOB PERFORMANCE** 

MEASURE

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 214 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

Appendi	x D	Operator Actions Form ES-E	J-2	
Op-Test Event D	Op-Test No.: Scenario No.:2 Event No.:7			
	r. r.			
Time	Position	Applicant's Actions or Behavior		
	SS**	If Reactor power is above 4%, orders Standby Liquid Control (SL initiation. (Must be ordered before 115 degrees F in Suppression Pool.	<u>.</u> C) ו	
	BOP	On orders initiates both trains of Standby Liquid Control.		
	BOP	Observes failure of SLC Squib Valves to fire and reports to SS.		
	SS	Orders injection of boron using Attachment 28 of EP-1		
	BOP/RO	Report failure of A and B Bypass Valves. C Bypass Valve still functioning		
	SS	Orders maintaining RPV Pressure using C Bypass Valve and SRVs.		

\*\* Critical Task



**JOB PERFORMANCE** 

MEASURE

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 215 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

Appendix D		Operator Actions Form ES-D-2				
Op-Test No.: Scenario No.:2 Event No.:7 Event Description: ATWS with Main Steam Bypass Valves (cont.)						
Time	Position	Applicant's Actions or Behavior				
	BOP/RO	Maintains RPV Pressure using C Bypass Valve and SRVs.				
	SS	If level drops below –191 inches Fuel Zone and cannot be restored, may elect to Emergency Depressurize. (Optional) (SS may continue if systems are available to raise level.)				
	SS	If Emergency Depressurization is required, orders to Initiate Standby Liquid Control will be given.				
	SS	Orders Terminate and Prevent step for Emergency Depressurization. (Optional)				
	BOP/RO	Terminates and prevents injection systems ordered by SS. (Optional) Boron, CRD and RCIC are acceptable to remain operating and injecting.				
	BOP/RO	If ordered opens 8 ADS SRVs. (Optional)				
	SS	Upon Reactor pressure drop < 219 psig with 8 SRVs (see Table 6 of EP-2A) open, orders slow injection with Condensate and Feedwater. (Optional)				
	BOP/RO	Injects with Condensate at prescribed rates by SS. (Optional)				

<u>Optionals</u> for Emergency Depressurization leg of EP-2A are only if SS elects to use this based on RP

REVISION 0 1/11/2007



**JOB PERFORMANCE** 

MEASURE

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 216 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

Appendi	x D		Scenario Outline	Form ES-D-1			
Facility: GRAND GULF NUCLEAR STATION Scenario No.: 3 Op-Test No.: Day 2							
Examine	ers:		Operators:				
				_			
<ul> <li>Objectives: To evaluate the candidates' ability to operate the facility in response to the following evolutions:</li> <li>1. Start and parallel Division 3 Diesel Generator to Offsite.</li> <li>2. Respond to a RFPT HPU Leak and subsequent RFPT Trip.</li> <li>3. Respond to a Recirc FCV Runback and entry into regions of Power to Flow Map.</li> <li>4. Insert Control Rods to exit undesired regions of Power to Flow Map.</li> <li>5. Diagnose and respond to a Recirc Pump Seal Failure.</li> <li>6. Respond to a Feedwater Line break in the Turbine Building and LOCA in the Drywell.</li> <li>7. Respond to a failure of Division 2 ECCS to initiate.</li> <li>8. Respond to a failure of 2 ADS SRVs to open.</li> </ul>							
Initial Conditions: Reactor Power is at 100 %.							
<ul> <li>INOPERABLE Equipment</li> <li>SRM 'F' are INOP and bypassed.</li> <li>IRMs 'A' &amp; 'H' are INOP and bypassed.</li> <li>APRM 'H' is INOP due to failed <i>downscale</i>.</li> <li>HPCS Pump is tagged out of service for failure of the Jockey Pump.</li> <li>ESF 12 Transformer is tagged out of service for maintenance.</li> <li>RPS 'A' is on Alternate Power due to EPA circuit breaker failure.</li> <li>SBGT 'A' is operating for surveillance.</li> <li>Appropriate clearances and LCOs are written.</li> <li>Turnover: Start and parallel Division 3 Diesel Generator with offsite for engineering testing. There are scattered thunder showers reported in the Tensas Parish area.</li> </ul>							
Event No.	Malf. No.	Event Type*	Event Description				
1		N	Start and parallel Division 3 Diesel Generator. (SOI 04	I-1-01-P81-1)			

REVISION 0 1/11/2007

SCENARIO 3 PAGE 216 of 272


 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 217 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

# JOB PERFORMANCE MEASURE

		(BOP)	
2	1	C (RO)	Respond to a leak on the Hydraulic Power Unit for RFPT 'A' and subsequent RFPT Trip. (ARI 04-1-02-1H13-P680; ONEP 05-1-02-V-6)
		C (RO) TS (SS)	Respond to Recirc Flow Control Valve runback and entry into undesirable regions of the Power to Flow Map (ARI 04-1-02-1H13- P680 and ONEP 05-1-02-III-3) Complete <b>Technical Specification</b> determination.



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 218 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

Appendix D

Scenario Outline

Form ES-D-1

Scenario **3** Day **2** (Continued)

Event No.	Malf. No.	Event Type*	Event Description
3		R (RO)	Insert Control Rods to exit undesired regions of Power to Flow Map. (Control Rod Movement Sheet)
4	2	TS (SS)	Respond to Recirc Pump Seal Failure. (ARI 04-1-02-1H13- P680) Complete <b>Technical Specification</b> determination.
5	3	M (ALL)	Respond to indications of large break LOCA on Feedwater Line in the Turbine Building with Recirc Pump Seal Failure to extreme.
	4	l (BOP)	Respond to a failure of Division 2 ECCS to initiate.
	5	C (BOP)	Respond to a failure of 2 ADS SRVs to open.

(N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor

## Critical Tasks

- When level drops to < -191 inches or after level drops between TAF and 191 inches, opens at least seven SRVs before level drops to 212 inches. Pumps must be running and lined up for injection before reactor pressure decreases to 300 psig.
- Manually initiates Division 2 ECCS when fails to initiate.

**REVISION 0 1/11/2007** 



 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 219 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

JOB PERFORMANCE MEASURE

Scenario **3** Day **2** (Continued)

#### Crew Turnover:

Rx power is at 100% CTP.

SRMs 'F' is INOP and bypassed.

IRMs 'A' & 'H' are INOP and bypassed.

APRM 'H' is failed downscale and bypassed.

ESF 12 Transformer is tagged out of service for maintenance.

RPS 'A' is on Alternate Power due to an EPA circuit breaker failure.

SBGT 'A' is operating for surveillance 06-OP-1T48-M-0001 holding at step 5.2.11 allowing the System Engineer to obtain data.

HPCS Pump and Jockey Pump are out of service due to the Jockey pump motor burned up.

Appropriate clearances and LCOs are written.

Continue plant operations at rated conditions.

Need to start and parallel Division 3 Diesel Generator with offsite for engineering testing. Load the Diesel to at least 2000 KW.

Plant EOOS is 7.3 YELLOW.

There are scattered thunderstorms reported in the Tensas Parish area.

**REVISION 0 1/11/2007** 

SCENARIO 3 PAGE 219 of 272



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 220 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

Simulator Setup: (Scenarios may be setup and shot into encrypted ICs and Password protected.)

Start the process from a new simulator load. Reset to IC-19. Verify or perform the following: IC: 19 OOS: APRM H (Place in Bypass w/ Caution tag) IRMs A & H (Place in Bypass w/ Caution tag) SRMs F (Place in Bypass w/ Caution tag) RPS A (Transfer to Alternate Power and reset RPS A w/ Caution tag) Manually Initiate SBGT A HPCS and HPCS Jockey Pump OOS (Place HPCS OOSVC to OOSVC and place tags on HPCS Pump and Jockey Pump HS) ESF XFMER 12 (Place tag on J3885, 152-1903, 152-1904, 152-1905, 152-1511, 152-1611, 152-1704 HS) Active malfunctions: c51002f SRM F incorporated into present simulator load c51005a IRM A incorporated into present simulator load c51005h IRM H incorporated into present simulator load c71077a RPS A MG failure (Normal EPA OOS) c51010h APRM H downscale Active Remote Functions: p81218 J3885 115KV Disconnect OPEN e22644 HPCS Pump BKR OUT e22646 HPCS JKY pump breaker OPEN 152-1511 lo\_1r21m601a\_g Bus 15AA FDR FM ESF XFMR 12 OFF di 1r21m601ap864/01c Bus 15AA FDR FM ESF XFMR 12 TRIP 152-1611 lo\_1r21m601b\_g Bus 16AB FDR FM ESF XFMR 12 OFF di\_1r21m601bp864/02c Bus 16AB FDR FM ESF XFMR 12 TRIP 152-1704 lo 1e22m709 g 17AC FDR FM ESF 12 OFF di\_1e22m709p601/16c 17AC FDR FM ESF 12 OFF 152-1903 lo 1r21m623 g Bus 15AA/16AB/27AC FDR FM ESF XFMR 12 OFF di 1r21m623p807/01c Bus 15AA/16AB/27AC FDR FM ESF XFMR 12 TRIP 152-1904 lo 1r21m624 g Bus 17AC/25AA/26AB FDR FM ESF XFMR 12 OFF di\_1r21m624p807/01c Bus 17AC/25AA/26AB FDR FM ESF XFMR 12 **REVISION 0 1/11/2007** SCENARIO 3 NUREG 1021 REVISION 9 PAGE 220 of 272



**JOB PERFORMANCE** 

**MEASURE** 

Number: GJPM-SRO-A&E-43 **Revision: 00** Page: 221 of 272 **Rtype: QA Record** Number of pages Date Initials

## TRIP 152-1905 lo\_1r21m637\_g SWYD XFMR T3 FDR FM ESF XFMR 12 OFF di 1r21m637p807/01c SWYD XFMR T3 FDR FM ESF XFMR 12 TRIP rr040f@0 Drywell Pressure channel F downscale rr041f@100 RPV Level Wide Range channel F upscale Active Case File: cae sgtsai.cae SBGT A operating for surveillance Active overrides: di\_1b21m605j AUTO ADS valve B21-F047A fail to manually open di\_1b21m605s AUTO ADS valve B21-F051B fail to manually open Pending overrides: lo 1n21m674a w2 ON HPU Trouble Status Light (TRG 2) Pending malfunctions: p680 2a c5 ON RFPT A GOV VLV CONTR TROUBLE ann. (TRG 2) fw123a RFPT A Trip 3 minute time delay (TRG 2) rr015b1 0 to 100% ramp over 2 minutes Recirc Pump B Seal 1 Failure (TRG 4) rr015b2 0 to 100% ramp over 3 minutes Recirc Pump B Seal 2 Failure (TRG 4) fw070b@100% Feedwater Line 'B' break in Turbine Building (TRG 5) rr063b@4.93% Recirc line 'B' leakage to simulate Feedwater Check Valve leakage ramp 3% to 4.93% over 6 minutes (TRG 5)

Pending component malfunctions: None

**Trigger files:** Trigger 2 RFPT HPU Leak and Feed Pump Trip Trigger 4 Recirc Pump Seal Leak

Trigger 5 Feedwater Line 'A' rupture in Turbine Building

COMPONENT	PANEL	INDICATION or	SIMULATOR	STATUS	DONE
		CONTROL	CODE		
APRM H			c51010h	downscale	
HPCS PUMP	P601-16C		e22644_OUT	OUT	
HPCS Jockey Pump	P601-16C		e22646_OPEN	OPEN	
RPS A on Alternate	P610	Handswitch	c71077a	ALT	
152-1511	P864-1C	Green light	lo_1r21m601a_g	OFF	
	P864-1C	Handswitch	di_1r21m601a	STOP	
152-1611	P864-2C	Green light	lo_1r21m601b_g	OFF	
REVISION 0 1/11/2007	S	CENARIO 3	NUREG	1021 REVIS	ION 9



# JOB PERFORMANCE MEASURE

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 222 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

	P864-2C	Handswitch	di_1r21m601b	STOP
152-1704	P601-16C	Green light	lo_1e22m709_g	OFF
	P601-16C	Handswitch	di_1e22m709	STOP
152-1903	P807-1C	Green light	lo_1r21m623_g	OFF
	P807-1C	Handswitch	di_1r21m623	STOP
152-1904	P807-1C	Green light	lo_1r21m624_g	OFF
	P807-1C	Handswitch	di_1r21m624	STOP
152-1905	P807-1C	Green light	lo_1r21m637_g	OFF
	P807-1C	Handswitch	di_1r21m637	STOP
J3885 115 KV Disconnect	P807-1C	Green Light	p81218	OPEN

Bypass Division 2 APRM Bypass Joystick to APRM H position.

IRMs A and H, SRMs F are bypassed in the IC setup for Cycle 15.

Verify or perform the following:

Open Circuit Breakers 152-1903, 1904, 1905, 1511, 1611, and 1704

Place HPCS OOSVC handswitch to OOSVC.

Place RPS A on Alternate Power and RESET RPS A logic on P680.

Verify SBGT A is operating.

Startup all PDS / SPDS screens. Clear any graphs and trends off of SPDS.

Setup the presently used cyclops display and verify it is functional.

Ensure the correct startup sequence is available at the P680 for the present IC.

Install turnover guide, red tag, and LCO paperwork as applicable.

Advance all chart recorders and ensure all pens are inking properly. (APRM chart recorders must be turned on and settings for scales on pens 0 - 125 scale)

Place tags on ALL circuit breakers associated with the ESF 12 Transformer outage.

Place tags on APRM H, IRM A & H and SRMS F Joysticks.

**REVISION 0 1/11/2007** 

SCENARIO 3 PAGE 222 of 272



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 223 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_

 Date \_\_\_\_\_ Initials \_\_\_\_\_

Place tags on HPCS Pump and Jockey Pump handswitches.

REVISION 0 1/11/2007

SCENARIO 3 PAGE 223 of 272



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 224 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

#### **SIMULATOR OPERATION SCENARIO 3**

Once simulator is reinitialized and setup complete take the simulator out of Freeze.

Once the Crew has taken control note the simulator time.

#### Start and parallel Division 3 DG to offsite

The operator will start and parallel Division 3 Diesel Generator to the bus per SOI 04-1-01-P81-1.

Cues:

If asked, report as Outside Operator actions at the diesel generator as needed.

#### RFPT HPU Leak and RFPT Trip (GGNS OE from Spring 2006 RFPT A Trip)

Two minutes after the Diesel Generator is loaded to the target loading, activate TRIGGER 2.

Cues:

When asked, report as Turbine Building Operator that hydraulic fluid is spraying from the common discharge piping on the 'A' Hydraulic Power Unit and does not appear to be isolable.

#### After three minutes report that both hydraulic pumps for the HPU have tripped.

RFPT A will trip resulting in a Recirc Flow Control Valve Runback. (ONEP 05-1-02-V-6)

Reactor Power to Flow should be in the Restricted Region of the Power to Flow Map. (ONEP 05-1-02-III-3)

#### **Restricted Region of Power to Flow Map**

The crew should take action per the Reduction in Recirc Flow ONEP to exit the Restricted Region of the Power to Flow Map.

REVISION 0 1/11/2007	SCENARIO 3	NUREG 1021 REVISION 9
	PAGE 224 of 272	



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 225 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

The crew should insert control rods per the Control Rod Movement Sequence Cram Rods to lower Reactor Power to exit the Restricted Region.

The crew may reset the Flow Control Valve runback following the power reduction.

The Power to Flow Map is contained in ONEP 05-1-02-III-3 and COLR Manual.

**REVISION 0 1/11/2007** 

SCENARIO 3 PAGE 225 of 272



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 226 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

#### **Recirc Pump Shaft Seal Failure**

Once power is reduced to exit the Restricted Region of the Power to Flow Map, one minute after the SS competes any briefing, <u>activate TRIGGER 4.</u>

The RO will receive annunciators indicating changes in Recirc Pump B seal status.

The SS should dispatch operators to evaluate Drywell Floor and Equipment Sump indications.

Cue:

If asked, as Auxiliary Building Operator report Drywell Equipment Drain flow is up to 20 gpm.

The SS should be determining based on indications the applicability of Tech Spec 3.4.5 RCS Leakage.

SS confers with Duty Manager about requirement to secure Recirc Pump.

Cue:

As Duty Manager, acknowledge the need to secure Recirc Pump B and order the unit to be shutdown. (OE Clinton Power Station)

#### Feedwater rupture in the Turbine Building

Once the Reactor Recirc Pumps are in slow speed and the Lead Evaluator concurs, <u>activate</u> <u>TRIGGER 5.</u>

The reactor will scram on low reactor water level.

All control rods will fully insert.

Crew will implement actions of EP-2 and EP-3.

High Pressure Core Spray is unavailable.

REVISION 0 1/11/2007

SCENARIO 3 PAGE 226 of 272



JOB PERFORMANCE MEASURE

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 227 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_\_

When Recirc System leak becomes active may need to raise the severity to ensure level drops to top of active fuel requiring Emergency Depressurization.

After the LOCA is detected, perform the following attachments when requested.

Attachment 12 Defeat SDC interlocks

4 minutes to DONE

Attachment 25 RPV makeup with Condensate Transfer

Attachment 26 RPV makeup with Fire Systems



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 228 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

Attachments 25 (Condensate Transfer) and 26 (Fire Water) can not be installed by any remote functions just acknowledge the request.

# TERMINATION

Once Reactor level is being restored with Low Pressure ECCS following the High Drywell Pressure condition due to the leakage from Recirc.

#### Critical Tasks

- When level drops to <-191 inches or after level drops between TAF and 191 inches, opens at least seven SRVs before level drops to 212 inches. Pumps must be running and lined up for injection before reactor pressure drops to 300 psig.
- Manually initiates Division 2 ECC when fails to initiate.

#### **Emergency Plan Procedure – Emergency Action Level Classification**

Alert based on 10-S-01-1 Attachment II FS1 Loss or Potential loss of any two fission product barriers.

**REVISION 0 1/11/2007** 

SCENARIO 3 PAGE 228 of 272



**JOB PERFORMANCE** 

**MEASURE** 

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 229 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

Appendix [	)	Operator Actions	Form ES-D-2			
Op-Test N Event Des	Op-Test No.: Scenario No.:3 Event No.:1 Event Description: Startup and parallel Division 3 Diesel (SOI 04-1-01-P81-1)					
Time	Position	Applicant's Actions or Behavior				
	ВОР	Startup and parallel Division 3 Diesel Generator to bu (SOI 04-1-01-P81-1)	s 17AC.			
	BOP	Loads Diesel Generator to 2000 kw and				

Op-Test No.: Scenario No.: <b>3</b> Event No.: <b>2</b>					
Event Description: Respond to leak on Hydraulic Power Unit (HPU) for RFPT 'A'.					
Time	Position	Applicant's Actions or Behavior			
	RO	Reports alarms on RFPT 'A'.			
	SS	Acts on the report of leak of hydraulic fluid on HPU to order the shutdown of RFPT 'A' by either tripping the RFPT or securing it rapidly. (Either method is acceptable.)			

REVISION 0 1/12/2007

ſ

SCENARIO 4 PAGE 229 of 272



**JOB PERFORMANCE** 

**MEASURE** 

Number: GJPM-SRO-A&E-43 Revision: 00 Page: 230 of 272 Rtype: \_\_\_\_\_\_ QA Record Number of pages \_\_\_\_\_ Date \_\_\_\_\_ Initials \_\_\_\_\_

RO	Shuts down RFPT 'A' by the method ordered by the SS. If the RFPT is tripped responds to the Recirc FCV Runback if received.
BOP	Monitors Pressure, Level, Power, and Turbine Loading.
SS	May contact Radwaste of oil and have operator/mechanics attempt to contain oil.

REVISION 0 1/12/2007

SCENARIO 4 PAGE 230 of 272



**JOB PERFORMANCE** 

**MEASURE** 

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 231 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

Appendix D		Operator Actions	Form ES-D-2				
Op-Test Event De	Op-Test No.: Scenario No.:3_ Event No.:2 (Cont.) Event Description: Respond to Recirc Flow Control Valve Runback. (ONEP 05-1-02-III-3 and ARI 04-1-02-1H13-P680)						
Time	Position	Applicant's Actions or Behavior					
	RO	Monitors Recirc Loop Flows and Reactor Power.					
	RO	Determine plant operating conditions for Power to Flow Ma observes operation is in the Restricted Region.	ip and				
	BOP	Monitors Reactor Level Power and Pressure.					
	SS	Determines actions per ONEP 05-1-02-III-3 for operation in Region and exiting the region is required to meet core stat (part of Operating License) and orders insertion of control power.	n the Restricted ility per COLR rods to lower				
	SS	Assigns BOP operator as Thermal Hydraulic Instability wat concurrent duties.	ch with no				

REVISION 0 1/12/2007

SCENARIO 4 PAGE 231 of 272



**JOB PERFORMANCE** 

**MEASURE** 

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 232 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

Appendix D		Operator Actions	Form ES-D-2		
Op-Test No.: Scenario No.:3 Event No.:3 Event Description: Insert Control Rods to exit Restricted Region of Power to Flow Map (Control Rod Movement Sequence and ONEP 05-1-02-III-3)					
Time	Position	Applicant's Actions or Behavior			
	SS	Conducts reactivity brief for insertion of control rods a conditions.	nd target		
	BOP	Performs duties of Thermal Hydraulic Instability watch control rod selections for lowering power.	and verifier of		
	RO	Inserts control rods to lower power to exit the Restricte Power to Flow map. Control Rod Movement Sequence 02-III-3)	ed Region of the e and ONEP 05-1-		

REVISION 0 1/12/2007

SCENARIO 4 PAGE 232 of 272



**JOB PERFORMANCE** 

MEASURE

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 233 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

Appendix	( D	Operator Actions	Form ES-D-2				
Op-Test Event De	Op-Test No.: Scenario No.:3 Event No.:4 Event Description: Respond to Reactor Recirc Pump Seal Failure. (ARI 04-1-02-1H13-680 and GGNS Tech Specs 3.4.5)						
Time	Position	Applicant's Actions or Behavior					
	RO	Respond to annunciation of Seal Failure and determine b indications the Recirc pump failed and which portion of th indicating failure. (ARI 04-1-02-1H13-P680 3A-A12 & 3A- of a failure of both Seals 1 and 2	ased on e seal in B11) Indication				
	SS	Dispatches operators to monitor Drywell Floor and Equipr Sump indications.	nent Drain				
	BOP	Investigates and reports Drywell Floor Drain Sump indicated	tions.				
	SS	Reviews Tech Specs for RCS Operational Leakage and r determinations per Tech Spec 3.4.5	nakes				
	SS	Orders preparations for securing Reactor Recirc Pump B. Duty Manager. Should recommend shutdown of the unit operating single loop. (OE Clinton Power Station)	Confers with rather than				

REVISION 0 1/12/2007

SCENARIO 4 PAGE 233 of 272



**JOB PERFORMANCE** 

**MEASURE** 

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 234 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

Appendi	x D	Operator Actions	Form ES-D-2		
Op-Test No.: Scenario No.:3_ Event No.:5 Event Description: Feedwater Rupture in the Turbine Building with leakage past check values from the Reactor leakage in the Drywell will be elevated					
	(EO	P 05-S-01-EP-2; 05-1-01-EP-3)			
Time	Position	Applicant's Actions or Behavior			
	RO	Recognizes scram on Low Reactor Water level an immediate actions for Reactor Scram. Reports all inserted and places the Reactor Mode Switch to S Performs Scram Report. Part of Scram Report should include APRM power	d performs the rods fully HUTDOWN. r is less than 4%.		
	RO	Recognizes loss of ability to feed the reactor with 0 Feedwater. Communicates the loss to the SS. De conditions, RO may recognize which feed line has Indications of the Turbine Building Sump High leve telltale indication the rupture is in the Turbine Build Condensate and Feedwater are NOT available for	Condensate and spending on rupture. als will be the ding and level control.		
	RO	Secures the Condensate and Feedwater Systems operating pumps.	by tripping all		
	SS	Enters EP-2 and EP-3, orders the BOP Operator to and inhibit ADS (HPCS is tagged out).	o initiate RCIC		

REVISION 0 1/12/2007

SCENARIO 4 PAGE 234 of 272



JOB PERFORMANCE MEASURE Number: GJPM-SRO-A&E-43 Revision: 00 Page: 235 of 272 Rtype: \_\_\_\_\_\_ QA Record Number of pages \_\_\_\_\_ Date \_\_\_\_\_ Initials \_\_\_\_\_

BOP or RO	Verifies/initiates RCIC (If RO/SS determine which Feedwater Line is ruptured allows injection of RCIC due to it injects via the unaffected Feedwater line.) Level band should be +30 to -30 inches.
BOP/RO	Verify Auxiliary Building, Containment, and Drywell isolations, ECCS initiations on -41.6 inches and start of Division III Diesel Generator.
BOP	On orders restores the Auxiliary Building Isolations. (Containment/Drywell)

REVISION 0 1/12/2007

SCENARIO 4 PAGE 235 of 272



REVISION 0 1/12/2007

## GRAND GULF NUCLEAR STATION

JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 236 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

NUREG 1021 REVISION 9

Appendix D		Operator Actions Form ES	-D-2		
Op-Test Event D	Op-Test No.: Scenario No.:3_ Event No.:5 (Cont.)         Event Description: Feedwater Rupture in the Turbine Building with leakage past check         valves from the Reactor leakage in the Drywell will be elevated.				
Time	Position	Applicant's Actions or Behavior			
	SS	Orders CRD maximized and possible initiation of SLC. (Optiona	l)		
	RO/BOP	Maximizes CRD for FLOW per operator aid.			
	SS	Establishes Critical parameters and assigns operators to monitor those parameters.			
	SS	Dispatches EP Attachments to be installed Attachment 12 RHR through Shutdown Cooling Attachment 25 Condensate Transfer injection Attachment 26 Fire Water injection			
	RO/BOP	Reports the lowering RPV water level.			
	RO/BOP	Reports High Drywell Pressure signal and failure of Division 2 to automatically initiate.			

SCENARIO 4

PAGE 236 of 272



**JOB PERFORMANCE** 

**MEASURE** 

Number: GJPM-SRO-A&E-43Revision: 00Page: 237 of 272Rtype: \_\_\_\_\_QA RecordNumber of pages \_\_\_\_\_Date \_\_\_\_\_ Initials \_\_\_\_\_

RO/BC	P Manually initiates Division 2 ECCS.	
-------	---------------------------------------	--

\*\* Critical task

REVISION 0 1/12/2007

SCENARIO 4 PAGE 237 of 272



**JOB PERFORMANCE** 

**MEASURE** 

Number: GJPM-SRO-A&E-43Revision: 00Page: 238 of 272Rtype: \_\_\_\_\_QA RecordNumber of pages \_\_\_\_\_Date \_\_\_\_\_Initials \_\_\_\_\_

Appendix D		Operator Actions Form ES-D-	-2		
Op-Test Event D	Op-Test No.: Scenario No.:3 Event No.:5 (Cont.) Event Description: Feedwater Rupture in the Turbine Building with leakage past check valves from the Reactor leakage in the Drywell will be elevated.				
	(EO	P 05-S-01-EP-2; 05-1-01-EP-3)			
Time	Position	Applicant's Actions or Behavior			
	SS **	Orders alignment of Low Pressure ECCS for injection to the Reactor.			
	BOP/RO **	Align Low Pressure ECCS for injection.			
	SS **	If Reactor Level drops below – 160 inches, orders Emergency Depressurization with 8 SRVs (at least 5 SRVs should be open)			
	BOP/RO **	On orders, opens 8 SRVs using handswitches (initiation pushbuttons may be used initially, however should be followed wit handswitches.) SRVs B21-F047A and B21-F051B will fail to open ONLY 6 SRVs are open.			
	BOP/RO **	Opens two non-ADS SRVs to make 8 SRVs open (minimum is one other to meet 7 SRVs per EOP-2 step ED-5.	Э		
	BOP/RO Verifies injection to the RPV with Low Pressure ECCS.				

REVISION 0 1/12/2007

SCENARIO 4 PAGE 238 of 272



**JOB PERFORMANCE** 

**MEASURE** 

Number: GJPM-SRO-A&E-43 Revision: 00 Page: 239 of 272 Rtype: \_\_\_\_\_\_ QA Record Number of pages \_\_\_\_\_ Date \_\_\_\_\_ Initials \_\_\_\_\_

BOP/RC	Restores level using LP ECCS with band of +30 inches to -30 inches Wide Range.
--------	--

\*\* Critical task

REVISION 0 1/12/2007

SCENARIO 4 PAGE 239 of 272



**JOB PERFORMANCE** 

**MEASURE** 

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 240 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

Appendix D

Scenario Outline

Form ES-D-1

Facility: <b>GR</b>	AND GULF NUCLEAR STATION Scenario No.: 4 Op-Test No.: BACK UP			
Examiners:	Operators:			
Examiners.	Operators			
<ul> <li>Objectives: To evaluate the candidates' ability to operate the facility in response to the following evolutions:</li> <li>1. Start 2<sup>nd</sup> Condensate Pump and Condensate Booster Pump.</li> <li>2. Raise Reactor Power/ Pressure by withdrawing control rods.</li> <li>3. Respond to a stuck control rod.</li> <li>4. Respond to a trip of LCC 15BA3.</li> <li>5. Shift operating CRD pumps.</li> <li>6. Recognize the failure of MSIVs to completely isolate and take actions to isolate the Main Steam Lines.</li> <li>7. Recognize and respond to a steam leak in the Auxiliary Building Steam Tunnel. Take actions for mitigation of the leak with a failure of the MSIVs to fully isolate.</li> <li>8. Take actions per the EOPs in response to three stuck control rods following a Reactor Scram.</li> </ul>				
Initial Cond	itions: Reactor Power is at 1 % plant heatup and pressurization is in progress. The			
Reactor is ≈	400 psig with 1 Condensate and Condensate Booster Pump in service on Startup Level			
Control. Ste	p 50 of the Control Rod Movement Sequence.			
INOPER	ABLE Equipment			
SRM 'F' i	s INOP.			
IRMs 'A'	& 'H' are INOP.			
APRM 'H	' is INOP due to failed downscale.			
LPCS Pu	mp is tagged out of service for motor oil replacement and will be returned to service in			
two (2) ho	Durs.			
ESF-12 I	ransformer is tagged out of service for Entergy – Mississippi maintenance.			

REVISION 0 1/12/2007

SCENARIO 4 PAGE 240 of 272



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 241 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

Appropriate clearances and LCOs are written.

**Turnover:** Continue power ascension. Ready to Start second Condensate and Condensate Booster Pump. There are scattered thundershowers reported in the Tensas Parish area.

REVISION 0 1/12/2007

SCENARIO 4 PAGE 241 of 272



**JOB PERFORMANCE** 

**MEASURE** 

Number: GJPM-SRO-A&E-43Revision: 00Page: 242 of 272Rtype: \_\_\_\_\_QA RecordNumber of pages \_\_\_\_\_Date \_\_\_\_\_ Initials \_\_\_\_\_

Appendix D

Scenario Outline

Form ES-D-1

Scenario 4 Backup (Continued)

Event No.	Malf. No.	Event Type*	Event Description		
1		N (RO)	Start 2nd Condensate and Condensate Booster Pumps. (SOI 04-1-01-N19-1)		
2		R (RO)	Raise reactor power and pressure by withdrawing control rods. (IOI 03-1-01-1 and Control Rod Movement Sheet)		
3	1	C (RO/ BOP) TS (SS)	Respond to a stuck control rod during withdrawal. (ONEP 05-1-02-IV-1) Complete <b>Technical Specification</b> determination.		
4		N (BOP)	Shift operating CRD pump.		
5	2	C (BOP/ RO) TS (SS)	Respond to a trip of Load Control Center 15BA3. (ONEP 05-1-02-I-4; 05-1-02-III-5; and SOI 04-1-01-R21-15) Complete <b>Technical Specification</b> determination.		
6	4	I (BOP)	Recognize the failure of MSIVs to completely isolate and take actions to isolate the Main Steam Lines.		
7	5	M (ALL)	Recognize and respond to a steam leak in the Auxiliary Building Steam Tunnel. Take actions for mitigation of the leak with a failure of the MSIVs to fully isolate.		
	6	C (RO)	Recognize the failure of two additional control rods to fully insert on the Reactor Scram. (Three Rods Out) insert control rods (ONEP 05-1-02-IV-1)		
* (N)orn	* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor				
REVISION 0 1/12/2007 SCENARIO 4 NUREG 1021 REVISION 9					

PAGE 242 of 272



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 243 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_

 Date \_\_\_\_\_ Initials \_\_\_\_\_

**Critical Tasks** 

- When multiple control rod drifts occur, manually scrams the reactor.
- Restore LCC 15BA3 to allow inserting all insertable control rods.

REVISION 0 1/12/2007

SCENARIO 4 PAGE 243 of 272



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 244 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

Scenario 4 BACKUP (Continued)

Crew Turnover:

Rx is at 1% CTP.

Reactor pressure is approximately 400 psig.

Plant Startup and Heat up is in progress.

One Condensate and Condensate Booster Pump are in service on the Startup Level Control Valve.

Control Rod Movement is on Step 50 of the Control Rod Movement Sequence.

APRM 'H' is failed downscale and bypassed.

LPCS Pump is tagged out of service for motor oil replacement. (Expected return to service is two hours)

ESF-12 Transformer is tagged out of service for Entergy – Mississippi maintenance.

Appropriate clearances and LCOs are written.

Continue to bring the plant to full power per IOI-1 step 6.2.13.

Start both a Condensate and Condensate Booster Pump. Radwaste is ready to put on additional Precoat filters and Deep Bed Demineralizers as necessary.

Plant EOOS factor is 9.7 GREEN.

REVISION 0 1/12/2007

SCENARIO 4 PAGE 244 of 272

	GRAND GULF NUCLEAR STATION	Number: GJPM-SRO-A&E-43 Revision: 00 Page: 245 of 272
Entergy	JOB PERFORMANCE MEASURE	Rtype:     QA Record     Number of pages     Date   Initials

Once the Condensate and Condensate Booster Pump are in service, raise Reactor power by withdrawing control rods to 15% Bypass Valve position in preparation for Reactor Feed Pump Startup.

There are scattered thunderstorms reported in the Tensas Parish area.

REVISION 0 1/12/2007

SCENARIO 4 PAGE 245 of 272



Start the process from a new simulator load. Reset to IC-8.

Verify or perform the following:

IC:		8		
OOS:	APRM H (I ] ]	Place in Bypa LPCS Pump ESF XFMER 152-1511, 15	ess w/ Caution tag (Place tag on start 12 (Place tag on 2-1611, 152-1704	) : HS) J3885, 152-1903, 152-1904, 152-1905, HS)
Active malfunction z02 ms1	ns: <b>z02</b> 2 2022_16_3 183b MSIV	2022_16_29 2022022_32_ 7 Control Ro B21-F022B ms184b MSI c51002f SRM c51005a IRM c51005h IRM c51010h API	Control Rod 16-2 <b>13</b> Control Rod 3 d 16-37 stuck failed open ( <b>as-is</b> ) V B21-F028B fai 4 F out of service 1 A out of service 4 H out of service RM 'H' downscal	9 stuck 2-13 stuck led open ( <b>as-is</b> ) (Cycle 15 initial conditions) (Cycle 15 initial conditions) (Cycle 15 initial conditions) e
Remote functions	None			
Active overrides (ins	epatt09 ert overrid	DONE EP A	Attachment 9 Defe lator is initialized	eat MSIV/Group 1 isolation d)
Pending overrides	None			
REVISION 0 1/12/2007		SC PAC	CENARIO 4 GE 246 of 272	NUREG 1021 REVISION 9



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 247 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

Pending malfunctions:

# r21142t LCC 15BA3 trip (TRG 4) ms066b @ 2% ramp to 1% Main Steam Line B steam leak in Auxiliary Building Steam Tunnel (TRG 1).

Pending component malfunctions:

Trigger files: Trigger 4 Loss of LCC 15BA3 Trigger 1 Steam leak in Aux Bldg Steam Tunnel; Automatic Scram Failure and Group 1 Isolation Failure

REVISION 0 1/12/2007

SCENARIO 4 PAGE 247 of 272



**JOB PERFORMANCE** 

**MEASURE** 

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 248 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

COMPONENT	PANEL	INDICATION or CONTROL	SIMULATOR CODE	STATUS	DONE
APRM H			c51010h	downscale	
LPCS PUMP	P601-21C		e21643_OUT	OUT	
152-1511	P864-1C	Green light	lo_1r21m601a_g	OFF	
	P864-1C	Handswitch	di_1r21m601a	STOP	
152-1611	P864-2C	Green light	lo_1r21m601b_g	OFF	
	P864-2C	Handswitch	di_1r21m601b	STOP	
152-1704	P601-16C	Green light	lo_1e22m709_g	OFF	
	P601-16C	Handswitch	di_1e22m709	STOP	
152-1903	P807-1C	Green light	lo_1r21m623_g	OFF	
	P807-1C	Handswitch	di_1r21m623	STOP	
152-1904	P807-1C	Green light	lo_1r21m624_g	OFF	
	P807-1C	Handswitch	di_1r21m624	STOP	
152-1905	P807-1C	Green light	lo_1r21m637_g	OFF	
	P807-1C	Handswitch	di_1r21m637	STOP	
J3885 115 KV Disconnect	P807-1C	Green Light	p81218	OPEN	

Bypass Division 2 APRM Bypass Joystick to APRM H position.

Place LPCS OOSVC handswitch to OOSVC.

Ensure only one Condensate and Condensate Booster Pumps are operating.

Insert control rods in sequence to get at the beginning of step 80 to ensure the Main Steam Bypass Valves are less than 10% open to require control rod movement to raise power and pressure to open the Main Steam Bypass valves

Startup all PDS / SPDS screens. Clear any graphs and trends off of SPDS.

Setup the presently used Cyclops display and verify it is functional.

Ensure the correct startup sequence is available at the P680 for the present IC. Install turnover guide, red tag, and LCO paperwork as applicable.

REVISION 0 1/12/2007	SCENARIO 4	NUREG 1021 REVISION 9		
	PAGE 248 of 272			

	GRAND GULF NUCLEAR STATION	Number: GJPM-SRO-A&E-43 Revision: 00 Page: 249 of 272
Entergy	JOB PERFORMANCE MEASURE	Rtype: QA Record Number of pages Date Initials

Advance all chart recorders and ensure all pens are inking properly. (APRM chart recorders must be turned on and settings for scales on pens 0 - 125 scale)

SCENARIO 4 PAGE 249 of 272



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 250 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

#### **SIMULATOR OPERATION SCENARIO 3**

Once simulator is reinitialized and setup complete take the simulator out of Freeze.

Once the Crew has taken control note the simulator time.

Condensate Pump and Reactivity change may be reversed at the discretion of the SS.

#### Startup of Condensate and Condensate Booster Pump

The Crew will start second Condensate and Condensate Booster Pump per SOI 04-1-01-N19-1. (Condensate Pre-coat Differential Pressure Control Valve N22-F502 is full open)

Simulator Operator will coordinate with the RO for Condensate Pre-coat and Deep Bed Demineralizers as necessary.

#### **Raise Power with control rods**

The Crew will raise reactor power and pressure (opening the Main Steam Bypass Valves to >10% open) by withdrawing control rods. Starting at step 80 of the Control Rod Movement Sequence.

#### Control Rod 16-29 Stuck

When control rod 16-29 is selected to be moved, it is stuck. The Crew will implement actions of the Control Rod/Drive Malfunctions ONEP 05-1-02-IV-1 section 3.5. The Crew will attempt to raise Drive pressure to move the control rod but the control rod will NOT move inward or outward.

Cue:

If asked, respond as Auxiliary Building Operator, the following indications:		
CRD Drive Filter DP	15 psid	
CRD Suction Filter DP	2.2 psid	
CRD Backwash Filter DP	2.2 psid	
CRD Flow Control Valve Station valve lineup and operation is normal.		

REVISION 0 1/12/2007	<b>SCENARIO</b> 4	NUREG 1021 REVISION 9
	PAGE 250 of 272	



When asked, respond as Auxiliary Building Operator with Local CRD Drive Water Pressure from 1C11R006A/B/C/D as the same reading as the computer point C11N008.

If asked, respond as Reactor Engineering, that analysis will have to be performed and an action plan developed. The same applies for System Engineering. At this time it is NOT desired to locally scram the stuck control rod.

The SS should refer to Technical Specifications for actions concerning the stuck control rod. Condition A of Tech Spec 3.1.3.

REVISION 0 1/12/2007

SCENARIO 4 PAGE 251 of 272



JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 252 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

#### **Shift Operating CRD Pumps**

CUE the SS that the Shift Manager noted CRD Pump A is making a strange noise and wants the operating CRD pump transferred to CRD Pump B.

BOP operator will shift operating CRD pumps per SOI 04-1-01-C11-1.

Cues:

When asked, as Auxiliary Building Operator CLOSE CRD Pump B Discharge Valve C11-F217B.

When asked, as Auxiliary Building Operator CRD Pump B is vented via C11-F109B.

CRD PUMP B START

When asked, as Auxiliary Building Operator OPEN CRD Pump B Discharge Valve C11-F217B.

When asked, as Auxiliary Building Operator CLOSE CRD Pump A Discharge Valve C11-F217A.

CRD PUMP A STOP

When asked, as Auxiliary Building Operator OPEN CRD Pump A Discharge Valve C11-F217A. (may elect to leave closed in preparation for tagout.

REVISION 0 1/12/2007

SCENARIO 4 PAGE 252 of 272


GRAND GULF NUCLEAR STATION

JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 253 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

### Loss of LCC 15BA3

Two (2) minutes after the CRD Pump Transfer, activate TRIGGER 4.

Load Control Center 15BA3 will trip. This will result in a closure of Primary Containment and Secondary Containment air operated valves associated with Instrument Air, Plant Service Water, Fire Protection; Standby Gas Treatment Enclosure Building Fan 'A' and RHR 'A' motor operated valves and Jockey Pump.

Cue:

If asked, report as Auxiliary Building Operator, circuit breaker 52-15301 is tripped and cannot be reset.

If asked, report as Electrical Maintenance, the tripper mechanism in the circuit breaker is damaged and there is no apparent damage to the bus or its associated components. A spare breaker can be moved to the LCC and installed to restore the bus.

The Tech Spec Identification for inoperable equipment will a post scenario evolution since the loss of the bus and not regaining the bus until after the main event will preclude adequate time to check inoperable equipment.

04-1-01-R21-15 Attachment I has the load list of affected equipment.

Tech Specs

3.5.1 ECCS – Operating
3.6.1.3 Primary Containment Isolation Valves
3.6.1.7 RHR Containment Spray System
3.6.1.8 Feedwater Leakage Control System
3.6.2.3 RHR Suppression Pool Cooling
3.6.3.2 Primary Containment and Drywell Hydrogen Igniters
3.6.4.2 Secondary Containment Isolation Valves
3.6.4.3 Standby Gas Treatment System
3.8.7 Distribution Systems – Operating

REVISION 0 1/12/2007

SCENARIO 4 PAGE 253 of 272

	GRAND GULF NUCLEAR STATION	Number: GJPM-SRO-A&E-43 Revision: 00 Page: 254 of 272
Entergy	JOB PERFORMANCE MEASURE	Rtype:      QA Record      Number of pages      Date      Initials

SS Tech Spec reviews will occur post scenario.

Based on the loss of Instrument Air the SS will identify a point at which insertion of a manual scram will be ordered.

REVISION 0 1/12/2007

SCENARIO 4 PAGE 254 of 272



GRAND GULF NUCLEAR STATION

JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 255 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

# ATWS

When the RO inserts a manual scram using RPS either the Reactor Mode Switch to SHUTDOWN or depressing of the Manual Scram Pushbuttons, RPS will activate. All control rods will insert with the exception of three (32-13; 16-37; 16-29 are at position 24). This will put operations in EP-2A.

# **Steam Line Break in the Auxiliary Building Steam Tunnel with a failure of MSIVs to isolate** <u>fully</u>

Two minutes after control rods are inserted, <u>activate TRIGGER 1 (Auxiliary Building Steam</u> <u>Tunnel Steam leak with failure of Group 1 isolation</u>).

Three (3) Minutes after Reactor Scram, report as Security white smoke or steam is coming out of the top of the Auxiliary Building.

If contacted, report as Radiation Protection, there are NO abnormal radiation surveys of the Auxiliary Building.

If contacted, report as Chemistry, there is NO leaking fuel bundles in the reactor.

SS will take actions per EP-4 for an uncontrolled, unfiltered, and unmonitored release from Secondary Containment.

Six (6) minutes after Trigger 3, delete malfunction r21142t.

Cue:

Report as Auxiliary Building Operator or Electrical Supervisor, circuit breaker 52-15301 was inadvertently tripped via the manual trip pushbutton and the closing springs were found to be discharged. The closing springs have been recharged and the circuit breaker is ready for closure.

REVISION 0 1/12/2007

SCENARIO 4 PAGE 255 of 272



GRAND GULF NUCLEAR STATION

JOB PERFORMANCE MEASURE 

 Number: GJPM-SRO-A&E-43

 Revision: 00

 Page: 256 of 272

 Rtype: \_\_\_\_\_\_

 QA Record

 Number of pages \_\_\_\_\_\_

 Date \_\_\_\_\_\_ Initials \_\_\_\_\_

**EOP** Attachments:

Attachment 18 Defeat ATWS ARI	4 minutes to DONE
Attachment 19 Defeat RPS	5 minutes to DONE
If Attachment 20 is the only attachment requested cl	hange the time to 3 minutes.
Attachment 20 Defeat RCIS	6 minutes to DONE
Attachment 2 Defeat RCIC Trips	8 minutes to DONE
Attachment 1 Defeat RCIC Suction Xfer	8 minutes to DONE
Attachment 12 Defeat RHR SDC Interlocks	6 minutes to DONE

Call up the full core display to identify which control rod malfunctions to delete. Once Attachments are installed and Control Rods 32-13 and 16-37 are selected for insertion delete malfunctions to allow insertion using RCIS. Maintain control rod 16-29 stuck at its position.

This will allow the SS to make a decision to traverse to EP-2 from EP-2A.

#### TERMINATION

ONCE:

Systems are aligned for RPV level control and pressure control.

And Control Rods 32-13 and 16-37 have been inserted.

And the Lead Evaluator concurs the scenario may be terminated.

Critical Tasks

REVISION 0 1/12/2007

SCENARIO 4 PAGE 256 of 272

	GRAND GULF NUCLEAR STATION	Number: GJPM-SRO-A&E-43 Revision: 00 Page: 257 of 272
Entergy	JOB PERFORMANCE MEASURE	Rtype:      QA Record      Number of pages      Date      Initials

- When multiple control rod drifts occur, manually scrams the reactor.
- Restore LCC 15BA3 to allow inserting all insertable control rods.

# **Emergency Plan Procedure – Emergency Action Level Classification**

Site Area Emergency based on 10-S-01-1 Attachment I EAL SA3.

REVISION 0 1/12/2007

SCENARIO 4 PAGE 257 of 272

Appendix	k D	Operator Actions	Form ES-D-2	
Op-Test No.: Scenario No.:4_ Event No.:1 Event Description: Start second Condensate and Condensate Booster Pump				
(SOI 04-1-01-N19-1 section 4.3)				
Time	Position	Applicant's Actions or Behavior		
	RO	Starts second Condensate Pump. (04-1-01-N19-1 Section 4.3.2a)		
	RO	Starts second Condensate Booster Pump. (04-1-01-N19-1 Section 4.3.2b)		

Events may be reversed by the crew.

Op-Test No.: Scenario No.:4_ Event No.:2 Event Description: Withdraw control rods to raise power. (Control Rod Movement Sequence & 03-1-01-1)			
Time	Position	Applicant's Actions or Behavior	
	SS	Provides Reactivity brief to crew.	
	RO	Verifies control rods and positions per Control Rod Movement Sequence and selects control rods per next gang of control rods. (May select Individual or Gang movement and may select any Control Rod in the Gang.)	
	BOP	Act as Verifier for Control Rod movements.	
REVISIO	ON 0 1/12/2007	SCENARIO 4 NUREG 1021 REVISION 9 PAGE 258 of 272	

RO	Moves Control Rods per Control Rod Movement Sequence. (04-1-01-C11-2 Sections 4.3 and 4.5)
RO	Withdraws control rods to achieve 10% Main Steam Bypass Valve Opening per 03-1-01-1 Section 6.2.13a.

SCENARIO 4 PAGE 259 of 272

Appendi	x D	Operator Actions Form ES-D-2		
Op-Test Event Do <b>(ONEP (</b>	Op-Test No.: Scenario No.:4_ Event No.:3 Event Description: Control Rod 16-29 stuck (ONEP 05-1-02-IV-1 and Technical Specifications 3.1.3 & 3.1.4)			
Time	Position	Applicant's Actions or Behavior		
	RO	Identifies control rod 16-29 will not move with normal drive pressure from CRD.		
	SS	Directs actions per ONEP 05-1-02-IV-1 section 3.5. May skip section 3.5.1. This section is not required based on plant conditions.		
	SS/BOP	Dispatches local operators to check CRD operating parameters.		
	SS	Orders raising CRD Drive Pressure in 25 psid increments.		
	BOP	Adjusts C11-F003 CRD Pressure Control Valve to raise CRD Drive Pressure 25 psid.		
	RO	Attempts to move control rod 16-29 and determines the control rod will not move.		
The steps of raising CRD Drive Pressure and attempting to withdraw the control rod will be repeated up to 475 psid. Once indication on H13-P601 is off scale high indication will either be local or using PDS Computer Point. C11N008.				
	SS	Once CRD Drive Water Pressure is at 475 psid, CRD Drive Water Pressure will be reduced to normal and an alternate control rod will be moved to verify this is not a generic problem. (ONEP 05-1-02-IV-1 Section 3.5.5)		
	RO	Moves alternate Control Rod.		
REVISI	ON 0 1/12/2007	SCENARIO 4 NUREG 1021 REVISION 9		

SCENARIO 4 PAGE 260 of 272

SS Consults Technical Specifications 3.1.3 condition A and 3.1.4 ard contacts System and Reactor Engineering for consideration of scramming control rod 16-29.
--

SCENARIO 4 PAGE 261 of 272

Appendi	x D	Operator Actions Form ES-D-2	
Op-Test No.: Scenario No.:4_ Event No.:4 Event Description: Shift operating CRD Pumps.			
Time	Position	Applicant's Actions or Behavior	
	BOP	Directs local operator to close CRD Pump B discharge valve C11- F217B.	
	BOP	Directs local operator to vent CRD Pump B.	
	BOP	Starts CRD Pump B.	
	BOP	Directs local operator to open CRD Pump B discharge valve C11- F217B.	
	BOP	Directs local operator to close CRD Pump A discharge valve C11- F217A.	
	BOP	Stops CRD Pump A.	
	BOP	Directs local operator to open CRD Pump A discharge valve C11- F217A.	

SCENARIO 4 PAGE 262 of 272

Appendi	x D	Operator Actions	Form ES-D-2
Op-Test No.: Scenario No.:4 Event No.:5 Event Description: Loss of Load Control Center (LCC) 15BA3 (ONEP 05-1-02-I-4, 05-1-02-V-6, SOI 04-1-01-R21-15 and Technical Specification 3.8.7)			
Time	Position	Applicant's Actions or Behavior	
	ВОР	Identifies the loss of power to LCC 15BA3 and that cires of 15301 on H13-P864 is open. (ARI 04-1-02-1H13-P86	rcuit breaker 52- 4 1A-C3 & E3)
	SS	Directs BOP operator to attempt to close circuit break (ONEP 05-1-02-I-4 Section 2.2)	er 52-15301.
	BOP	Attempts to close circuit breaker 52-15301 and deterr did not close and reports to SS.	nines breaker
	SS	Dispatches an operator and electricians to circuit breat to investigate failure.	aker 52-15301
	SS	Takes actions per ONEP 05-1-02-I-4, Loss of AC Pov Response Instructions.	ver and Alarm
	SS	Orders control room operators to determine equipmen affected by the loss.	nt and systems
Systems of primary concern: Instrument Air to Scram Air Header and Main Steam Isolation Valves. Plant Service Water to the plant. Plant Chillers will trip on loss of Plant Service Water Plant Chilled Water isolation valves will eventually close due to loss of Instrument Air			
	SS	Establishes conditions that will warrant inserting a ma scram.	nual reactor
	RO/BOP	Assess equipment affected by the power loss. (04-1-01-R21-15 Attachment I)	
REVISI	ON 0 1/12/2007	SCENARIO 4 NUREG 102 PAGE 263 of 272	1 REVISION 9

SS	<b>POST SCENARIO</b> – Consults Technical Specifications to determine LCO status. (T/S 3 8 7: 02-S-01-17 Attachment II)
	(T/S 3.8.7; 02-S-01-17 Attachment II)

SCENARIO 4 PAGE 264 of 272

Appendi	x D	Operator Actions Fo	orm ES-D-2		
Op-Test Event D (ONEP	Op-Test No.: Scenario No.:4 Event No.:5 (Cont.) Event Description: Loss of Load Control Center (LCC) 15BA3 (ONEP 05-1-02-I-4, 05-1-02-V-6, SOI 04-1-01-R21-15 and Technical Specification 3.8.7)				
Time	Position	Applicant's Actions or Behavior			
	RO**	When multiple control rods begin to drift, places the Read Switch to Shutdown or arms and depresses at least one Scram Pushbutton per RPS Division (A & B).	ctor Mode Manual		
	RO	Reports all control rods have fully inserted except for thre (16-29; 32-13; 16-37)	e		
	SS	Enters EP-2A.			
	RO	Reports downshift of Recirc Pumps to Slow Speed.			
	Depending upon the pace of actions from EP-2A, control rods may begin to drift inward. This is acceptable.				
	RO	On orders initiates ATWS ARI/RPT.			
	BOP	On orders inhibits ADS.			
	BOP	On orders initiates and overrides HPCS.			
	SS	Specifies RPV level band and method of pressure contro	ı.		
	RO	Verifies alignment of Condensate and Feedwater system Startup Level Control and maintains reactor level within le specified by the SS.	s on evel band		

SCENARIO 4 PAGE 265 of 272

BOP	Controls reactor pressure based on orders of SS with Main Steam Bypass valves.
** Critical Task	

SCENARIO 4 PAGE 266 of 272

Appendix D Operator Actions		Form ES-D-2	
Op-Test No.: Scenario No.:4 Event No.:6 Event Description: Respond to a steam leak in Auxiliary Building Steam Tunnel with a failure to isolate. (EP-4) w/ Automatic Scram failure Scenario is geared toward EP-4 actions, stuck control rods are a component malfunction to implement actions for control rod insertion.			
Time	Position	Applicant's Actions or Behavior	
	BOP	Announces Steam Tunnel temperature alarms and failure of Group 1 to isolate.	EP-4 entry and
	BOP**	Manually isolates MSIVs and reports failure of 'B' M to isolate and closes B21-F098B Main Steam Shuto (Operator may close all 4 B21-F098's.)	ain Steam Line ff Valve.
	SS	Enters EP-4 for Steam leak in Auxiliary Building. (S recognize no conditions exist warranting lowering of for ATWS.)	S should reactor level
	SS	Directs Reactor water level control band using Conc Feedwater on Startup Level Control.	lensate and
	RO	Maintains Reactor water level using Condensate an Startup Level Control.	d Feedwater on
	SS	Directs Reactor pressure control using SRVs. (Option	onal)
	BOP	Maintains Reactor pressure using SRVs. (Optional)	
	SS	Directs use of RHR 'B' for Suppression Pool Cooling	g. (Optional)

SCENARIO 4 PAGE 267 of 272

	BOP	Starts RHR 'B' in Suppression Pool Cooling. (Optional)
** Critical	l Task	

SCENARIO 4 PAGE 268 of 272

Appendix D		Operator Actions Fo	orm ES-D-2
Op-Test No.: Scenario No.:4 Event No.:6 (Cont.) Event Description: Respond to a steam leak in Auxiliary Building Steam Tunnel with a failure to isolate. (EP-4) w/ Automatic Scram failure			
Time	Position	Applicant's Actions or Behavior	
	SS	Directs installation of EOP Attachment 20. (May order Attachments 18 and 19 but should not be required if RPN and pressure are being maintained in the normal operatin ATWS ARI may be reset to normal and RPS failed to act order Attachment 21 and if so must clear this attachment facilitate insertion of stuck control rods.)	/ Level ng band. tuate. May to
	RO	Resets ATWS ARI/RPT to allow use of RCIS to insert co	ntrol rods.
	SS	Upon report that LCC 15BA3 is ready to be restored, ord restoration of LCC 15BA3.	ers
	BOP	Restores LCC 15BA3 by closing 52-15301. (SOI 04-1-01-R21-1 section 4.1)	
	BOP	Restores Auxiliary Building isolation valves. (ONEP 05-1-02-III-5)(Auxiliary Building Bypass switches required to complete this.)	are not
	SS	On orders insertion of control rods that are not fully inser (EOP EP-2A and ONEP 05-1-02-I-1 section 3.5.5)	ted.
	RO/BOP	Sets up CRD for driving control rods. (SOI 04-1-01-C11-1 Attachment VIII)	
	RO	Inserts control rods 32-13 and 16-37 (order not specified	).
	RO	Attempts to insert control rod 16-29 and determines cont immovable.	rol rod is
REVISIC	ON 0 1/12/2007	SCENARIO 4 NUREG 1021 RI PAGE 269 of 272	EVISION 9

SS	Determines Reactor will remain sub-critical under all conditions
	without boron and the single control rod stuck out and exits EP-2A

SCENARIO 4 PAGE 270 of 272

APPENDIX E - REGION IV GRAND GULF OPERATING TEST JOB PERFORMANCE MEASURE QUALITY REVIEW MATRIX JPM# 1. Dyn (D/S)2.LOD 4. Job Content Errors 5. (1-5) 3. Attributes U/E/S 6. Explanation (See below for instructions) IC Focus Cues Critical StepsScope (N/B) Overlap Job-Link Minutia ADM-11 S 2 U U All the steps in the JPM are noted as critical. The only step that should be noted as critical is the correct determination of the individual to be on the fire brigade. ADM-12 S 3 U U All the steps in the JPM are noted as critical. The only step that should be noted as critical is the correct determination of the risk being "yellow." ADM-13 S 3 S No comments ADM-14 S 3 S No comments ADM-15 S 3 S No comments D S No comments Sa 3 D S Sb 3 No comments Sc D 3 S No comments S Sd D 3 No comments Se D 3 S No comments Sf D S No comments 4 D Sg 2 S No comments S Pi S 3 No comments Pj S 1 U This JPM does not appear to have discriminatory value. Pk S 3 U U This JPM is evaluated as unsatisfactory due to being a repeat safety function. Instructions for Completing Matrix

This form is not contained in or required by NUREG-1021. Utilities are not required or encouraged to use it. The purpose of this form is to enhance regional consistency in reviewing operating tests. Additional information on these areas may be found in Examination Good Practices Appendix D. Check or mark any item(s) requiring comment and explain the issue in the space provided.

1. Determine whether the task is dynamic (D) or static (S). A dynamic task is one that involves continuous monitoring and response to varying parameters. A static task is basically a system reconfiguration or realignment.

REVISION 0 1/12/2007

SCENARIO 4 PAGE 271 of 272

2.Determine level of difficulty (LOD) using established 1-5 rating scale. Levels 1 and 5 represent inappropriate (low or high) discriminatory level for the license being tested.

- 3. Check the appropriate box when an attribute weakness is identified:
  - The initiating cue is not sufficiently clear to ensure the operator understands the task and how to begin.
  - The JPM does not contain sufficient cues that are objective (not leading).
  - All critical steps (elements) have not been properly identified.
    - Scope of the task is either too narrow (N) or too broad (B).
- Excessive overlap with other part of operating test or written examination.
- 4. Check the appropriate box when a job content error is identified:
  - Topics not linked to job content (e.g., disguised task, not required in real job).
  - Task is trivial and without safety significance.

٠

- 5. Based on the reviewer's judgment, is the JPM as written (U)nacceptable (requiring repair or replacement), in need of (E)ditorial enhancement, or (S)atisfactory?
- 6. Provide a brief description of problem in the explanation column. Provide conclusion on whether JPM <u>SET</u> criteria satisfied (i.e., number/distribution of safety functions, A.3 and A.4 integrated with parts B/C, Admin topics per section meet ES).