



RE: 0730-EQ

August 8, 2007

CERTIFIED MAIL 7006 0810 0004 5717 8545
RETURN RECEIPT REQUESTED

Ms. Roshini Nambiar
Enforcement and Compliance
DEPARTMENT OF ENVIRONMENTAL QUALITY
P.O. Box 1677
Oklahoma City, OK 73101-1677


Re: OPDES Permit OK0000191
Sequoyah Fuels Corporation

Dear Ms. Nambiar:

The ammonia permit limit of 10.5 mg/l was exceeded at Outfall 008 on July 1, 2007 when an ammonia analysis of 23.3 mg/l was measured. The laboratory reported this value to Sequoyah Fuels Corporation (SFC) on August 8, 2007. Andy Potter of the Oklahoma Department Environmental Quality was notified by phone on August 8th. The source of this exceedance is contaminated water present in Pond 2. This is a continuation of a problem that has persisted for the past few months and was described in a letter to you dated June 14, 2007. Planned corrective actions were also described in that letter.

If you have any questions or require further information, you may contact Scott Munson, Environmental Manager, at 918/489-5511 (Extension 20).

Sincerely,


Craig L. Harlin, Director
Regulatory Affairs

CLH:bt

Enclosures: As Stated Above

cc: Linda M. Gersey, NRC Region IV
Mike H. Fliegel, NRC Headquarters