

August 31, 2007

LICENSEE: Entergy Nuclear Operations, Inc.

FACILITY: Pilgrim Nuclear Power Station

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALLS HELD ON
AUGUST 23, 2007 AND AUGUST 27, 2007, BETWEEN THE U.S. NUCLEAR
REGULATORY COMMISSION AND ENTERGY NUCLEAR OPERATIONS, INC.,
CONCERNING REQUESTS FOR ADDITIONAL INFORMATION PERTAINING TO
THE PILGRIM NUCLEAR POWER STATION, LICENSE RENEWAL
APPLICATION

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of Entergy Nuclear Operations, Inc., held telephone conference calls on August 23, 2007 and August 27, 2007, to discuss and clarify the staff's requests for additional information (RAIs) concerning the Pilgrim Nuclear Power Station, license renewal application. The telephone conference calls were useful in clarifying the intent of the staff's RAIs.

Enclosure 1 provides a listing of the participants and Enclosure 2 contain the RAI discussed with the applicant, including a brief description on the status.

The applicant had an opportunity to comment on this summary.

/RA/

Perry Buckberg, Project Manager
License Renewal Branch A
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-293

Enclosures:
As stated

cc w/encls: See next page

August 31, 2007

LICENSEE: Entergy Nuclear Operations, Inc.

FACILITY: Pilgrim Nuclear Power Station

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALLS HELD ON AUGUST 23, 2007 AND AUGUST 27, 2007, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND ENTERGY NUCLEAR OPERATIONS, INC., CONCERNING REQUESTS FOR ADDITIONAL INFORMATION PERTAINING TO THE PILGRIM NUCLEAR POWER STATION, LICENSE RENEWAL APPLICATION

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of Entergy Nuclear Operations, Inc., held telephone conference calls on August 23, 2007 and August 27, 2007, to discuss and clarify the staff's requests for additional information (RAIs) concerning the Pilgrim Nuclear Power Station, license renewal application. The telephone conference calls were useful in clarifying the intent of the staff's RAIs.

Enclosure 1 provides a listing of the participants and Enclosure 2 contain the RAI discussed with the applicant, including a brief description on the status.

The applicant had an opportunity to comment on this summary.

/RA/
Perry Buckberg, Project Manager
License Renewal Branch A
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-293

Enclosures:
As stated

cc w/encls: See next page

DISTRIBUTION: See next page

ADAMS Accession No.: ML072390007

OFFICE	PM:RLRA:DLR	LA:DLR	BC:RLRA:DLR
NAME	PBuckberg	IKing	LLund
DATE	08/31/07	08/30/07	08/31/07

OFFICIAL RECORD COPY

**TELEPHONE CONFERENCE CALL
PILGRIM NUCLEAR POWER STATION
LICENSE RENEWAL APPLICATION**

LIST OF PARTICIPANTS
AUGUST 23, 2007 AND AUGUST 27, 2007

PARTICIPANTS

AFFILIATIONS

Pao-Tsin Kuo	U.S. Nuclear Regulatory Commission (NRC)
Kenneth Chang	NRC
Louise Lund	NRC
Perry Buckberg	NRC
Peter Wen	NRC
James Medoff	NRC
Gary Young	Entergy Nuclear Operations, Inc. (Entergy)
Steve Bethay	Entergy
Bryan Ford	Entergy
Fred Mogolesko	Entergy
Edward Sanchez	Entergy
Alan Cox	Entergy
Rick Plasse	Entergy
David Mannai	Entergy

REQUESTS FOR ADDITIONAL INFORMATION
PILGRIM NUCLEAR POWER STATION
LICENSE RENEWAL APPLICATION

AUGUST 23, 2007 AND AUGUST 27, 2007

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of Entergy Nuclear Operations, Inc. held telephone conference calls on August 23 and August 27, 2007, to discuss and clarify the following request for additional information (RAI) concerning the Pilgrim Nuclear Power Station, license renewal application.

RAI # 4.3.3-1

The license renewal application (LRA) for the Pilgrim Nuclear Power Station listed several reactor coolant pressure boundary components that did not receive a plant-specific metal fatigue analysis and cumulative usage factor (CUF). The applicant generated LRA Commitment No. 31 to address this issue. In the commitment, the applicant committed to take one of the following options or a combination of options to ensure that the time-limited aging analysis (TLAA) on environmentally-assisted fatigue (EAF) of these components, and any other Class 1 components requiring reanalysis for EAF, will be acceptable under 10 CFR 54.21(c)(1) for the period of extended operation:

Option (1): either refine the existing fatigue analyses or perform new fatigue analyses using at least one of four suboptions under this option.

Option (2): manage aging using an aging management program for the period of extended operation.

Option (3): repair or replace the impacted component prior to exceeding a CUF of 1.0.

In order to make a determination on the acceptability of the applicant's TLAA on EAF under the requirements of 10 CFR 54.21(c)(1), the staff requests that the applicant provide additional information on the option(s) that will be used for LRA Commitment No. 31. The applicant is requested to describe the methodology that will be used for the chosen option(s) in detail sufficient for staff review. Specifically, the staff requests that:

- A. If Option (1) is chosen, describe the methodology and the process that will be used to ensure that assumptions, transients, cycles, external loadings, F_{en} values, and analysis methods are valid for the refined or new fatigue analyses.

In the event the refined analyses performed under Option (1) result in CUFs greater than 1.0, describe the option(s) that may be used in addition to Option (1).

- B. If Option (2) is chosen, describe the AMP in sufficient detail with regard to inspection scope, inspection methods, inspection frequency, and inspection qualification techniques.

- C. If Option (3) is chosen, describe how the repair or replacement activity will be implemented in accordance with applicable repair or replacement requirements of the ASME Code Section XI.

Discussion: On August 23, 2007, the staff indicated that the response to this RAI requires clarification. The applicant concurred with the staff's assessment and discussed a new approach to answering the RAI. On August 27, 2007, the applicant described a new response to the RAI that would be submitted to the staff.

Letter to Entergy Nuclear Operations, from P. Buckbery dated August 31, 2007

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALLS HELD ON
AUGUST 23, 2007 AND AUGUST 27, 2007, BETWEEN THE U.S. NUCLEAR
REGULATORY COMMISSION AND ENTERGY NUCLEAR OPERATIONS, INC.,
CONCERNING REQUESTS FOR ADDITIONAL INFORMATION PERTAINING TO
THE PILGRIM NUCLEAR POWER STATION, LICENSE RENEWAL
APPLICATION

DISTRIBUTION:

HARD COPY:

DLR RF

E-MAIL:

PUBLIC

SSmith (srs3)

SDuraiswamy

RidsNrrDir

RidsNrrDirRlra

RidsNrrDirRlrb

RidsNrrDirRlrc

RidsNrrDirReba

RidsNrrDirRebb

RidsNrrDci

RidsNrrDra

RidsNrrDe

RidsNrrDeEemb

RidsNrrDeEeeb

RidsNrrDss

RidsOgcMailCenter

RidsNrrAdes

PBuckberg

SHoffman

SUttal

JShea

AWilliamson

JDavis

KChang

GWilson

CAnderson, RI

WRaymond, RI

NSheehan, RI

Pilgrim Nuclear Power Station

cc:

Regional Administrator, Region I
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406-1415

Senior Resident Inspector
U. S. Nuclear Regulatory Commission
Pilgrim Nuclear Power Station
Post Office Box 867
Plymouth, MA 02360

Chairman, Board of Selectmen
11 Lincoln Street
Plymouth, MA 02360

Chairman
Nuclear Matters Committee
Town Hall
11 Lincoln Street
Plymouth, MA 02360

Chairman, Duxbury Board of Selectmen
Town Hall
878 Tremont Street
Duxbury, MA 02332

Office of the Commissioner
Massachusetts Department of
Environmental Protection
One Winter Street
Boston, MA 02108

Office of the Attorney General
One Ashburton Place
20th Floor
Boston, MA 02108

MA Department of Public Health
Radiation Control Program
Schrafft Center, Suite 1M2A
529 Main Street
Charlestown, MA 02129

Secretary of Public Safety
Executive Office of Public Safety
One Ashburton Place
Boston, MA 02108

Director, Massachusetts Emergency
Management Agency
Attn: James Muckerheide
400 Worcester Road
Framingham, MA 01702-5399

Mr. William D. Meinert
Nuclear Engineer
Massachusetts Municipal Wholesale
Electric Company
P.O. Box 426
Ludlow, MA 01056-0426

Mr. Kevin H. Bronson
Site Vice President
Entergy Nuclear Operations
Pilgrim Nuclear Power Station
600 Rocky Hill Road
Plymouth, MA 02360-5508

Mr. Robert G. Smith
General Manager, Plant Operations
Entergy Nuclear Operations
Pilgrim Nuclear Power Station
600 Rocky Hill Road
Plymouth, MA 02360-5508

Mr. Stephen J. Bethay
Director, Nuclear Safety Assurance
Entergy Nuclear Operations
Pilgrim Nuclear Power Station
600 Rocky Hill Road
Plymouth, MA 02360-5508

Mr. Bryan S. Ford
Manager, Licensing
Entergy Nuclear Operations
Pilgrim Nuclear Power Station
600 Rocky Hill Road
Plymouth, MA 02360-5508

cc:

Mr. John T. Herron
Sr. Vice President
Entergy Nuclear Operations
1340 Echelon Parkway
Jackson, MS 39213

Mr. Oscar Limpias
Vice President, Engineering
Entergy Nuclear Operations
440 Hamilton Avenue
White Plains, NY 10601

Mr. John A. Ventosa
GM, Engineering
Entergy Nuclear Operations
440 Hamilton Avenue
White Plains, NY 10601

Mr. Joseph P. DeRoy
VP, Operations Support
Entergy Operations, Inc.
1340 Echelon Parkway
Jackson, MS 39213

Mr. Michael Kansler
President & CEO/CNO
Entergy Nuclear Operations
1340 Echelon Parkway
Jackson, MS 39213

Mr. John F. McCann
Director, Nuclear Safety & Licensing
Entergy Nuclear Operations
440 Hamilton Avenue
White Plains, NY 10601

Ms. Charlene D. Faison
Manager, Licensing
Entergy Nuclear Operations
440 Hamilton Avenue
White Plains, NY 10601

Mr. Ernest J. Harkness
Director, Oversight
Entergy Nuclear Operations, Inc.
1340 Echelon Parkway
Jackson, MS 39213

Mr. William C. Dennis
Assistant General Counsel
Entergy Nuclear Operations
440 Hamilton Avenue
White Plains, NY 10601

Ms. Stacey Lousteau
Treasury Department
Entergy Services, Inc.
639 Loyola Avenue
New Orleans, LA 70113

Mr. James Sniezek
5486 Nithsdale Drive
Salisbury, MD 21801-2490

Mr. Michael D. Lyster
5931 Barclay Lane
Naples, FL 34110-7306

Ms. Julie Keys
Nuclear Energy Institute
1776 I Street, NW, Suite 400
Washington, DC 20006-3708

Plymouth Public Library
Attn: Dinah O'Brien
132 South Street
Plymouth, MA 02360

Duxbury Free Library
ATTN: Ms. Elaine Winquist
77 Alden Street
Duxbury, MA 02332

Kingston Public Library
ATTN: Reference Librarian
6 Green Street
Kingston, MA 02364

Ms. Mary Lampert
Duxbury Nuclear Advisory, Chair
Pilgrim Watch, Director
148 Washington Street
Duxbury, MA 02332

Pilgrim Nuclear Power Station

-3-

cc:

Mr. Garrett D. Edwards
814 Waverly Road
Kennett Square, PA 19348

Mr. John Doering
P.O. Box 189
Parker Ford, PA 19457