

(1) Maximum Power Level

PSEG Nuclear LLC is authorized to operate the facility at a steady state reactor core power level not in excess of 3459 megawatts (one hundred percent of rated core power).

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 284, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

(3) Deleted Per Amendment 22, 11-20-79

(4) Less than Four Loop Operation

PSEG Nuclear LLC shall not operate the reactor at power levels above P-7 (as defined in Table 3.3-1 of Specification 3.3.1.1 of Appendix A to this license) with less than four (4) reactor coolant loops in operation until safety analyses for less than four loop operation have been submitted by the licensees and approval for less than four loop operation at power levels above P-7 has been granted by the Commission by Amendment of this license.

(5) PSEG Nuclear LLC shall implement and maintain in effect all provisions of the approved fire protection program as described in the Updated Final Safety Analysis Report, and as approved in the NRC Safety Evaluation Report dated November 20, 1979, and in its supplements, subject to the following provision:

PSEG Nuclear LLC may make changes to the approved fire protection program without prior approval of the Commission only if those changes would not adversely affect the ability to achieve and maintain safe shutdown in the event of a fire.

6.9.1.9 CORE OPERATING LIMITS REPORT (COLR)

- a. Core operating limits shall be established prior to each reload cycle, or prior to any remaining portion of a reload cycle, and shall be documented in the COLR for the following:
 1. Moderator Temperature Coefficient Beginning of Life (BOL) and End of Life (EOL) limits and 300 ppm surveillance limit for Specification 3/4.1.1.4,
 2. Control Bank Insertion Limits for Specification 3/4.1.3.5,
 3. Axial Flux Difference Limits and target band for Specification 3/4.2.1,
 4. Heat Flux Hot Channel Factor, F_0 , its variation with core height, $K(z)$, and Power Factor Multiplier PF_{xy} , Specification 3/4.2.2, and
 5. Nuclear Enthalpy Hot Channel Factor, and Power Factor Multiplier, PF_{DH} for Specification 3/4.2.3.
 6. Refueling boron concentration per Specification 3.9.1
- b. The analytical methods used to determine the core operating limits shall be those previously reviewed and approved by the NRC, specifically those described in the following documents:
 1. WCAP-9272-P-A, Westinghouse Reload Safety Evaluation Methodology, (W Proprietary), Methodology for Specifications listed in 6.9.1.9.a.

2. WCAP-8385, Power Distribution Control and Load Following Procedures - Topical Report, (W Proprietary) Methodology for Specification 3/4.2.1 Axial Flux Difference.
 3. WCAP-10054-P-A, Westinghouse Small Break ECCS Evaluation Model Using NOTRUMP Code (W Proprietary), Methodology for Specification 3/4.2.2 Heat Flux Hot Channel Factor.
 4. WCAP-10266-P-A, The 1981 Version of Westinghouse Evaluation Model Using BASH Code, (W Proprietary) Methodology for Specification 3/4.2.2 Heat Flux Hot Channel Factor.
 5. WCAP-12472-P-A, BEACON - Core Monitoring and Operations Support System, (W Proprietary).
 6. CENPD-397-P-A, Improved Flow Measurement Accuracy Using Crossflow Ultrasonic Flow Measurement Technology.
- c. The core operating limits shall be determined such that all applicable limits (e.g., fuel thermal mechanical limits, core thermal hydraulic limits, Emergency Core Cooling Systems (ECCS) limits, nuclear limits such as SDM, transient analysis limits, and accident analysis limits) of the safety analysis are met.
- d. The COLR, including any mid-cycle revisions or supplements, shall be provided upon issuance for each reload cycle to the NRC.

6.9.1.10 STEAM GENERATOR TUBE INSPECTION REPORT

A report shall be submitted within 180 days after the initial entry into HOT SHUTDOWN following completion of an inspection performed in accordance with the Specification 6.8.4.i, "Steam Generator (SG) Program." The report shall include:

- a. The scope of inspections performed on each SG,
- b. Active degradation mechanisms found,
- c. Nondestructive examination techniques utilized for each degradation mechanism,
- d. Location, orientation (if linear), and measured sizes (if available) of service induced indications,
- e. Number of tubes plugged during the inspection outage for each active degradation mechanism,
- f. Total number and percentage of tubes plugged to date, and
- g. The results of condition monitoring, including the results of tube pulls and in-situ testing.