



Tennessee Valley Authority, Post Office Box 2000, Spring City, Tennessee 37381

JAN 18 1995

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

In the Matter of the Application of) Docket Nos. 50-390
Tennessee Valley Authority) 50-391

WATTS BAR NUCLEAR PLANT (WBN) - UNITS 1 AND 2 - NRC INSPECTION REPORT NO.
50-390, 391/94-35 - CHANGE TO PREVIOUS COMMITMENT - NCO940237004

The purpose of this letter is to document the date provided on January 13, 1995, to NRC Resident Inspector Julio Lara concerning a previous commitment involving Violation 50-390, 391/94-35-01, Example 3. In the response to this Violation example dated July 20, 1994, TVA committed to inspect panels 1-R-73 and 1-R-74 and those not previously inspected prior to being transferred and to correct, if necessary, those identified conditions.

During the commitment closure review of Unit 1 required non-transferred panel inspections in the auxiliary instrument room, the line organization's verification identified that at least one cable requiring corrective action was missed and that all of the required inspections could not be confirmed. TVA will complete the corrective actions for this commitment by February 28, 1995.

If you should have any questions, contact P. L. Pace at (615)-365-1824.

Sincerely,

Dwight E. Nunn
Vice President
New Plant Completion
Watts Bar Nuclear Plant

cc: See page 2

9501270066 950118
PDR ADDCK 05000390
PDR

JED 11

JAN 18 1995

cc: NRC Resident Inspector
Watts Bar Nuclear Plant
Rt. 2, Box 700
Spring City, Tennessee 37381

Mr. P. S. Tam, Senior Project Manager
U.S. Nuclear Regulatory Commission
One White Flint North
11555 Rockville Pike
Rockville, Maryland 20852

U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323