

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.3.1.11	<p>-----NOTES-----</p> <ol style="list-style-type: none"> 1. For Function 4, not required to be performed until 12 hours after THERMAL POWER is below the P-10 interlock. 2. For Function 5, not required to be performed until 4 hours after THERMAL POWER is below the P-6 interlock. <p>-----</p> <p>Perform COT.</p>	184 days
SR 3.3.1.12	Perform CHANNEL CALIBRATION.	184 days
SR 3.3.1.13	Perform CHANNEL CALIBRATION.	24 months
SR 3.3.1.14	<p>-----NOTE-----</p> <p>Neutron detectors are excluded from CHANNEL CALIBRATION.</p> <p>-----</p> <p>Perform CHANNEL CALIBRATION.</p>	24 months
SR 3.3.1.15	<p>-----NOTE-----</p> <p>Normalization of the ΔT is not required to be performed until 72 hours after THERMAL POWER is $\geq 98\%$ RTP.</p> <p>-----</p> <p>Perform CHANNEL CALIBRATION.</p>	24 months
SR 3.3.1.16	Perform COT.	24 months
SR 3.3.1.17	Perform TADOT.	24 months