

official

JAN 26 1988

Tennessee Valley Authority
ATTN: Mr. S. A. White
Manager of Nuclear Power
6N 38A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

Gentlemen:

SUBJECT: REPORT NOS. 50-390/87-03 AND 50-391/87-03

Thank you for your revised response of December 31, 1987, to our Notice of Violation issued on July 27, 1987, concerning activities conducted at your Watts Bar facility. We have evaluated your response and found that it meets the requirements of 10 CFR 2.201. We will examine the implementation of your corrective actions during future inspections.

As a result of telephone conversations with your Site Licensing staff on January 12, 1987, we understand that your procedure for preventive maintenance, WBN CEP 1.52, will include, by early February 1988, a requirement for an evaluation when PMs cannot be completed. This evaluation would include any compensatory measures and will be documented on the discrepancy report.

We appreciate your cooperation in this matter.

Sincerely,

ORIGINAL SIGNED BY
KENNETH P. BARR

Kenneth P. Barr, Acting Assistant
Director for Inspection Programs
TVA Projects Division
Office of Special Projects

- cc: G. Toto, Site Director
Watts Bar Nuclear Plant
- J. A. Kirkebo, Director,
Nuclear Engineering
- R. A. Pedde, Project Manager
Watts Bar Nuclear Plant
- R. L. Gridley, Director
Nuclear Safety and Licensing
- W. A. McDonald, Site Licensing
Manager
- TVA Representative, Bethesda
Office

8802020237 880126
PDR ADDCK 05000390
Q PDR

1/0

IE01

JAN 26 1988

Tennessee Valley Authority

2

bcc: ✓ S. D. Ebnetter, OSP
✓ S. D. Richardson, OSP
✓ G. Zech, OSP
✓ B. D. Liaw, OSP
W. S. Little, OSP/RII
S. A. Elrod, OSP/RII
G. K. Hunegs, OSP/RII
✓ J. Rutberg, OGC
WRC Resident Inspector
DRS Technical Assistant
NRC Document Control Desk
State of Tennessee

OSP/RII

for PXT
SElrod:d1m

1/27/88

OSP/RII

WLittle

1/27/88