

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401  
1630 Chestnut Street Tower II

July 2, 1985

U.S. Nuclear Regulatory Commission  
Region II  
Attn: Dr. J. Nelson Grace, Regional Administrator  
101 Marietta Street, NW, Suite 2900  
Atlanta, Georgia 30323

Dear Dr. Grace:

WATTS BAR NUCLEAR PLANT - STEAM GENERATOR LEVEL SETPOINTS AND ALLOWABLE VALUES

In the NRC inspection report 50-390/85-32 a discrepancy was noted concerning Watts Bar Surveillance Instruction (SI) 3.1.18, Steam Generator Level-Channel Calibration. TVA agreed to get Westinghouse to resolve the discrepancy between the Watts Bar technical specification and the Watts Bar Statistical Setpoint Report concerning the setpoint and allowable value for steam generator level. In its letter to TVA dated April 23, 1985, Westinghouse stated that item 13 of Table 2.2-1 in Rev. 0 or Rev. 1 of the Setpoint study should read ". . . between 0 and 35% load . . ." as opposed to ". . . between 0 and 30% load . . . ." This confirms that the Watts Bar technical specifications are correct.

If you have any questions, please get in touch with R. H. Shell at FTS 858-2688.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

*J. A. Hufham*  
J. W. Hufham, Manager  
Licensing and Risk Protection

cc: Mr. James Taylor, Director  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Mr. E. A. Novotnak, Project Manager  
TVA Projects  
Westinghouse Electric Corporation  
P.O. Box 355  
Pittsburgh, Pennsylvania 15230

8508020385 850702  
PDR ADDCK 05000390  
Q PDR