

DMB

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

5N 157B Lookout Place

06 MAR 10 1986 05

U.S. Nuclear Regulatory Commission  
Region II  
Attention: Dr. J. Nelson Grace, Regional Administrator  
101 Marietta Street, NW, Suite 2900  
Atlanta, Georgia 30323

Dear Dr. Grace:

WATTS BAR NUCLEAR PLANT UNIT 1 - FOURTH SUPPLEMENTAL RESPONSE TO DEVIATION  
390/85-33-01 - FAILURE TO MAINTAIN 480 VOLT SHUTDOWN BOARD CIRCUIT BREAKER  
OPEN AND ALARMED IN CONTROL ROOM WHEN THIS CONDITION IS NOT MET

We responded to D. M. Verrelli's letter dated May 7, 1985, report numbers  
50-390/85-33 and 50-391/85-28 concerning the subject deviation by letter dated  
June 14, 1985. Supplemental responses were submitted on August 7,  
September 11, and October 21, 1985. Below is our fourth supplemental response.

In our third supplemental response to the subject deviation, we committed to  
complete corrective actions for the review of the plant walkdown (commitments  
12.002 and 12.005) by November 1, 1985 and repair door C20 (commitment 10.008)  
by November 15, 1985. As discussed with Al Ignatonis on January 6, 1986 and  
Bob Carroll on January 30, and February 20, 1986, these commitments have been  
missed.

Our commitments 12.002 and 12.005 have been rescheduled to June 1, 1986 as a  
result of identification, during the review, that for approximately 10% of the  
areas requiring ALARA review, the walkdown has not been performed. Commitment  
10.008 has a new completion date of April 30, 1986 because of problems in  
determining the appropriate documentation methods. The work on the door  
itself has been completed.

If there are any questions, please get in touch with R. H. Shell at  
FTS 858-2688.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

*R. L. Gridley*  
R. L. Gridley  
Manager of Licensing

cc: Mr. James Taylor, Director  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Records Center  
Institute of Nuclear Power Operations  
1100 Circle 75 Parkway, Suite 1500  
Atlanta, Georgia 30339

8603140189 860303  
PDR ADDCK 05000390  
Q PDR

An Equal Opportunity Employer

/10

IE01