

APPENDIX A

NOTICE OF VIOLATION

Tennessee Valley Authority
Watts Bar Nuclear Plant

License No. CPPR-91

Based on the NRC inspection on January 3-5, 1979, certain of your activities were apparently not conducted in full compliance with NRC requirements as indicated below. These items have been categorized as described in correspondence to you dated December 31, 1974.

As required by Criterion III of Appendix B to 10 CFR 50, as implemented by paragraph 17.1A.3 of Topical Report TVA TR 75-1 titled, "Design Control", and Construction QAP-3.01, titled "Field Change Requests", design changes, including field changes, shall be subject to design control measures commensurate with those applied to the original design and be approved by the organization that performed the original design unless the applicant designates another responsible organization.

Contrary to the above, the design of hanger 74-1RHR-R36 was changed by relocating the lower anchor plate and the hanger installed and approved without being subject to those design control measures.

This is an infraction.

7903200226