

APPENDIX A

NOTICE OF VIOLATION

Tennessee Valley Authority
Watts Bar Nuclear Plant

License Nos. CPPR-91
and CPPR-92

Based on the NRC inspection February 20-23, 1979, certain of your activities were apparently not conducted in full compliance with NRC requirements as indicated below. These items have been categorized as described in correspondence to you dated December 31, 1974.

- A. As required by Criterion V of Appendix B to 10 CFR 50 and implemented by FSAR, paragraph 17.1A.5, "Activities affecting quality shall be prescribed by documented instructions, procedures, or drawings or a type appropriate to the circumstances and shall be accomplished in accordance with these instructions...".

Contrary to the above, on February 21, 1979, the weld reinforcement on both ASME Section III, Class 3 CVCS Holdup Tanks exceeded the maximum specified by ND-4426 of ASME Section III.

This is an infraction.

7906210054