

APPENDIX A
NOTICE OF VIOLATION

Tennessee Valley Authority
Watts Bar Nuclear Plant
Unit 1

License No. CPPR-91

Based on the NRC inspection February 6-9, 1979, certain of your activities were apparently not conducted in full compliance with NRC requirements as indicated below. These items have been categorized as described in correspondence to you dated December 31, 1974.

- A. As required by Criterion V of Appendix B to 10 CFR 50, as implemented by Watts Bar FSAR Section 17.1A.5, appropriate instructions will be used for activities affecting quality. QCP-3.5 requires that electrical cables be installed in raceways as detailed on pull slips and as designated in this procedure.

Contrary to the above, cables 1-4PL-70-4733-A, 1-5PP-212-759-A, and 1-4PL-213-4935-A were not routed in raceways as detailed on their pull slips.

This is an infraction.

7906210108