



State of New Jersey

DEPARTMENT OF ENVIRONMENTAL PROTECTION

Division of Environmental Safety and Health

Radiation Protection and Release Prevention Element

Bureau of Nuclear Engineering

PO Box 415

Trenton, New Jersey 08625-0415

Phone: (609) 984-7700

Fax: (609) 984-7513

JON S. CORZINE
Governor

LISA P. JACKSON
Commissioner

September 6, 2007

United States Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555-0001

Gentlemen:

Subject: Hope Creek Generating Station (HCGS)
Docket No. 50-354
License Change Request (LCR) H07-02

PSEG Nuclear LLC (PSEG) submitted the subject change request to the Nuclear Regulatory Commission (NRC) on July 26, 2007. The proposed change would remove the value for the turbine first stage pressure equivalent to P_{bypass} from the Technical Specifications. P_{bypass} is the reactor power level below which the turbine stop valve closure and turbine control valve fast closure reactor protection system trip functions and the end-of-cycle recirculation pump trips are bypassed automatically.

The New Jersey Department of Environmental Protection's Bureau of Nuclear Engineering reviewed the request in accordance with the requirements of 10 CFR 50.91(b). We have no comments.

If you have any questions, please contact Jerry Humphreys at (609) 984-7469.

Sincerely,

Patrick Mulligan
Acting Manager
Bureau of Nuclear Engineering

A001

MRK

- c: P. Bauldauf, New Jersey DEP, Assistant Director
- N. McNamara, NRC Region I State Liaison Officer
- R. Ennis, NRC Hope Creek Project Manager
- G. Malone, NRC Senior Resident Inspector, Hope Creek
- M. Gaffney, PSEG Hope Creek Regulatory Assurance
- C. Neely, PSEG Director - Regulatory Assurance