

APPENDIX A

NOTICE OF VIOLATION

Tennessee Valley Authority  
Watts Bar

License Nos. CPPR-91  
CPPR-92

Based on the NRC inspection July 28-31, 1980, certain of your activities were apparently not conducted in full compliance with NRC requirements as indicated below. These items have been categorized as described in correspondence to you dated December 31, 1974.

As required by 10CFR50, Appendix B, Criterion XII and implemented by the Watts Bar FSAR Paragraph 17.1A.12 "Tools, Gauges,.... are controlled, calibrated... to written procedures.... These procedures establish the responsibilities and methods..... by which periodic calibration and adjustment schedules are established. WBNP QCP 1.12 "Control and Calibration of Construction Tools, Gauges, Instruments and Measuring Devices" specifies in Table 1 that pressure gauges are to be calibrated every three months.

Contrary to the above, on July 30, 1980, a pressure gauge on a foam generator had not been calibrated which was due for calibration on June 12, 1980. The foam generation was in use when this item was identified.

This is an Infraction.

8103050462